



Engineering & Construction



ENERGY  
ENVIRONMENT  
ENGINEERING

GRE CODE

GRE.EEC.R.24.IT.W.15066.16.005.00

PAGE

1 di/of 2

TITLE:


AVAILABLE LANGUAGE: IT

Nuova SE a 380/150kV "Macomer 380"  
e Raccordi alla RTN  
in entra-esci sulla linea esistente a 380kV  
"ITTIRI – SELARGIUS"

Raccordi alla RTN

Tabella di Picchettazione

File:



00	Apr. 2022	Emissione	3E	3E	EGP
REV.	DATE	DESCRIPTION	PREPARED	VERIFIED	APPROVED

GRE VALIDATION

	NAPOLI	MARLETTA
COLLABORATORS	VERIFIED BY	VALIDATED BY

PROJECT / PLANT

GRE CODE

GROUP	FUNCION	TYPE	ISSUER	COUNTRY	TEC	PLANT	SYSTEM	PROGRESSIVE	REVISION
GRE	EEC	R	24	IT	W	15066	16	005	00

CLASSIFICATION

UTILIZATION SCOPE



Engineering & Construction



ENERGY  
ENVIRONMENT  
ENGINEERING

GRE CODE

GRE.EEC.R.24.IT.W.15066.16.005.00

PAGE

2 di/of 2

<i>numero PICCHETTO</i>	<i>PROGRESSIVA (m)</i>	<i>QUOTA (m)</i>	<i>CAMPATA successiva (m)</i>	<i>DISLIVELLO successivo (m)</i>	<i>ALTEZZA UTILE (m)</i>	<i>ALTEZZA TOTALE (m)</i>	<i>CAMPATA MEDIA (m)</i>	<i>ANGOLO SLINEAMENTO (°)</i>	<i>K costante altimetrica</i>	<i>Tipo PALO</i>	<i>ARMAMENTO</i>
<b>Raccordo Verso Ittiri</b>											
171	0	501.3	364.2	-24.59	33	40.40	0.00	0.0	-	N	S
2A	364	473.7	227.7	-20.49	36	55.70	295.96	90.0	-0.172	E	A
1A	591	462.2	306.4	-14.00	27	34.00	267.08	0.0	-0.118	C	A
P	898	454.2	0	-	21	24.00	-	0.0	-	PORTALE	A
<b>Raccordo Verso Selargius</b>											
P	0	457.6	0	-	21	24.00	-	0.0	-	PORTALE	A
1B	228	460.0	228.1	5.41	24	31.00	268.52	0.0	0.060	C	A
2B	309	467.3	309.0	10.23	27	46.70	350.23	90.0	0.043	E	A
173	391	461.5	391.5	0.18	33	40.40	0.00	0.0	-	N	S