

Input Report

Workspace: 72438-2FSRURegas-14R

FSRU in rigassificazione

Study

72438-2FSRURegas-14R

| Tab | Group | Field | Value | Units |
|----------------------------|-----------------------------|--|-----------------|-------|
| Context of calculations | Selection of context | Weathers to use for this study | Weather folder | |
| | | Parameters to use for this study | Parameter set | |
| | | Obstructions to use for this study | | |
| Bund, building and terrain | Terrain and bund definition | Type of terrain for dispersion | Default terrain | |
| | | Type of pool substrate and bunds | No bund | |
| Toxic parameters | Indoor toxic calculations | Specify the downwind building type | Unselected | |
| | | Building type (downwind building type) | | |
| Dispersion | Distances of interest | Distances of interest | | m |

14R Linee BOG da serbatoi

Pressure vessel

72438-2FSRURegas-14R\FSRU in rigassificazione

| Tab | Group | Field | Value | Units |
|----------------------|----------------------------|--|---|----------|
| Material | Material | Material | GAS NATURALE | |
| | | Specify volume inventory? | Yes | |
| | | Mass inventory | 2250 | kg |
| | | Volume inventory | 380,23 | m3 |
| | | Material to track | GAS NATURALE | |
| | Phase | Specified condition | Pressure/temperature | |
| | | Temperature | 45 | degC |
| | | Pressure (gauge) | 7,5 | bar |
| | | Fluid state | Vapour | |
| | | Liquid mole fraction | 0 | fraction |
| Scenario | Pipe dimensions | Pipe length | | m |
| | Release location | Elevation | 12,5 | m |
| | | Tank head | 0 | m |
| | Direction | Outdoor release direction | Horizontal | |
| | | Outdoor release angle | 0 | deg |
| Discharge parameters | Model settings | Atmospheric expansion method | DNV recommended | |
| | | Phase change upstream of orifice? | Disallow liquid phase change only (metastable liquid) | |
| | Droplet break-up mechanism | Droplet break-up mechanism - instantaneous | Use flashing correlation | |
| | | Droplet break-up mechanism - continuous | Do not force correlation | |

| | | | | |
|-----------------------|---|--|-----------|----------------|
| Short pipe | Pipe characteristics | Pipe roughness | 0,045 | mm |
| | Frequencies | Frequency of bends in pipe | 0 | /m |
| | | Frequency of couplings in pipe | 0 | /m |
| | | Frequency of junctions in pipe | 0 | /m |
| | Frequencies of valves | Frequency of excess flow valves | 0 | /m |
| | | Frequency of non-return valves | 0 | /m |
| | | Frequency of shut-off valves | 0 | /m |
| | Velocity head losses | Excess flow valve velocity head losses | 0 | |
| | | Non-return valve velocity head losses | 0 | |
| | | Shut-off valve velocity head losses | 0 | |
| Time varying releases | Modelling of time-varying leaks and line ruptures | Vacuum relief valve | Operating | |
| | | Vacuum relief valve set point | 0 | bar |
| | Inventory data for time-varying releases | Tank volume | 380,23 | m ³ |
| | | Tank vapour volume | 380,23 | m ³ |
| | | Tank liquid volume | 0 | m ³ |
| | | Tank liquid level | 0 | m |

| | | | | |
|----------------------------|---|--|-----------------|-----|
| | | Maximum vapour release height | 0 | m |
| | | Minimum mass inventory | 0,1 | kg |
| | | Maximum mass inventory | 1E+09 | kg |
| | Safety system modelling for time-varying releases | Safety system modelling (isolation and blowdown) | No | |
| Dispersion | Dispersion scope | Concentration of interest | | ppm |
| | | Averaging time for concentration of interest | | |
| | | Specify user-defined averaging time | No | |
| | | User defined averaging time | | s |
| | Distances of interest | Distances of interest | | m |
| | Averaging time for reports | ERPG [1 hr] | No | |
| | | IDLH [30 mins] | No | |
| | | STEL [15 mins] | No | |
| Bund, building and terrain | Terrain and bund definition | Type of terrain for dispersion | Default terrain | |
| | | Type of pool substrate and bunds | No bund | |
| | Building definition | Release building | | |
| | | In-building release? | Outdoor | |
| | | Building wake effect | None | |
| | | Wind or release | 0 | deg |

| | | | | |
|----------------------|--|--|--------------------------------|----------|
| | | angle from North | | |
| | | Handling of droplets | Trapped | |
| | | Indoor mass modification factor | 3 | |
| Explosion parameters | Explosion method (Consequence calculations only) | Explosion method | Multi-Energy: Uniform confined | |
| | Ignition | Supply late ignition location | No ignition location | |
| | | Location of late ignition | | m |
| | Vapour liquid method | Use explosion mass modification factor | Yes | |
| | | Explosion mass modification factor | 3 | |
| Fireball | Result types to calculate | Calculate probit | No | |
| | | Calculate dose | No | |
| | | Calculate lethality | No | |
| | Radiation levels | Number of input radiation levels | 3 | |
| | | Intensity levels | 4; 12,5; 37,5 | kW/m2 |
| | | Probit levels | 2,73; 3,72; 7,5 | |
| | | Dose levels | 1,27E+06; 5,8E+06; 2,51E+07 | |
| | | Lethality levels | 0,01; 0,1; 0,99 | fraction |
| | Parameters | Mass modification factor | 3 | |
| | | Fireball maximum exposure | 20 | s |

| | | | | |
|-----------|---------------------------|---|-----------------------------|----------|
| | | duration | | |
| | Calculation method | Fireball model | Martinsen time varying | |
| | | TNO model flame temperature | 1726,85 | degC |
| Jet fire | Jet fire method | Jet fire method | Cone model | |
| | Result types to calculate | Calculate probit | No | |
| | | Calculate dose | No | |
| | | Calculate lethality | No | |
| | Radiation levels | Number of input radiation levels | 5 | |
| | | Intensity levels | 3; 5; 7; 12,5; 37,5 | kW/m2 |
| | | Probit levels | 2,73; 3,72; 7,5 | |
| | | Dose levels | 1,27E+06; 5,8E+06; 2,51E+07 | |
| | | Lethality levels | 0,01; 0,1; 0,99 | fraction |
| | Parameters | Rate modification factor | 3 | |
| | | Jet fire maximum exposure duration | 20 | s |
| | Cone model data | Horizontal options | Use standard method | |
| | | Correlation | Recommended | |
| | | Flame-shape adjustment if grounded | Yes | |
| | Surface emissive power | Calculation method for surface emissive power | Calculate SEP | |
| | | Flame emissive power | | kW/m2 |
| | | Emissivity fraction | | fraction |
| Pool fire | Result types to | Calculate probit | No | |

| | | | | |
|----------|------------------|--------------------------------------|-----------------------------|----------|
| | calculate | | | |
| | | Calculate dose | No | |
| | | Calculate lethality | No | |
| | Radiation levels | Number of input radiation levels | 5 | |
| | | Intensity levels | 3; 5; 7; 12,5; 37,5 | kW/m2 |
| | | Probit levels | 2,73; 3,72; 7,5 | |
| | | Dose levels | 1,27E+06; 5,8E+06; 2,51E+07 | |
| | | Lethality levels | 0,01; 0,1; 0,99 | fraction |
| | Parameters | Radiative fraction for general fires | 0,4 | fraction |
| | | Pool fire maximum exposure duration | 20 | s |
| Geometry | Geometry | East | 0 | m |
| | | North | 0 | m |

80mm

Leak

72438-2FSRURegas-14R\FSRU in rigassificazione\14R Linee BOG da serbatoi

| Tab | Group | Field | Value | Units |
|----------------------|----------------------------|--|---|----------|
| Scenario | Hole | Orifice diameter | 80 | mm |
| | | Use specified discharge coefficient? | Yes | |
| | | Discharge coefficient | 0,62 | fraction |
| | Release location | Elevation | 12,5 | m |
| | | Tank head | 0 | m |
| | Direction | Outdoor release direction | Horizontal | |
| | | Outdoor release angle | 0 | deg |
| Material | Material | Material characteristics | Flammable only | |
| | | Material to track | GAS NATURALE | |
| | | Type of risk effects to model | Flammable only | |
| | Phase | Phase to be released | Vapour | |
| Discharge parameters | Model settings | Atmospheric expansion method | DNV recommended | |
| | | Phase change upstream of orifice? | Disallow liquid phase change only (metastable liquid) | |
| | Droplet break-up mechanism | Droplet break-up mechanism - continuous | Do not force correlation | |
| Dispersion | Dispersion scope | Concentration of interest | | ppm |
| | | Averaging time for concentration of interest | | |
| | | Specify user-defined averaging time | No | |

| | | | | |
|----------------------------|-----------------------------|--|--------------------------------|----------|
| | | User defined averaging time | | s |
| | Distances of interest | Distances of interest | | m |
| | Averaging time for reports | ERPG [1 hr] | No | |
| | | IDLH [30 mins] | No | |
| | | STEL [15 mins] | No | |
| Bund, building and terrain | Terrain and bund definition | Type of terrain for dispersion | Default terrain | |
| | | Type of pool substrate and bunds | No bund | |
| Explosion parameters | Explosion method | Explosion method | Multi-Energy: Uniform confined | |
| | Ignition | Supply late ignition location | No ignition location | |
| | | Location of late ignition | | m |
| | Vapour liquid method | Use explosion mass modification factor | Yes | |
| | | Explosion mass modification factor | 3 | |
| Fireball | Result types to calculate | Calculate probit | No | |
| | | Calculate dose | No | |
| | | Calculate lethality | No | |
| | Radiation levels | Number of input radiation levels | 3 | |
| | | Intensity levels | 4; 12,5; 37,5 | kW/m2 |
| | | Probit levels | 2,73; 3,72; 7,5 | |
| | | Dose levels | 1,27E+06; 5,8E+06; 2,51E+07 | |
| | | Lethality levels | 0,01; 0,1; 0,99 | fraction |
| | Parameters | Mass modification factor | 3 | |
| | | Fireball maximum exposure duration | 20 | s |

| | | | | |
|-----------|---------------------------|---|-----------------------------|----------|
| | Calculation method | Fireball model | Martinsen time varying | |
| | | TNO model flame temperature | 1726,85 | degC |
| Jet fire | Jet fire method | Jet fire method | Cone model | |
| | Result types to calculate | Calculate probit | No | |
| | | Calculate dose | No | |
| | | Calculate lethality | No | |
| | Radiation levels | Number of input radiation levels | 5 | |
| | | Intensity levels | 3; 5; 7; 12,5; 37,5 | kW/m2 |
| | | Probit levels | 2,73; 3,72; 7,5 | |
| | | Dose levels | 1,27E+06; 5,8E+06; 2,51E+07 | |
| | | Lethality levels | 0,01; 0,1; 0,99 | fraction |
| | Parameters | Rate modification factor | 3 | |
| | | Jet fire maximum exposure duration | 20 | s |
| | Cone model data | Correlation | Recommended | |
| | | Horizontal options | Use standard method | |
| | | Flame-shape adjustment if grounded | Yes | |
| | Surface emissive power | Calculation method for surface emissive power | Calculate SEP | |
| | | Flame emissive power | | kW/m2 |
| | | Emissivity fraction | | fraction |
| Pool fire | Result types to calculate | Calculate probit | No | |
| | | Calculate dose | No | |
| | | Calculate lethality | No | |
| | Radiation levels | Number of input | 5 | |

| | | | | |
|--|------------|---|--------------------------------|-------------------|
| | | radiation levels | | |
| | | Intensity levels | 3; 5; 7; 12,5; 37,5 | kW/m ² |
| | | Probit levels | 2,73; 3,72; 7,5 | |
| | | Dose levels | 1,27E+06; 5,8E+06; 2,51E+07 | |
| | | Lethality levels | 0,01; 0,1; 0,99 | fraction |
| | Parameters | Radiative fraction for general fires | 0,4 | fraction |
| | | Pool fire maximum exposure duration | 20 | s |

