

SCS ENLIN S.r.l.
 Sede Legale:
 Via F.do Ayroldi, 10
 72017 Ostuni (BR)
 P. IVA 02703630745



CODE

SCS.DES.R.CIV.ITA.W.5681.002.00

PAGE

1 di/of 2

AVAILABLE LANGUAGE: IT

**IMPIANTO EOLICO MONTEMILONE
 COMUNI DI
 MONTEMILONE E VENOSA (PZ)**

Relazione specialistica - Studio anemologico

File name: SCS.DES.R.CIV.ITA.W.5681.002.00_A.5_Studio Anemologico.docx

00	19/02/2024	EMISSIONE	SCS INGEGNERIA	SCS INGEGNERIA	SCS INGEGNERIA
			SCS Team	F. de Castro	A. Sergi
REV	DATE	DESCRIPTION	PREPARED	VERIFIED	APPROVED
IMPIANTO / Plant		CODE			
IMPIANTO EOLICO		GROUP	FUNCION	TYPE	DISCIPLINE
MONTEMILONE		SCS	DES	R	C I V I T A W 5 6 8 1 0 0 2 0 0
CLASSIFICATION:		UTILIZATION SCOPE : PROGETTO DEFINITIVO			



PRELIMINARY WIND
RESOURCE ASSESSMENT
MONTEMILONE

March 2024

Details

A.1.1 Prepared for:

Client: SCS Ingegneria S.r.l.

Contact: Francesco de Castro

Reference: VRIT230350

A.1.2 Prepared by:

Vector Renewables S.r.l.

Via Alberto Falck, 4/16, Sesto San Giovanni, Milano • +39 02 87 36 68 56

Contact details

Contact Name	Position	Email
Chiara Pavan	Head of Technical Advisory – Italy	acervetto@vectorenrenewables.com
Nell Franchi	Technical Advisory – Italy	nfranchi@vectorenrenewables.com
Gianmarco Palma	Technical Advisory – Italy	gpalma@vectorenrenewables.com

Version control

Version	Description	Date	Drafted	Reviewed	Approved
V00	Initial version	08/07/2022	NF	IP	AC
V01	Updated layout	07/10/2022	NF	CP	AC
V02	Updated layout	11/08/2023	NF	GP	CP
V03	Updated WTG model	05/03/2024	NF	GP	CP



Disclaimer

The contents of this document have been prepared by Vector Renewables Italia S.r.l. (hereinafter, "Vector Renewables") based on its knowledge, the present project information, as well as the current legislation and the wind and photovoltaic market according to its experience in the renewable energy sector and, particularly, in the auditing and consultancy of wind and photovoltaic facilities. Therefore, the results, analysis and comments included in this document shall be solely interpreted under such considerations.

Estimates, conclusions, and recommendations included in this document are based on information which has been considered correct, provided by reliable and verified databases as well as the best practice standards and estimates by Vector Renewables. Notwithstanding the above, it is not possible to guarantee the integrity and accuracy of such information, especially in relation to forecasts or future projections as long as the whole information needed or required for its production has not been received or its accuracy not verified. In this sense, Vector Renewables, its partners, affiliates, directors, or employees are not responsible for the accuracy, completeness or veracity of the information contained herein or conclusions or decisions made, based on false, incomplete or inaccurate information.

The content of this document is strictly limited to the matters that are addressed herein. In this sense, in no case should be understood that the content can be applied by analogy to other issues that it does not make explicit reference. The content of this document does not necessarily cover every matter of the topics dealt herein.

Vector Renewables, its partners, affiliates, directors or employees accept no responsibility for the results that any interested third party may produce, either for direct damages or for any damages which, directly or indirectly, could be derived from decisions or considerations based on this document, or any use that the recipient may make of this document.

With regards to the liability Vector Renewables may be made responsible for as an independent Technical Advisor, this will not exceed, under any circumstance, the fees agreed to carry out the services for which Vector Renewables has been hired, and in any case, will exclude indirect or consequential damages, lost profits, damages or opportunity costs. Vector Renewables will respond solely and exclusively to the recipient or the petitioner of the service excluding any liability towards any third party involved directly or indirectly in the project.

This document has an informative and confidential nature and does not represent a report for qualified expert opinion purposes to be used in a court or at a trial, nor is it a legal or a fiscal report. It is therefore, intended solely and exclusively for such purposes to the recipient or borrower, with its exhibition, distribution, or reproduction without the prior written consent of Vector Renewables being prohibited. The use of this document for others than those uses agreed will need prior written consent by Vector Renewables.

In case of using this document for other purposes not agreed or without prior written consent by Vector Renewables will lead to Vector Renewables to be entitled to claim an additional 20% to the fees received for the elaboration of this document, all without prejudice to legal action under the applicable law that may correspond for any damages that were caused.

The reception of this document by its recipient implies the full acceptance of this "Disclaimer".



Contents

1. Foreword	4
2. Supplied Material	5
2.1. Proposed area and layout	5
2.2. Wind turbine model	9
3. Wind resource assessment	10
4. Preliminary expected energy yield assessment	11
5. Conclusions	13



1. FOREWORD

SCS Ingegneria S.r.l. (the "Client") engaged Vector Renewables Italia S.r.l. (formerly Windfor S.r.l.) as "Technical Advisor" to perform a preliminary analysis for the definition of the wind resource of an area located in Italy, municipality of Montemilone, Province of Potenza, in Basilicata to evaluate the potential of the Montemilone wind farm (the "Project").

A first analysis was undertaken in July 2022 resulting in a preliminary layout designed by the Technical Advisor for the Project, whose details are described in the report RVRIT22170 V00. In October 2022 and August 2023 revision V01 and V02 respectively of the report were issued for a new layout provided by the Client.

The current analysis consisted in the update of the former energy assessment, assuming the same wind resource assessment and wind flow model already performed and described in the above-mentioned report, for a new configuration provided by the Client:

Turbine model	Hub height [m]	Number of turbines	Wind farm capacity [MW]
13xSG 7.0-170	115.0	13	91.0

Tab. 1 - Configuration of Montemilone wind farm

The activity consisted in the preliminary estimation of the expected annual energy production of each wind farm configuration, according to the Technical Advisor's analysis on the long-term wind regime representative of the area at the desired hub height.

As requested by the Client, the Energy Assessment has been performed by adopting WAsP 12 model propagation as embedded in WindPRO 4.0. Considering that a measurement campaign recorded onsite is not yet available, the preliminary estimation of the expected annual energy production of the Project is extrapolated from a Virtual Met Mast obtained by using the sources available in the area deemed as representative, such as land-based wind data and re-analysis data.

It is necessary to emphasize that the Virtual Met Mast does not replace a traditional on-site measurement mast. Therefore, any assessment of the energy production will have a high uncertainty: the results shall be intended as a **preliminary estimation only** and they should be updated when a full year measurement campaign onsite is available.



The proposed area lies on a hilly and moderately complex terrain at about 300 m a.s.l. with low roughness.

The height contours and roughness maps to be included in the wind flow model were not provided and therefore they were downloaded from online sources covering an area of about 20 km x 20 km. In particular, the elevation map was retrieved from the Italian digital elevation model (DEM) Tinitaly, that has been created from individual DEMs from the administrative regions of Italy, with the grid resolution of 10m. The roughness map was downloaded from the Corine Land Cover 2018 database.

The metric coordinates of the provided layout are shown in the following table.

UTM WGS84 Zone 33		
Turbine ID	Longitude [m]	Latitude [m]
WTG01	575967	4542517
WTG02	576643	4542735
WTG03	578021	4541810
WTG04	579127	4542620
WTG05	579787	4542420
WTG06	579353	4543851
WTG07	579812	4544422
WTG08	580930	4544363
WTG09	580936	4545233
WTG10	581930	4544146
WTG11	582675	4546363
WTG12	582093	4546942
WTG13	582727	4547276

Tab. 2 - Montemilone wind farm coordinates

The layout of the Project is shown in the following figure.






Fig. 2 - Map of the site with proposed Montemilone wind turbines

The next table shows the distances among the closest turbines in meters and in diameters of 170 m rotor for the 13 turbines for the proposed layout.

All turbines are spaced by minimum 4.1 rotor diameters. Nevertheless, it is recommended to obtain the turbine manufacturer's Mechanical Load assessment and site suitability Analysis (MLA), in order to ensure that the fatigue loads, resulting from the wind conditions onsite and acting on the turbine main components, are within the design load envelope.



ID	Nearest WTG	Horizontal distance	Rotor diameters	Distance in rotor diameters
		[m]	[m]	[RD]
WTG01	WTG02	710	170	4.2
WTG02	WTG01	710	170	4.2
WTG03	WTG04	1371	170	8.1
WTG04	WTG05	690	170	4.1
WTG05	WTG04	690	170	4.1
WTG06	WTG07	733	170	4.3
WTG07	WTG06	733	170	4.3
WTG08	WTG09	870	170	5.1
WTG09	WTG08	870	170	5.1
WTG10	WTG08	1023	170	6.0
WTG11	WTG12	821	170	4.8
WTG12	WTG13	717	170	4.2
WTG13	WTG12	717	170	4.2

Tab. 3 - Montemilone wind farm spacings

The existing wind farm consists of n. 12 Vestas V126-3.3 MW turbines with a hub height of 94 m, located at a distance of about 20 diameters of a 170 m rotor to the North-West of the Project. These turbines will be included in the wake model to account for the potential interference with the Project. Instead, the evaluation of the impact of the Project on existing wind turbines is outside the current scope of the work.


It is noted that several wind farms are under development in the area but have not been included in the assessment since not yet authorized. In case new information is available on the wind farms under development, it is recommended to update the study accordingly.



2.2. Wind turbine model

The expected energy production of the wind farm is estimated considering the following wind turbine model, as requested by the Client, whose power curve has been provided at the air density of 1.225 kg/m³ and then adjusted to the site air density of 1.17 kg/m³, according to the IEC 61400-12 method correction within the WindPRO 4.0 software.

Turbine type		SG 7.0-170	Diameter [m]	170.0
Rated power [MW]		7.0	Hub height [m]	115.0
Rated wind speed [m/s]		14.0	IEC class	S
Cut-in/Cut-out [m/s]		3.5/25.0	Air density [kg/m ³]	1.225
Bin wind speed [m/s]	Power [kW]	Thrust coefficient [-]		
0.0	0	0		
1.0	0	0		
2.0	0	0		
3.5	148	0.929		
4.0	310	0.870		
5.0	751	0.826		
6.0	1374	0.821		
7.0	2221	0.814		
8.0	3318	0.798		
9.0	4659	0.762		
10.0	5950	0.672		
11.0	6728	0.540		
12.0	6962	0.412		
13.0	6997	0.314		
14.0	7000	0.246		
15.0	7000	0.198		
16.0	7000	0.162		
17.0	7000	0.135		
18.0	7000	0.114		
19.0	7000	0.098		
20.0	6737	0.081		
21.0	6212	0.065		
22.0	5687	0.053		
23.0	5162	0.043		
24.0	4900	0.037		
25.0	4900	0.034		



Tab. 4 – SGRE SG 7.0-170, power and C_t curves

3. WIND RESOURCE ASSESSMENT

Considering that a measurement campaign recorded onsite is not yet available, the preliminary estimation of the expected annual energy production of the Project is extrapolated from a Virtual Met Mast downscaled to a representative location of the wind farm at the desired hub heights. The Virtual Met Mast statistics is obtained by using the sources available in the area deemed as representative, such as land-based wind data and re-analysis data.

It is necessary to emphasize that the Virtual Met Mast does not replace a traditional on-site measurement mast and therefore any assessment of the energy production will have a high uncertainty. Therefore, the results shall be intended as a **preliminary estimation only**. It is recommended to install at least one met mast onsite, whose structure should be high at least 2/3 of the proposed hub height in order to reduce the vertical extrapolation and update the analysis accordingly.

The Virtual Met Mast has been aligned to the long-term wind regime expected onsite by correlation with 20-year ERA5T re-analysis data and has been interpolated to the hub height of 115 m. In the figures below, the following wind conditions modelled at the Virtual Met Mast location, are reported in Fig. 3:

- Energy rose split into five wind speed classes and 12 sectors
- Wind rose split into five wind speed classes and 12 sectors

Investigating concurrent wind roses of different locations in the area, significant disagreements are detected, both among land-based and re-analysis data. It is again strongly recommended to plan a thorough measurement campaign at site.




Fig. 3 - Wind conditions at the Virtual Met Mast



4. PRELIMINARY EXPECTED ENERGY YIELD ASSESSMENT

The expected energy production of the Montemilone wind farm has been estimated with the wind turbine configurations requested, using the long-term frequency distribution at the hub height and adopting the WAsP 12 model propagation as embedded in WindPRO 4.0. The wake model implemented in the analysis is the N.O. Jensen (RISO/EMD) Park2 2018 wake model with DTU default onshore wake decay constant of 0.090.

The energy production accounts for the losses due to wake effects and to the site air density. To be noted that for the energy assessment only the operational wind turbines have been included in the wake modelling.

The tables hereunder contain the following information for each wind turbine:

Site ID: ID number of the wind turbine in the tables

X [m]: longitude in **UTM WGS84 Zone 33** coordinates

Y [m]: latitude in **UTM WGS84 Zone 33** coordinates

Elev. [m]: elevation above sea level (ASL)

HH [m]: hub height

V [m/s]: average wind speed estimated by the model at hub height

Gross Production [GWh]: expected gross output, gross and net of wake losses

Loss [%]: percent of production lost due to wake losses

Equivalent Hours [h]: equivalent annual hours of gross production, net of wake losses



ID	X [m]	Y [m]	Elev. [m]	HH [m]	V [m/s]	Gross Production [GWh]		Wake Loss [%]	Net Hours [h]	
						Gross of wakes	Net of wakes			
WTG01	575967	4542517	336	115.0	6.14	17.58	17.26	1.83	2465	
WTG02	576643	4542735	335	115.0	6.10	17.36	16.01	7.76	2288	
WTG03	578021	4541810	340	115.0	6.09	17.32	17.14	1.05	2448	
WTG04	579127	4542620	330	115.0	6.13	17.49	16.01	8.45	2287	
WTG05	579787	4542420	340	115.0	6.18	17.81	16.66	6.46	2380	
WTG06	579353	4543851	320	115.0	6.12	17.41	16.80	3.50	2400	
WTG07	579812	4544422	320	115.0	6.17	17.71	16.57	6.45	2366	
WTG08	580930	4544363	320	115.0	6.13	17.47	15.70	10.17	2242	
WTG09	580936	4545233	310	115.0	6.21	17.97	17.09	4.92	2441	
WTG10	581930	4544146	330	115.0	6.35	18.69	17.57	5.99	2510	
WTG11	582675	4546363	280	115.0	6.23	18.10	17.41	3.80	2487	
WTG12	582093	4546942	290	115.0	6.45	19.34	18.65	3.57	2665	
WTG13	582727	4547276	270	115.0	6.33	18.63	17.14	8.02	2448	
					Average	6.20	17.91	16.92	5.54	2417
					Total	232.87	219.98			

Tab. 5 – Montemilone energy production

It should be noted that the energy production presented above accounts only for the losses due to air density and wake effects and no other losses are included. Overall, the wake losses are reasonable with a maximum loss of 10.2% on turbine WTG08.

At this preliminary stage, a reasonable assumption of the additional losses related to turbine, B.O.P. and grid availability, electrical plant, environment, turbine performance and excluding any potential curtailment consists of about **9/10%** for a **10-year period**. A more detailed evaluation could be performed when supply or O&M agreement are in place or even at a discussion phase.

The following table summarizes the results obtained for the Project:

Configuration	Wind farm capacity [MW]	Gross production (net of wakes)		Net production (deliverable to grid)	
		[GWh/year]	[h/year]	[GWh/year]	[h/year]
13xSG 70-170	91.0	219.98	2417	199.09	2188

Tab. 6 – Gross and Net energy production

The expected net production estimates (deliverable to grid) shown in the table above, represent the so-called P_{50%}, i.e. the production calculated with the average wind conditions, also called central estimate.



5. CONCLUSIONS

The activity of the current assessment consisted in the preliminary estimation of the expected annual energy production of the Montemilone wind farm. The study was based on the analysis of the long-term wind regime representative of the area at the desired hub heights, according to the expected wind statistics at the site extrapolated from a Virtual Met Mast downscaled to a location deemed as representative of the wind farm.

It is necessary to emphasize that the Virtual Met Mast does not replace a traditional on-site measurement mast and therefore any assessment of the energy production will have a high uncertainty. Therefore, the results shall be intended as a **preliminary estimation only**.

In order to reduce the uncertainties and to achieve a bankable project, at least one met mast shall be installed onsite and update the analysis accordingly. The location of the mast should be selected to be well exposed with respect to the prevailing wind direction and well representative of the turbine locations. The structure of such mast should be sufficiently high to reduce uncertainty related to the vertical extrapolation: a height of at least 2/3 of the proposed hub height is recommended.

The analysis accounts for wake losses induced by n. 1 operational wind farm located nearby the Project. It is noted that several wind farms are under development in the area but have not been included in the assessment since not yet authorized. In case new information is available on the wind farms under development, it is recommended to update the study accordingly.

At this preliminary stage, a reasonable assumption of the additional losses related to turbine, B.O.P. and grid availability, electrical plant, environment, turbine performance and excluding any potential curtailment consists of about **9/10%** for a **10-year period**. A more detailed evaluation could be performed when supply or O&M agreement are in place or even at a discussion phase.

In addition, it is recommended to verify that the desired wind turbine model will be appropriate for the site according to IEC 61400-1 Standard Ed.3 by defining the site class in terms of the extreme wind speed at hub height with a recurrence period of 50 years averaged over a period of 10 minutes and the representative turbulence levels.



Vector Renewables



Expertise and insights gained as Asset Manager of more than **3.5 GW**



70 GW of experience including solar PV and wind power services



Experience in more than **40** countries worldwide



Multidisciplinary team composed of over **200** employees



Offices in **10** countries



15 years in the renewable energy industry

