

00	06/02/2024	ELABORATO GRAFICO	ING. D. TOMARCHIO	ING. F. RAPICAVOLI	ING. F. RAPICAVOLI
REVISIONE	DATA	DESCRIZIONE	PREPARATO	CONTROLLATO	VALIDATO



CODICE IDENTIFICATIVO ELABORATO

17-PD.00

SOCIETÀ PROPONENTE

TIMBRO E FIRMA



CERO ITALY PROJECTS 1 S.R.L.
 Via MELCHIORRE GIOIA 8, 20124 (MI)
 P.IVA 12517980962
 PEC: ceroitalyprojects1@legalmail.it

TITOLO INIZIATIVA

PROGETTO PER LA REALIZZAZIONE DI UN IMPIANTO AGRIVOLTAICO DENOMINATO " SAN GIULIANO ",
 DI POTENZA NOMINALE PARI A 80MW INTEGRATO DA UN SISTEMA DI ACCUMULO DA 100MW,
 SITO NEL COMUNE DI BUTERA (CL)

SOCIETÀ PROGETTAZIONE

TIMBRO E FIRMA TECNICO ABILITATO

ETERNA S.R.L.
 Via Manganelli 20/g
 95030 Nicolosi (ct)
 tel: 095914116 - cell: 3339533392
 P.IVA 05944070878
 PEC: eterna@arubapec.it

FORMATO

A4

SCALA

FOGLIO

TITOLO DOCUMENTO

RELAZIONE ANALISI DI PRODUCIBILITA'

LIVELLO DI PROGETTAZIONE

PROGETTO DEFINITIVO

PVsyst - Simulation report

Grid-Connected System

Progetto: Butera 80 MW

PV Area Est

Impianto a strutture fisse

System power: 39.24 MWp

Pozzillo - Italy

**PVsyst V7.4.6**

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Project summary

Geographical Site		Situation		Project settings	
Pozzillo		Latitude	37.23 °N	Albedo	0.20
Italy		Longitude	14.23 °E		
		Altitude	343 m		
		Time zone	UTC+1		
Weather data					
Butera					
SolarGIS Monthly aver. , period not spec. - Sintetico					

System summary

Grid-Connected System		Impianto a strutture fisse			
Simulation for year no 1					
PV Field Orientation		Near Shadings		User's needs	
Fixed plane		According to strings : Fast (table)		Unlimited load (grid)	
Tilt/Azimuth	25.1 / 0.7 °	Electrical effect	100 %		
System information					
PV Array					
Nb. of modules		58140 units	Inverters	Nb. of units	31 units
Pnom total		39.24 MWp		Pnom total	34.10 MWac
				Pnom ratio	1.151

Results summary

Produced Energy	69059392 kWh/year	Specific production	1760 kWh/kWp/year	Perf. Ratio PR	86.82 %
-----------------	-------------------	---------------------	-------------------	----------------	---------

Table of contents

Cover page	1
Project and results summary	2
General parameters, PV Array Characteristics, System losses	3
Horizon definition	8
Near shading definition - Iso-shadings diagram	9
Main results	10
Loss diagram	11
Predef. graphs	12
P50 - P90 evaluation	18
CO ₂ Emission Balance	19



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

General parameters

Grid-Connected System		Impianto a strutture fisse			
PV Field Orientation		Sheds configuration		Models used	
Orientation		Nb. of sheds	1938 units	Transposition	Perez
Fixed plane		Identical arrays		Diffuse	Perez, Meteonorm
Tilt/Azimuth	25.1 / 0.7 °	Sizes		Circumsolar	separate
		Sheds spacing	8.40 m		
		Collector width	4.79 m		
		Ground Cov. Ratio (GCR)	57.0 %		
		Shading limit angle			
		Limit profile angle	26.6 °		
Horizon		Near Shadings		User's needs	
Average Height	5.9 °	According to strings : Fast (table)		Unlimited load (grid)	
		Electrical effect	100 %		
Bifacial system					
Model	2D Calculation				
	unlimited sheds				
Bifacial model geometry		Bifacial model definitions			
Sheds spacing	8.40 m	Ground albedo	0.20		
Sheds width	4.79 m	Bifaciality factor	80 %		
Limit profile angle	26.6 °	Rear shading factor	10.0 %		
GCR	57.0 %	Rear mismatch loss	10.0 %		
Height above ground	1.50 m	Shed transparent fraction	0.0 %		

PV Array Characteristics

PV module		Inverter	
Manufacturer	CSI Solar	Manufacturer	Sungrow
Model	CS7N-675TB-AG 1500V	Model	SG1100-UD
(Original PVsyst database)		(Custom parameters definition)	
Unit Nom. Power	675 Wp	Unit Nom. Power	1100 kWac
Number of PV modules	58140 units	Number of inverters	31 units
Nominal (STC)	39.24 MWp	Total power	34100 kWac
Array #1 - Sottocampo #16			
Number of PV modules	10800 units	Number of inverters	6 units
Nominal (STC)	7290 kWp	Total power	6600 kWac
Modules	360 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	6743 kWp	Pnom ratio (DC:AC)	1.10
U mpp	1078 V		
I mpp	6254 A		
Array #2 - Sottocampo #17			
Number of PV modules	1920 units	Number of inverters	1 unit
Nominal (STC)	1296 kWp	Total power	1100 kWac
Modules	64 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	1199 kWp	Pnom ratio (DC:AC)	1.18
U mpp	1078 V		
I mpp	1112 A		



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

PV Array Characteristics

Array #3 - Sottocampo #18

Number of PV modules	5850 units	Number of inverters	3 units
Nominal (STC)	3949 kWp	Total power	3300 kWac
Modules	195 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3652 kWp	Pnom ratio (DC:AC)	1.20
U mpp	1078 V		
I mpp	3388 A		

Array #4 - Sottocampo #19

Number of PV modules	3750 units	Number of inverters	2 units
Nominal (STC)	2531 kWp	Total power	2200 kWac
Modules	125 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2341 kWp	Pnom ratio (DC:AC)	1.15
U mpp	1078 V		
I mpp	2171 A		

Array #5 - Sottocampo #20

Number of PV modules	5700 units	Number of inverters	3 units
Nominal (STC)	3848 kWp	Total power	3300 kWac
Modules	190 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3559 kWp	Pnom ratio (DC:AC)	1.17
U mpp	1078 V		
I mpp	3301 A		

Array #6 - Sottocampo #21

Number of PV modules	5940 units	Number of inverters	3 units
Nominal (STC)	4010 kWp	Total power	3300 kWac
Modules	198 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3708 kWp	Pnom ratio (DC:AC)	1.22
U mpp	1078 V		
I mpp	3440 A		

Array #7 - Sottocampo #22

Number of PV modules	7950 units	Number of inverters	4 units
Nominal (STC)	5366 kWp	Total power	4400 kWac
Modules	265 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	4963 kWp	Pnom ratio (DC:AC)	1.22
U mpp	1078 V		
I mpp	4604 A		

Array #8 - Sottocampo #23

Number of PV modules	2010 units	Number of inverters	1 unit
Nominal (STC)	1357 kWp	Total power	1100 kWac
Modules	67 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	1255 kWp	Pnom ratio (DC:AC)	1.23
U mpp	1078 V		
I mpp	1164 A		



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

PV Array Characteristics

PV Array Characteristics			
Array #9 - Sottocampo #24			
Number of PV modules	2010 units	Number of inverters	1 unit
Nominal (STC)	1357 kWp	Total power	1100 kWac
Modules	67 string x 30 In series		
At operating cond. (50°C)			
Pmpp	1255 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.23
I mpp	1164 A		
Array #10 - Sottocampo #25			
Number of PV modules	2010 units	Number of inverters	1 unit
Nominal (STC)	1357 kWp	Total power	1100 kWac
Modules	67 string x 30 In series		
At operating cond. (50°C)			
Pmpp	1255 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.23
I mpp	1164 A		
Array #11 - Sottocampo #26			
Number of PV modules	5130 units	Number of inverters	3 units
Nominal (STC)	3463 kWp	Total power	3300 kWac
Modules	171 string x 30 In series		
At operating cond. (50°C)			
Pmpp	3203 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.05
I mpp	2971 A		
Array #12 - Sottocampo #27			
Number of PV modules	5070 units	Number of inverters	3 units
Nominal (STC)	3422 kWp	Total power	3300 kWac
Modules	169 string x 30 In series		
At operating cond. (50°C)			
Pmpp	3165 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.04
I mpp	2936 A		
Total PV power		Total inverter power	
Nominal (STC)	39245 kWp	Total power	34100 kWac
Total	58140 modules	Number of inverters	31 units
Module area	180603 m ²	Pnom ratio	1.15

Array losses

Array Soiling Losses		Thermal Loss factor		Serie Diode Loss	
Loss Fraction	3.0 %	Module temperature according to irradiance		Voltage drop	0.7 V
		Uc (const)	29.0 W/m ² K	Loss Fraction	0.1 % at STC
		Uv (wind)	0.0 W/m ² K/m/s		
LID - Light Induced Degradation		Module Quality Loss		Module mismatch losses	
Loss Fraction	1.0 %	Loss Fraction	-0.4 %	Loss Fraction	0.5 % at MPP
Strings Mismatch loss		Module average degradation			
Loss Fraction	0.2 %	Year no	1		
		Loss factor	0.4 %/year		
		Mismatch due to degradation			
		Imp RMS dispersion	0.4 %/year		
		Vmp RMS dispersion	0.4 %/year		

**PVsyst V7.4.6**

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Array losses**IAM loss factor**

Incidence effect (IAM): Fresnel, AR coating, n(glass)=1.526, n(AR)=1.290

0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0.999	0.987	0.962	0.892	0.816	0.681	0.440	0.000

DC wiring losses

Global wiring resistance 0.52 mΩ
Loss Fraction 1.5 % at STC

Array #1 - Sottocampo #16

Global array res. 2.8 mΩ
Loss Fraction 1.5 % at STC

Array #3 - Sottocampo #18

Global array res. 5.2 mΩ
Loss Fraction 1.5 % at STC

Array #5 - Sottocampo #20

Global array res. 5.3 mΩ
Loss Fraction 1.5 % at STC

Array #7 - Sottocampo #22

Global array res. 3.8 mΩ
Loss Fraction 1.5 % at STC

Array #9 - Sottocampo #24

Global array res. 15 mΩ
Loss Fraction 1.5 % at STC

Array #11 - Sottocampo #26

Global array res. 5.9 mΩ
Loss Fraction 1.5 % at STC

Array #2 - Sottocampo #17

Global array res. 16 mΩ
Loss Fraction 1.5 % at STC

Array #4 - Sottocampo #19

Global array res. 8.1 mΩ
Loss Fraction 1.5 % at STC

Array #6 - Sottocampo #21

Global array res. 5.1 mΩ
Loss Fraction 1.5 % at STC

Array #8 - Sottocampo #23

Global array res. 15 mΩ
Loss Fraction 1.5 % at STC

Array #10 - Sottocampo #25

Global array res. 15 mΩ
Loss Fraction 1.5 % at STC

Array #12 - Sottocampo #27

Global array res. 6.0 mΩ
Loss Fraction 1.5 % at STC

System losses**Auxiliaries loss**

Proportionnal to Power 3.0 W/kW
0.0 kW from Power thresh.

AC wiring losses**Inv. output line up to MV transfo**

Inverter voltage 630 Vac tri
Loss Fraction 0.06 % at STC

Inverter: SG1100-UD

Wire section (31 Inv.) Copper 31 x 3 x 1000 mm²
Average wires length 10 m

MV line up to Injection

MV Voltage 36 kV
Average each inverter
Wires Alu 3 x 700 mm²
Length 6250 m
Loss Fraction 0.42 % at STC



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

AC losses in transformers

MV transfo

Medium voltage 36 kV

One transfo parameters

Nominal power at STC 19.38 MVA
Iron Loss (night disconnect) 18.41 kVA
Iron loss fraction 0.10 % at STC
Copper loss 202.49 kVA
Copper loss fraction 1.05 % at STC
Coils equivalent resistance 3 x 0.21 mΩ

Operating losses at STC (full system)

Nb. identical MV transfos 2
Nominal power at STC 38.75 MVA
Iron loss (night disconnect) 36.82 kVA
Copper loss 404.98 kVA



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Horizon definition

Horizon from PVGIS website API, Lat=37°13'33", Long=14°13'51", Alt=343m


Average Height	5.9 °	Albedo Factor	0.75
Diffuse Factor	0.96	Albedo Fraction	100 %

Horizon profile

Azimuth [°]	-180	-173	-165	-158	-143	-135	-128	-120	-113	-105	-98	-83
Height [°]	3.8	4.6	5.7	6.1	6.1	5.3	5.0	5.7	7.3	7.3	9.9	9.9
Azimuth [°]	-75	-68	-60	-53	-45	-38	-30	-23	-15	-8	0	8
Height [°]	6.9	7.3	8.0	9.2	9.5	8.8	8.4	5.3	1.9	1.1	1.1	3.1
Azimuth [°]	15	23	30	38	45	53	60	68	75	83	90	98
Height [°]	3.8	4.6	5.0	5.0	5.7	7.3	7.3	8.0	8.0	7.6	6.9	6.9
Azimuth [°]	105	113	120	128	135	143	150	158	165	173	180	
Height [°]	5.3	5.7	5.7	5.3	4.2	2.7	3.1	3.4	3.1	3.4	3.8	

Sun Paths (Height / Azimuth diagram)

Fixed plane, Tilts/azimuths: 25°/ 1°






PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Near shadings parameter


Perspective of the PV-field and surrounding shading scene



Iso-shadings diagram

Orientation #1

Fixed plane, Tilts/azimuths: 25°/ 1°





PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Main results


System Production

Produced Energy (P50) 9059392 kWh/year Specific production (P50) 1760 kWh/kWp/year Perf. Ratio PR 86.82 %
 Produced Energy (P90) 5254657 kWh/year Specific production (P90) 1663 kWh/kWp/year
 Produced Energy (P75) 7059039 kWh/year Specific production (P75) 1709 kWh/kWp/year

Normalized productions (per installed kWp)



Performance Ratio PR



Balances and main results

	GlobHor kWh/m ²	DiffHor kWh/m ²	T_Amb °C	GlobInc kWh/m ²	GlobEff kWh/m ²	EArray kWh	E_Grid kWh	PR ratio
January	73.4	30.70	9.60	110.6	98.3	3712333	3615438	0.833
February	92.6	37.60	9.70	125.8	116.1	4509780	4390182	0.890
March	140.4	54.90	11.50	169.3	157.5	6107128	5943911	0.894
April	170.8	67.30	14.30	185.0	172.2	6662502	6485320	0.893
May	214.8	73.90	18.50	213.3	198.8	7552201	7346011	0.878
June	228.3	71.60	22.70	218.7	204.3	7723578	7516051	0.876
July	244.9	67.20	25.20	239.2	224.0	8334505	8107060	0.864
August	214.6	64.00	25.50	226.8	212.3	7873185	7658055	0.860
September	155.3	58.00	22.30	178.0	165.4	6189253	6024428	0.862
October	116.4	48.10	18.70	149.5	138.6	5267542	5128713	0.874
November	76.4	34.10	14.50	110.3	98.8	3724416	3627657	0.838
December	65.4	28.40	10.89	100.3	88.6	3304134	3216566	0.818
Year	1793.3	635.80	16.99	2026.8	1874.9	70960557	69059392	0.868

Legends


GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_Grid	Energy injected into grid
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane		
GlobEff	Effective Global, corr. for IAM and shadings		



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Loss diagram






PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Energia incidente di riferimento su piano collettori



Fattori normalizzati di produzione e di perdita






PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Distribuzione irraggiamento incidente



Coda della distribuzione di irradiazione incidente





PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Temperatura del campo vs. irradiazione efficace





Diagramma giornaliero entrata/uscita






PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Energia giornaliera in uscita sistema



Distribuzione potenza dell'impianto






PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Distribuzione potenza in uscita sistema



Coda della distribuzione della potenza in uscita






PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Distribuzione tensione impianto



Distribuzione temperatura impianto





PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

P50 - P90 evaluation

Weather data

Source SolarGIS Monthly aver. , period not spec.
Kind Specific year
Year Sintetico
Year-to-year variability(Variance) 3.9 %

Specified Deviation

Year deviation from average 0.0 %

Global variability (weather data + system)

Variability (Quadratic sum) 4.3 %


Simulation and parameters uncertainties

PV module modelling/parameters 1.0 %
Inverter efficiency uncertainty 0.5 %
Soiling and mismatch uncertainties 1.0 %
Degradation uncertainty 1.0 %

Annual production probability

Variability 2.97 GWh
P50 69.06 GWh
P90 65.25 GWh
P75 67.06 GWh

Probability distribution





PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

CO₂ Emission Balance

Total: 1093672.4 tCO₂

Generated emissions

Total: 92752.40 tCO₂

Source: Detailed calculation from table below

Replaced Emissions

Total: 1367376.0 tCO₂

System production: 69059.39 MWh/yr

Grid Lifecycle Emissions: 660 gCO₂/kWh


Source: IEA List

Country: Zimbabwe

Lifetime: 30 years

Annual degradation: 1.0 %

Saved CO₂ Emission vs. Time



System Lifecycle Emissions Details

Item	LCE	Quantity	Subtotal
			[kgCO ₂]
Modules	1649 kgCO ₂ /kWp	54088 kWp	89206165
Supports	4.40 kgCO ₂ /kg	801300 kg	3527483
Inverters	436 kgCO ₂ /units	43.0 units	18754

PVsyst - Simulation report

Grid-Connected System

Progetto: Butera 80 MW

Variante: PV Area Ovest

Impianto a strutture fisse

System power: 54.09 MWp

Pozzillo - Italia



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

Project summary

Geographical Site Pozzillo Italia	Situation Latitude 37.23 °N Longitude 14.23 °E Altitude 343 m Time zone UTC+1	Project settings Albedo 0.20
Weather data Butera SolarGIS Monthly aver. , period not spec. - Sintetico		

System summary

Grid-Connected System Simulation for year no 1	Impianto a strutture fisse	
PV Field Orientation Fixed plane Tilt/Azimuth 25.2 / -1.8 °	Near Shadings According to strings : Fast (table) Electrical effect 100 %	User's needs Unlimited load (grid)
System information	PV Array	Inverters
Nb. of modules	80130 units	Nb. of units 43 units
Pnom total	54.09 MWp	Pnom total 47.30 MWac
		Pnom ratio 1.144

Results summary

Produced Energy	95464593 kWh/year	Specific production	1765 kWh/kWp/year	Perf. Ratio PR	87.10 %
-----------------	-------------------	---------------------	-------------------	----------------	---------

Table of contents

Cover page	1
Project and results summary	2
General parameters, PV Array Characteristics, System losses	3
Horizon definition	8
Near shading definition - Iso-shadings diagram	9
Main results	10
Loss diagram	11
Predef. graphs	12
P50 - P90 evaluation	18
CO ₂ Emission Balance	19



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

General parameters

Grid-Connected System		Impianto a strutture fisse			
PV Field Orientation		Sheds configuration		Models used	
Orientation		Nb. of sheds	2671 units	Transposition	Perez
Fixed plane		Identical arrays		Diffuse	Perez, Meteonorm
Tilt/Azimuth	25.2 / -1.8 °	Sizes		Circumsolar	separate
		Sheds spacing	8.40 m		
		Collector width	4.79 m		
		Ground Cov. Ratio (GCR)	57.0 %		
		Shading limit angle			
		Limit profile angle	26.6 °		
Horizon		Near Shadings		User's needs	
Average Height	5.9 °	According to strings : Fast (table)		Unlimited load (grid)	
		Electrical effect	100 %		
Bifacial system					
Model	2D Calculation				
	unlimited sheds				
Bifacial model geometry		Bifacial model definitions			
Sheds spacing	8.40 m	Ground albedo		0.20	
Sheds width	4.79 m	Bifaciality factor		80 %	
Limit profile angle	26.6 °	Rear shading factor		10.0 %	
GCR	57.0 %	Rear mismatch loss		10.0 %	
Height above ground	1.50 m	Shed transparent fraction		0.0 %	

PV Array Characteristics

PV module		Inverter	
Manufacturer	CSI Solar	Manufacturer	Sungrow
Model	CS7N-675TB-AG 1500V	Model	SG1100-UD
(Original PVsyst database)		(Custom parameters definition)	
Unit Nom. Power	675 Wp	Unit Nom. Power	1100 kWac
Number of PV modules	80130 units	Number of inverters	43 units
Nominal (STC)	54.09 MWp	Total power	47300 kWac
Array #1 - Sottocampo #1			
Number of PV modules	10920 units	Number of inverters	6 units
Nominal (STC)	7371 kWp	Total power	6600 kWac
Modules	364 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	6817 kWp	Pnom ratio (DC:AC)	1.12
U mpp	1078 V		
I mpp	6323 A		
Array #2 - Sottocampo #2			
Number of PV modules	3870 units	Number of inverters	2 units
Nominal (STC)	2612 kWp	Total power	2200 kWac
Modules	129 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2416 kWp	Pnom ratio (DC:AC)	1.19
U mpp	1078 V		
I mpp	2241 A		

**PVsyst V7.4.6**

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

PV Array Characteristics**Array #3 - Sottocampo #3**

Number of PV modules	3900 units	Number of inverters	2 units
Nominal (STC)	2633 kWp	Total power	2200 kWac
Modules	130 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2435 kWp	Pnom ratio (DC:AC)	1.20
U mpp	1078 V		
I mpp	2258 A		

Array #4 - Sottocampo #4

Number of PV modules	3420 units	Number of inverters	2 units
Nominal (STC)	2309 kWp	Total power	2200 kWac
Modules	114 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2135 kWp	Pnom ratio (DC:AC)	1.05
U mpp	1078 V		
I mpp	1980 A		

Array #5 - Sottocampo #5

Number of PV modules	3720 units	Number of inverters	2 units
Nominal (STC)	2511 kWp	Total power	2200 kWac
Modules	124 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2322 kWp	Pnom ratio (DC:AC)	1.14
U mpp	1078 V		
I mpp	2154 A		

Array #6 - Sottocampo #6

Number of PV modules	3750 units	Number of inverters	2 units
Nominal (STC)	2531 kWp	Total power	2200 kWac
Modules	125 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2341 kWp	Pnom ratio (DC:AC)	1.15
U mpp	1078 V		
I mpp	2171 A		

Array #7 - Sottocampo #7

Number of PV modules	5760 units	Number of inverters	3 units
Nominal (STC)	3888 kWp	Total power	3300 kWac
Modules	192 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3596 kWp	Pnom ratio (DC:AC)	1.18
U mpp	1078 V		
I mpp	3335 A		

Array #8 - Sottocampo #8

Number of PV modules	3870 units	Number of inverters	2 units
Nominal (STC)	2612 kWp	Total power	2200 kWac
Modules	129 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2416 kWp	Pnom ratio (DC:AC)	1.19
U mpp	1078 V		
I mpp	2241 A		



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

PV Array Characteristics

Array #9 - Sottocampo #9

Number of PV modules	5160 units	Number of inverters	3 units
Nominal (STC)	3483 kWp	Total power	3300 kWac
Modules	172 string x 30 In series		
At operating cond. (50°C)			
Pmpp	3221 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.06
I mpp	2988 A		

Array #10 - Sottocampo #10

Number of PV modules	9600 units	Number of inverters	5 units
Nominal (STC)	6480 kWp	Total power	5500 kWac
Modules	320 string x 30 In series		
At operating cond. (50°C)			
Pmpp	5993 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.18
I mpp	5559 A		

Array #11 - Sottocampo #11

Number of PV modules	5700 units	Number of inverters	3 units
Nominal (STC)	3848 kWp	Total power	3300 kWac
Modules	190 string x 30 In series		
At operating cond. (50°C)			
Pmpp	3559 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.17
I mpp	3301 A		

Array #12 - Sottocampo #12

Number of PV modules	5670 units	Number of inverters	3 units
Nominal (STC)	3827 kWp	Total power	3300 kWac
Modules	189 string x 30 In series		
At operating cond. (50°C)			
Pmpp	3540 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.16
I mpp	3283 A		

Array #13 - Sottocampo #13

Number of PV modules	5670 units	Number of inverters	3 units
Nominal (STC)	3827 kWp	Total power	3300 kWac
Modules	189 string x 30 In series		
At operating cond. (50°C)			
Pmpp	3540 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.16
I mpp	3283 A		

Array #14 - Sottocampo #14

Number of PV modules	5670 units	Number of inverters	3 units
Nominal (STC)	3827 kWp	Total power	3300 kWac
Modules	189 string x 30 In series		
At operating cond. (50°C)			
Pmpp	3540 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.16
I mpp	3283 A		



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

PV Array Characteristics

Array #15 - Sottocampo #15			
Number of PV modules	3450 units	Number of inverters	2 units
Nominal (STC)	2329 kWp	Total power	2200 kWac
Modules	115 string x 30 In series		
At operating cond. (50°C)			
Pmpp	2154 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.06
I mpp	1998 A		
Total PV power		Total inverter power	
Nominal (STC)	54088 kWp	Total power	47300 kWac
Total	80130 modules	Number of inverters	43 units
Module area	248912 m ²	Pnom ratio	1.14

Array losses

Array Soiling Losses		Thermal Loss factor		Serie Diode Loss				
Loss Fraction	3.0 %	Module temperature according to irradiance		Voltage drop	0.7 V			
		Uc (const)	29.0 W/m ² K	Loss Fraction	0.1 % at STC			
		Uv (wind)	0.0 W/m ² K/m/s					
LID - Light Induced Degradation		Module Quality Loss		Module mismatch losses				
Loss Fraction	0.5 %	Loss Fraction	-0.5 %	Loss Fraction	0.5 % at MPP			
Strings Mismatch loss		Module average degradation						
Loss Fraction	0.2 %	Year no	1					
		Loss factor	0.4 %/year					
		Mismatch due to degradation						
		Imp RMS dispersion	0.4 %/year					
		Vmp RMS dispersion	0.4 %/year					
IAM loss factor								
Incidence effect (IAM): Fresnel, AR coating, n(glass)=1.526, n(AR)=1.290								
0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0.999	0.987	0.962	0.892	0.816	0.681	0.440	0.000

DC wiring losses

Global wiring resistance	0.38 mΩ		
Loss Fraction	1.5 % at STC		
Array #1 - Sottocampo #1		Array #2 - Sottocampo #2	
Global array res.	2.8 mΩ	Global array res.	7.8 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #3 - Sottocampo #3		Array #4 - Sottocampo #4	
Global array res.	7.8 mΩ	Global array res.	8.9 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #5 - Sottocampo #5		Array #6 - Sottocampo #6	
Global array res.	8.2 mΩ	Global array res.	8.1 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #7 - Sottocampo #7		Array #8 - Sottocampo #8	
Global array res.	5.3 mΩ	Global array res.	7.8 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #9 - Sottocampo #9		Array #10 - Sottocampo #10	
Global array res.	5.9 mΩ	Global array res.	3.2 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC



PVsyst V7.4.6

VC0, Simulation date:
25/03/24 11:39
with V7.4.6

DC wiring losses

Array #11 - Sottocampo #11		Array #12 - Sottocampo #12	
Global array res.	5.3 mΩ	Global array res.	5.3 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #13 - Sottocampo #13		Array #14 - Sottocampo #14	
Global array res.	5.3 mΩ	Global array res.	5.3 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #15 - Sottocampo #15			
Global array res.	8.8 mΩ		
Loss Fraction	1.5 % at STC		

System losses

Auxiliaries loss	
Proportionnal to Power	3.0 W/kW
0.0 kW from Power thresh.	

AC wiring losses

Inv. output line up to MV transfo	
Inverter voltage	630 Vac tri
Loss Fraction	0.06 % at STC
Inverter: SG1100-UD	
Wire section (43 Inv.)	Copper 43 x 3 x 1000 mm ²
Average wires length	10 m
MV line up to Injection	
MV Voltage	36 kV
Average each inverter	
Wires	Alu 3 x 700 mm ²
Length	18675 m
Loss Fraction	1.15 % at STC

AC losses in transformers

MV transfo			
Medium voltage	36 kV		
One transfo parameters		Operating losses at STC (full system)	
Nominal power at STC	17.80 MVA	Nb. identical MV transfos	3
Iron Loss (24/24 Connexion)	17.80 kVA	Nominal power at STC	53.41 MVA
Iron loss fraction	0.10 % at STC	Iron loss (24/24 Connexion)	53.41 kVA
Copper loss	178.04 kVA	Copper loss	534.13 kVA
Copper loss fraction	1.00 % at STC		
Coils equivalent resistance	3 x 0.22 mΩ		



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

Horizon definition

Horizon from PVGIS website API, Lat=37°13'33", Long=14°13'51", Alt=343m


Average Height 5.9 ° Albedo Factor 0.75
Diffuse Factor 0.97 Albedo Fraction 100 %

Horizon profile

Azimuth [°]	-180	-173	-165	-158	-143	-135	-128	-120	-113	-105	-98	-83
Height [°]	3.8	4.6	5.7	6.1	6.1	5.3	5.0	5.7	7.3	7.3	9.9	9.9
Azimuth [°]	-75	-68	-60	-53	-45	-38	-30	-23	-15	-8	0	8
Height [°]	6.9	7.3	8.0	9.2	9.5	8.8	8.4	5.3	1.9	1.1	1.1	3.1
Azimuth [°]	15	23	30	38	45	53	60	68	75	83	90	98
Height [°]	3.8	4.6	5.0	5.0	5.7	7.3	7.3	8.0	8.0	7.6	6.9	6.9
Azimuth [°]	105	113	120	128	135	143	150	158	165	173	180	
Height [°]	5.3	5.7	5.7	5.3	4.2	2.7	3.1	3.4	3.1	3.4	3.8	

Sun Paths (Height / Azimuth diagram)

Fixed plane, Tilts/azimuths: 25° / -2°






PVsyst V7.4.6

VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Near shadings parameter


Perspective of the PV-field and surrounding shading scene



Iso-shadings diagram

Orientation #1

Fixed plane, Tilts/azimuths: 25°/-2°





PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Main results


System Production

Produced Energy (P50) 95464593 kWh/year Specific production (P50) 1765 kWh/kWp/year Perf. Ratio PR 87.10 %
 Produced Energy (P90) 90205099 kWh/year Specific production (P90) 1668 kWh/kWp/year
 Produced Energy (P75) 92699395 kWh/year Specific production (P75) 1714 kWh/kWp/year

Normalized productions (per installed kWp)



Performance Ratio PR



Balances and main results

	GlobHor kWh/m ²	DiffHor kWh/m ²	T_Amb °C	GlobInc kWh/m ²	GlobEff kWh/m ²	EArray kWh	E_Grid kWh	PR ratio
January	73.4	30.70	9.60	110.6	98.7	5214151	5034967	0.842
February	92.6	37.60	9.70	125.7	116.2	6273405	6060778	0.891
March	140.4	54.90	11.50	169.3	157.6	8486642	8201112	0.896
April	170.8	67.30	14.30	185.0	172.2	9255510	8949092	0.894
May	214.8	73.90	18.50	213.2	198.9	10500235	10147986	0.880
June	228.3	71.60	22.70	218.8	204.5	10739433	10384599	0.877
July	244.9	67.20	25.20	239.3	224.2	11593295	11204153	0.866
August	214.6	64.00	25.50	226.7	212.3	10943195	10573630	0.862
September	155.3	58.00	22.30	178.1	165.5	8603688	8316471	0.863
October	116.4	48.10	18.70	149.4	138.6	7315771	7070823	0.875
November	76.4	34.10	14.50	110.3	99.1	5209476	5032692	0.844
December	65.4	28.40	10.89	100.2	89.1	4652013	4488289	0.828
Year	1793.3	635.80	16.99	2026.5	1876.6	98786815	95464593	0.871

Legends


GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_Grid	Energy injected into grid
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane		
GlobEff	Effective Global, corr. for IAM and shadings		



PVsyst V7.4.6

VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Loss diagram






PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Energia incidente di riferimento su piano collettori



Fattori normalizzati di produzione e di perdita






PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Distribuzione irraggiamento incidente



Coda della distribuzione di irradiazione incidente





PVsyst V7.4.6

VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Temperatura del campo vs. irradiazione efficace





Diagramma giornaliero entrata/uscita






PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Energia giornaliera in uscita sistema



Distribuzione potenza dell'impianto






PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Distribuzione potenza in uscita sistema



Coda della distribuzione della potenza in uscita






PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Distribuzione tensione impianto



Distribuzione temperatura impianto





PVsyst V7.4.6

VC0, Simulation date:
25/03/24 11:39
with V7.4.6

P50 - P90 evaluation

Weather data

Source SolarGIS Monthly aver. , period not spec.
Kind Specific year
Year Sintetico
Year-to-year variability(Variance) 3.9 %

Specified Deviation

Year deviation from average 0.0 %

Global variability (weather data + system)

Variability (Quadratic sum) 4.3 %


Simulation and parameters uncertainties

PV module modelling/parameters 1.0 %
Inverter efficiency uncertainty 0.5 %
Soiling and mismatch uncertainties 1.0 %
Degradation uncertainty 1.0 %

Annual production probability

Variability 4.10 GWh
P50 95.46 GWh
P90 90.21 GWh
P75 92.70 GWh

Probability distribution





PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

CO₂ Emission Balance

Total: 1547307.9 tCO₂

Generated emissions

Total: 92752.40 tCO₂

Source: Detailed calculation from table below

Replaced Emissions

Total: 1890198.9 tCO₂

System production: 95464.59 MWh/yr

Grid Lifecycle Emissions: 660 gCO₂/kWh


Source: IEA List

Country: Zimbabwe

Lifetime: 30 years

Annual degradation: 1.0 %

Saved CO₂ Emission vs. Time



System Lifecycle Emissions Details

Item	LCE	Quantity	Subtotal
			[kgCO ₂]
Modules	1649 kgCO ₂ /kWp	54088 kWp	89206165
Supports	4.40 kgCO ₂ /kg	801300 kg	3527483
Inverters	436 kgCO ₂ /units	43.0 units	18754

PVsyst - Simulation report

Grid-Connected System

Progetto: Butera 80 MW

Variante: PV Area Ovest

Impianto a strutture fisse

System power: 54.09 MWp

Pozzillo - Italia



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

Project summary

Geographical Site Pozzillo Italia	Situation Latitude 37.23 °N Longitude 14.23 °E Altitude 343 m Time zone UTC+1	Project settings Albedo 0.20
Weather data Butera SolarGIS Monthly aver. , period not spec. - Sintetico		

System summary

Grid-Connected System Simulation for year no 1	Impianto a strutture fisse	
PV Field Orientation Fixed plane Tilt/Azimuth 25.2 / -1.8 °	Near Shadings According to strings : Fast (table) Electrical effect 100 %	User's needs Unlimited load (grid)
System information	PV Array	Inverters
Nb. of modules	80130 units	Nb. of units 43 units
Pnom total	54.09 MWp	Pnom total 47.30 MWac
		Pnom ratio 1.144

Results summary

Produced Energy	95464593 kWh/year	Specific production	1765 kWh/kWp/year	Perf. Ratio PR	87.10 %
-----------------	-------------------	---------------------	-------------------	----------------	---------

Table of contents

Cover page	1
Project and results summary	2
General parameters, PV Array Characteristics, System losses	3
Horizon definition	8
Near shading definition - Iso-shadings diagram	9
Main results	10
Loss diagram	11
Predef. graphs	12
P50 - P90 evaluation	18
CO ₂ Emission Balance	19



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

General parameters

Grid-Connected System		Impianto a strutture fisse			
PV Field Orientation		Sheds configuration		Models used	
Orientation		Nb. of sheds	2671 units	Transposition	Perez
Fixed plane		Identical arrays		Diffuse	Perez, Meteonorm
Tilt/Azimuth	25.2 / -1.8 °	Sizes		Circumsolar	separate
		Sheds spacing	8.40 m		
		Collector width	4.79 m		
		Ground Cov. Ratio (GCR)	57.0 %		
		Shading limit angle			
		Limit profile angle	26.6 °		
Horizon		Near Shadings		User's needs	
Average Height	5.9 °	According to strings : Fast (table)		Unlimited load (grid)	
		Electrical effect	100 %		
Bifacial system					
Model	2D Calculation				
	unlimited sheds				
Bifacial model geometry		Bifacial model definitions			
Sheds spacing	8.40 m	Ground albedo	0.20		
Sheds width	4.79 m	Bifaciality factor	80 %		
Limit profile angle	26.6 °	Rear shading factor	10.0 %		
GCR	57.0 %	Rear mismatch loss	10.0 %		
Height above ground	1.50 m	Shed transparent fraction	0.0 %		

PV Array Characteristics

PV module		Inverter	
Manufacturer	CSI Solar	Manufacturer	Sungrow
Model	CS7N-675TB-AG 1500V	Model	SG1100-UD
(Original PVsyst database)		(Custom parameters definition)	
Unit Nom. Power	675 Wp	Unit Nom. Power	1100 kWac
Number of PV modules	80130 units	Number of inverters	43 units
Nominal (STC)	54.09 MWp	Total power	47300 kWac
Array #1 - Sottocampo #1			
Number of PV modules	10920 units	Number of inverters	6 units
Nominal (STC)	7371 kWp	Total power	6600 kWac
Modules	364 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	6817 kWp	Pnom ratio (DC:AC)	1.12
U mpp	1078 V		
I mpp	6323 A		
Array #2 - Sottocampo #2			
Number of PV modules	3870 units	Number of inverters	2 units
Nominal (STC)	2612 kWp	Total power	2200 kWac
Modules	129 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2416 kWp	Pnom ratio (DC:AC)	1.19
U mpp	1078 V		
I mpp	2241 A		



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

PV Array Characteristics

Array #3 - Sottocampo #3

Number of PV modules	3900 units	Number of inverters	2 units
Nominal (STC)	2633 kWp	Total power	2200 kWac
Modules	130 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2435 kWp	Pnom ratio (DC:AC)	1.20
U mpp	1078 V		
I mpp	2258 A		

Array #4 - Sottocampo #4

Number of PV modules	3420 units	Number of inverters	2 units
Nominal (STC)	2309 kWp	Total power	2200 kWac
Modules	114 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2135 kWp	Pnom ratio (DC:AC)	1.05
U mpp	1078 V		
I mpp	1980 A		

Array #5 - Sottocampo #5

Number of PV modules	3720 units	Number of inverters	2 units
Nominal (STC)	2511 kWp	Total power	2200 kWac
Modules	124 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2322 kWp	Pnom ratio (DC:AC)	1.14
U mpp	1078 V		
I mpp	2154 A		

Array #6 - Sottocampo #6

Number of PV modules	3750 units	Number of inverters	2 units
Nominal (STC)	2531 kWp	Total power	2200 kWac
Modules	125 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2341 kWp	Pnom ratio (DC:AC)	1.15
U mpp	1078 V		
I mpp	2171 A		

Array #7 - Sottocampo #7

Number of PV modules	5760 units	Number of inverters	3 units
Nominal (STC)	3888 kWp	Total power	3300 kWac
Modules	192 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3596 kWp	Pnom ratio (DC:AC)	1.18
U mpp	1078 V		
I mpp	3335 A		

Array #8 - Sottocampo #8

Number of PV modules	3870 units	Number of inverters	2 units
Nominal (STC)	2612 kWp	Total power	2200 kWac
Modules	129 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2416 kWp	Pnom ratio (DC:AC)	1.19
U mpp	1078 V		
I mpp	2241 A		



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

PV Array Characteristics

Array #9 - Sottocampo #9

Number of PV modules	5160 units	Number of inverters	3 units
Nominal (STC)	3483 kWp	Total power	3300 kWac
Modules	172 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3221 kWp	Pnom ratio (DC:AC)	1.06
U mpp	1078 V		
I mpp	2988 A		

Array #10 - Sottocampo #10

Number of PV modules	9600 units	Number of inverters	5 units
Nominal (STC)	6480 kWp	Total power	5500 kWac
Modules	320 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	5993 kWp	Pnom ratio (DC:AC)	1.18
U mpp	1078 V		
I mpp	5559 A		

Array #11 - Sottocampo #11

Number of PV modules	5700 units	Number of inverters	3 units
Nominal (STC)	3848 kWp	Total power	3300 kWac
Modules	190 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3559 kWp	Pnom ratio (DC:AC)	1.17
U mpp	1078 V		
I mpp	3301 A		

Array #12 - Sottocampo #12

Number of PV modules	5670 units	Number of inverters	3 units
Nominal (STC)	3827 kWp	Total power	3300 kWac
Modules	189 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3540 kWp	Pnom ratio (DC:AC)	1.16
U mpp	1078 V		
I mpp	3283 A		

Array #13 - Sottocampo #13

Number of PV modules	5670 units	Number of inverters	3 units
Nominal (STC)	3827 kWp	Total power	3300 kWac
Modules	189 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3540 kWp	Pnom ratio (DC:AC)	1.16
U mpp	1078 V		
I mpp	3283 A		

Array #14 - Sottocampo #14

Number of PV modules	5670 units	Number of inverters	3 units
Nominal (STC)	3827 kWp	Total power	3300 kWac
Modules	189 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3540 kWp	Pnom ratio (DC:AC)	1.16
U mpp	1078 V		
I mpp	3283 A		



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

PV Array Characteristics

Array #15 - Sottocampo #15			
Number of PV modules	3450 units	Number of inverters	2 units
Nominal (STC)	2329 kWp	Total power	2200 kWac
Modules	115 string x 30 In series		
At operating cond. (50°C)			
Pmpp	2154 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.06
I mpp	1998 A		
Total PV power		Total inverter power	
Nominal (STC)	54088 kWp	Total power	47300 kWac
Total	80130 modules	Number of inverters	43 units
Module area	248912 m ²	Pnom ratio	1.14

Array losses

Array Soiling Losses		Thermal Loss factor		Serie Diode Loss				
Loss Fraction	3.0 %	Module temperature according to irradiance		Voltage drop	0.7 V			
		Uc (const)	29.0 W/m ² K	Loss Fraction	0.1 % at STC			
		Uv (wind)	0.0 W/m ² K/m/s					
LID - Light Induced Degradation		Module Quality Loss		Module mismatch losses				
Loss Fraction	0.5 %	Loss Fraction	-0.5 %	Loss Fraction	0.5 % at MPP			
Strings Mismatch loss		Module average degradation						
Loss Fraction	0.2 %	Year no	1					
		Loss factor	0.4 %/year					
		Mismatch due to degradation						
		Imp RMS dispersion	0.4 %/year					
		Vmp RMS dispersion	0.4 %/year					
IAM loss factor								
Incidence effect (IAM): Fresnel, AR coating, n(glass)=1.526, n(AR)=1.290								
0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0.999	0.987	0.962	0.892	0.816	0.681	0.440	0.000

DC wiring losses

Global wiring resistance	0.38 mΩ		
Loss Fraction	1.5 % at STC		
Array #1 - Sottocampo #1		Array #2 - Sottocampo #2	
Global array res.	2.8 mΩ	Global array res.	7.8 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #3 - Sottocampo #3		Array #4 - Sottocampo #4	
Global array res.	7.8 mΩ	Global array res.	8.9 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #5 - Sottocampo #5		Array #6 - Sottocampo #6	
Global array res.	8.2 mΩ	Global array res.	8.1 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #7 - Sottocampo #7		Array #8 - Sottocampo #8	
Global array res.	5.3 mΩ	Global array res.	7.8 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #9 - Sottocampo #9		Array #10 - Sottocampo #10	
Global array res.	5.9 mΩ	Global array res.	3.2 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC



PVsyst V7.4.6

VC0, Simulation date:
25/03/24 11:39
with V7.4.6

DC wiring losses

Array #11 - Sottocampo #11		Array #12 - Sottocampo #12	
Global array res.	5.3 mΩ	Global array res.	5.3 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #13 - Sottocampo #13		Array #14 - Sottocampo #14	
Global array res.	5.3 mΩ	Global array res.	5.3 mΩ
Loss Fraction	1.5 % at STC	Loss Fraction	1.5 % at STC
Array #15 - Sottocampo #15			
Global array res.	8.8 mΩ		
Loss Fraction	1.5 % at STC		

System losses

Auxiliaries loss	
Proportionnal to Power	3.0 W/kW
0.0 kW from Power thresh.	

AC wiring losses

Inv. output line up to MV transfo	
Inverter voltage	630 Vac tri
Loss Fraction	0.06 % at STC
Inverter: SG1100-UD	
Wire section (43 Inv.)	Copper 43 x 3 x 1000 mm ²
Average wires length	10 m
MV line up to Injection	
MV Voltage	36 kV
Average each inverter	
Wires	Alu 3 x 700 mm ²
Length	18675 m
Loss Fraction	1.15 % at STC

AC losses in transformers

MV transfo			
Medium voltage	36 kV		
One transfo parameters		Operating losses at STC (full system)	
Nominal power at STC	17.80 MVA	Nb. identical MV transfos	3
Iron Loss (24/24 Connexion)	17.80 kVA	Nominal power at STC	53.41 MVA
Iron loss fraction	0.10 % at STC	Iron loss (24/24 Connexion)	53.41 kVA
Copper loss	178.04 kVA	Copper loss	534.13 kVA
Copper loss fraction	1.00 % at STC		
Coils equivalent resistance	3 x 0.22 mΩ		



PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

Horizon definition

Horizon from PVGIS website API, Lat=37°13'33", Long=14°13'51", Alt=343m


Average Height 5.9 ° Albedo Factor 0.75
Diffuse Factor 0.97 Albedo Fraction 100 %

Horizon profile

Azimuth [°]	-180	-173	-165	-158	-143	-135	-128	-120	-113	-105	-98	-83
Height [°]	3.8	4.6	5.7	6.1	6.1	5.3	5.0	5.7	7.3	7.3	9.9	9.9
Azimuth [°]	-75	-68	-60	-53	-45	-38	-30	-23	-15	-8	0	8
Height [°]	6.9	7.3	8.0	9.2	9.5	8.8	8.4	5.3	1.9	1.1	1.1	3.1
Azimuth [°]	15	23	30	38	45	53	60	68	75	83	90	98
Height [°]	3.8	4.6	5.0	5.0	5.7	7.3	7.3	8.0	8.0	7.6	6.9	6.9
Azimuth [°]	105	113	120	128	135	143	150	158	165	173	180	
Height [°]	5.3	5.7	5.7	5.3	4.2	2.7	3.1	3.4	3.1	3.4	3.8	

Sun Paths (Height / Azimuth diagram)

Fixed plane, Tilts/azimuths: 25° / -2°






PVsyst V7.4.6

VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Near shadings parameter


Perspective of the PV-field and surrounding shading scene



Iso-shadings diagram

Orientation #1

Fixed plane, Tilts/azimuths: 25°/-2°





PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Main results


System Production

Produced Energy (P50) 95464593 kWh/year Specific production (P50) 1765 kWh/kWp/year Perf. Ratio PR 87.10 %
 Produced Energy (P90) 90205099 kWh/year Specific production (P90) 1668 kWh/kWp/year
 Produced Energy (P75) 92699395 kWh/year Specific production (P75) 1714 kWh/kWp/year

Normalized productions (per installed kWp)



Performance Ratio PR



Balances and main results

	GlobHor kWh/m ²	DiffHor kWh/m ²	T_Amb °C	GlobInc kWh/m ²	GlobEff kWh/m ²	EArray kWh	E_Grid kWh	PR ratio
January	73.4	30.70	9.60	110.6	98.7	5214151	5034967	0.842
February	92.6	37.60	9.70	125.7	116.2	6273405	6060778	0.891
March	140.4	54.90	11.50	169.3	157.6	8486642	8201112	0.896
April	170.8	67.30	14.30	185.0	172.2	9255510	8949092	0.894
May	214.8	73.90	18.50	213.2	198.9	10500235	10147986	0.880
June	228.3	71.60	22.70	218.8	204.5	10739433	10384599	0.877
July	244.9	67.20	25.20	239.3	224.2	11593295	11204153	0.866
August	214.6	64.00	25.50	226.7	212.3	10943195	10573630	0.862
September	155.3	58.00	22.30	178.1	165.5	8603688	8316471	0.863
October	116.4	48.10	18.70	149.4	138.6	7315771	7070823	0.875
November	76.4	34.10	14.50	110.3	99.1	5209476	5032692	0.844
December	65.4	28.40	10.89	100.2	89.1	4652013	4488289	0.828
Year	1793.3	635.80	16.99	2026.5	1876.6	98786815	95464593	0.871

Legends


GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_Grid	Energy injected into grid
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane		
GlobEff	Effective Global, corr. for IAM and shadings		



PVsyst V7.4.6

VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Loss diagram






PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Energia incidente di riferimento su piano collettori



Fattori normalizzati di produzione e di perdita






PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Distribuzione irraggiamento incidente



Coda della distribuzione di irradiazione incidente





PVsyst V7.4.6

VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Temperatura del campo vs. irradiazione efficace





Diagramma giornaliero entrata/uscita






PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Energia giornaliera in uscita sistema



Distribuzione potenza dell'impianto






PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Distribuzione potenza in uscita sistema



Coda della distribuzione della potenza in uscita






PVsyst V7.4.6


VC0, Simulation date:
25/03/24 11:39
with V7.4.6

Predef. graphs

Distribuzione tensione impianto



Distribuzione temperatura impianto





PVsyst V7.4.6

VC0, Simulation date:
25/03/24 11:39
with V7.4.6

P50 - P90 evaluation

Weather data

Source SolarGIS Monthly aver. , period not spec.
Kind Specific year
Year Sintetico
Year-to-year variability(Variance) 3.9 %

Specified Deviation

Year deviation from average 0.0 %

Global variability (weather data + system)

Variability (Quadratic sum) 4.3 %


Simulation and parameters uncertainties

PV module modelling/parameters 1.0 %
Inverter efficiency uncertainty 0.5 %
Soiling and mismatch uncertainties 1.0 %
Degradation uncertainty 1.0 %

Annual production probability

Variability 4.10 GWh
P50 95.46 GWh
P90 90.21 GWh
P75 92.70 GWh

Probability distribution





PVsyst V7.4.6

VCO, Simulation date:
25/03/24 11:39
with V7.4.6

CO₂ Emission Balance

Total: 1547307.9 tCO₂

Generated emissions

Total: 92752.40 tCO₂

Source: Detailed calculation from table below

Replaced Emissions

Total: 1890198.9 tCO₂

System production: 95464.59 MWh/yr

Grid Lifecycle Emissions: 660 gCO₂/kWh


Source: IEA List

Country: Zimbabwe

Lifetime: 30 years

Annual degradation: 1.0 %

Saved CO₂ Emission vs. Time



System Lifecycle Emissions Details

Item	LCE	Quantity	Subtotal
			[kgCO ₂]
Modules	1649 kgCO ₂ /kWp	54088 kWp	89206165
Supports	4.40 kgCO ₂ /kg	801300 kg	3527483
Inverters	436 kgCO ₂ /units	43.0 units	18754

PVsyst - Simulation report

Grid-Connected System

Progetto: Butera 80 MW

PV Area Est

Impianto a strutture fisse

System power: 39.24 MWp

Pozzillo - Italy

**PVsyst V7.4.6**

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Project summary

Geographical Site		Situation		Project settings	
Pozzillo		Latitude	37.23 °N	Albedo	0.20
Italy		Longitude	14.23 °E		
		Altitude	343 m		
		Time zone	UTC+1		
Weather data					
Butera					
SolarGIS Monthly aver. , period not spec. - Sintetico					

System summary

Grid-Connected System		Impianto a strutture fisse			
Simulation for year no 1					
PV Field Orientation		Near Shadings		User's needs	
Fixed plane		According to strings : Fast (table)		Unlimited load (grid)	
Tilt/Azimuth	25.1 / 0.7 °	Electrical effect	100 %		
System information					
PV Array					
Nb. of modules		58140 units	Inverters	Nb. of units	31 units
Pnom total		39.24 MWp		Pnom total	34.10 MWac
				Pnom ratio	1.151

Results summary

Produced Energy	69059392 kWh/year	Specific production	1760 kWh/kWp/year	Perf. Ratio PR	86.82 %
-----------------	-------------------	---------------------	-------------------	----------------	---------

Table of contents

Cover page	1
Project and results summary	2
General parameters, PV Array Characteristics, System losses	3
Horizon definition	8
Near shading definition - Iso-shadings diagram	9
Main results	10
Loss diagram	11
Predef. graphs	12
P50 - P90 evaluation	18
CO ₂ Emission Balance	19



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

General parameters

Grid-Connected System		Impianto a strutture fisse			
PV Field Orientation		Sheds configuration		Models used	
Orientation		Nb. of sheds	1938 units	Transposition	Perez
Fixed plane		Identical arrays		Diffuse	Perez, Meteonorm
Tilt/Azimuth	25.1 / 0.7 °	Sizes		Circumsolar	separate
		Sheds spacing	8.40 m		
		Collector width	4.79 m		
		Ground Cov. Ratio (GCR)	57.0 %		
		Shading limit angle			
		Limit profile angle	26.6 °		
Horizon		Near Shadings		User's needs	
Average Height	5.9 °	According to strings : Fast (table)		Unlimited load (grid)	
		Electrical effect	100 %		
Bifacial system					
Model	2D Calculation				
	unlimited sheds				
Bifacial model geometry		Bifacial model definitions			
Sheds spacing	8.40 m	Ground albedo	0.20		
Sheds width	4.79 m	Bifaciality factor	80 %		
Limit profile angle	26.6 °	Rear shading factor	10.0 %		
GCR	57.0 %	Rear mismatch loss	10.0 %		
Height above ground	1.50 m	Shed transparent fraction	0.0 %		

PV Array Characteristics

PV module		Inverter	
Manufacturer	CSI Solar	Manufacturer	Sungrow
Model	CS7N-675TB-AG 1500V	Model	SG1100-UD
(Original PVsyst database)		(Custom parameters definition)	
Unit Nom. Power	675 Wp	Unit Nom. Power	1100 kWac
Number of PV modules	58140 units	Number of inverters	31 units
Nominal (STC)	39.24 MWp	Total power	34100 kWac
Array #1 - Sottocampo #16			
Number of PV modules	10800 units	Number of inverters	6 units
Nominal (STC)	7290 kWp	Total power	6600 kWac
Modules	360 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	6743 kWp	Pnom ratio (DC:AC)	1.10
U mpp	1078 V		
I mpp	6254 A		
Array #2 - Sottocampo #17			
Number of PV modules	1920 units	Number of inverters	1 unit
Nominal (STC)	1296 kWp	Total power	1100 kWac
Modules	64 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	1199 kWp	Pnom ratio (DC:AC)	1.18
U mpp	1078 V		
I mpp	1112 A		



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

PV Array Characteristics

Array #3 - Sottocampo #18

Number of PV modules	5850 units	Number of inverters	3 units
Nominal (STC)	3949 kWp	Total power	3300 kWac
Modules	195 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3652 kWp	Pnom ratio (DC:AC)	1.20
U mpp	1078 V		
I mpp	3388 A		

Array #4 - Sottocampo #19

Number of PV modules	3750 units	Number of inverters	2 units
Nominal (STC)	2531 kWp	Total power	2200 kWac
Modules	125 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	2341 kWp	Pnom ratio (DC:AC)	1.15
U mpp	1078 V		
I mpp	2171 A		

Array #5 - Sottocampo #20

Number of PV modules	5700 units	Number of inverters	3 units
Nominal (STC)	3848 kWp	Total power	3300 kWac
Modules	190 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3559 kWp	Pnom ratio (DC:AC)	1.17
U mpp	1078 V		
I mpp	3301 A		

Array #6 - Sottocampo #21

Number of PV modules	5940 units	Number of inverters	3 units
Nominal (STC)	4010 kWp	Total power	3300 kWac
Modules	198 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	3708 kWp	Pnom ratio (DC:AC)	1.22
U mpp	1078 V		
I mpp	3440 A		

Array #7 - Sottocampo #22

Number of PV modules	7950 units	Number of inverters	4 units
Nominal (STC)	5366 kWp	Total power	4400 kWac
Modules	265 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	4963 kWp	Pnom ratio (DC:AC)	1.22
U mpp	1078 V		
I mpp	4604 A		

Array #8 - Sottocampo #23

Number of PV modules	2010 units	Number of inverters	1 unit
Nominal (STC)	1357 kWp	Total power	1100 kWac
Modules	67 string x 30 In series		
At operating cond. (50°C)		Operating voltage	895-1500 V
Pmpp	1255 kWp	Pnom ratio (DC:AC)	1.23
U mpp	1078 V		
I mpp	1164 A		



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

PV Array Characteristics

PV Array Characteristics			
Array #9 - Sottocampo #24			
Number of PV modules	2010 units	Number of inverters	1 unit
Nominal (STC)	1357 kWp	Total power	1100 kWac
Modules	67 string x 30 In series		
At operating cond. (50°C)			
Pmpp	1255 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.23
I mpp	1164 A		
Array #10 - Sottocampo #25			
Number of PV modules	2010 units	Number of inverters	1 unit
Nominal (STC)	1357 kWp	Total power	1100 kWac
Modules	67 string x 30 In series		
At operating cond. (50°C)			
Pmpp	1255 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.23
I mpp	1164 A		
Array #11 - Sottocampo #26			
Number of PV modules	5130 units	Number of inverters	3 units
Nominal (STC)	3463 kWp	Total power	3300 kWac
Modules	171 string x 30 In series		
At operating cond. (50°C)			
Pmpp	3203 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.05
I mpp	2971 A		
Array #12 - Sottocampo #27			
Number of PV modules	5070 units	Number of inverters	3 units
Nominal (STC)	3422 kWp	Total power	3300 kWac
Modules	169 string x 30 In series		
At operating cond. (50°C)			
Pmpp	3165 kWp	Operating voltage	895-1500 V
U mpp	1078 V	Pnom ratio (DC:AC)	1.04
I mpp	2936 A		
Total PV power		Total inverter power	
Nominal (STC)	39245 kWp	Total power	34100 kWac
Total	58140 modules	Number of inverters	31 units
Module area	180603 m ²	Pnom ratio	1.15

Array losses

Array Soiling Losses		Thermal Loss factor		Serie Diode Loss	
Loss Fraction	3.0 %	Module temperature according to irradiance		Voltage drop	0.7 V
		Uc (const)	29.0 W/m ² K	Loss Fraction	0.1 % at STC
		Uv (wind)	0.0 W/m ² K/m/s		
LID - Light Induced Degradation		Module Quality Loss		Module mismatch losses	
Loss Fraction	1.0 %	Loss Fraction	-0.4 %	Loss Fraction	0.5 % at MPP
Strings Mismatch loss		Module average degradation			
Loss Fraction	0.2 %	Year no	1		
		Loss factor	0.4 %/year		
		Mismatch due to degradation			
		Imp RMS dispersion	0.4 %/year		
		Vmp RMS dispersion	0.4 %/year		

**PVsyst V7.4.6**

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Array losses**IAM loss factor**

Incidence effect (IAM): Fresnel, AR coating, n(glass)=1.526, n(AR)=1.290

0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0.999	0.987	0.962	0.892	0.816	0.681	0.440	0.000

DC wiring losses

Global wiring resistance 0.52 mΩ
Loss Fraction 1.5 % at STC

Array #1 - Sottocampo #16

Global array res. 2.8 mΩ
Loss Fraction 1.5 % at STC

Array #3 - Sottocampo #18

Global array res. 5.2 mΩ
Loss Fraction 1.5 % at STC

Array #5 - Sottocampo #20

Global array res. 5.3 mΩ
Loss Fraction 1.5 % at STC

Array #7 - Sottocampo #22

Global array res. 3.8 mΩ
Loss Fraction 1.5 % at STC

Array #9 - Sottocampo #24

Global array res. 15 mΩ
Loss Fraction 1.5 % at STC

Array #11 - Sottocampo #26

Global array res. 5.9 mΩ
Loss Fraction 1.5 % at STC

Array #2 - Sottocampo #17

Global array res. 16 mΩ
Loss Fraction 1.5 % at STC

Array #4 - Sottocampo #19

Global array res. 8.1 mΩ
Loss Fraction 1.5 % at STC

Array #6 - Sottocampo #21

Global array res. 5.1 mΩ
Loss Fraction 1.5 % at STC

Array #8 - Sottocampo #23

Global array res. 15 mΩ
Loss Fraction 1.5 % at STC

Array #10 - Sottocampo #25

Global array res. 15 mΩ
Loss Fraction 1.5 % at STC

Array #12 - Sottocampo #27

Global array res. 6.0 mΩ
Loss Fraction 1.5 % at STC

System losses**Auxiliaries loss**

Proportionnal to Power 3.0 W/kW
0.0 kW from Power thresh.

AC wiring losses**Inv. output line up to MV transfo**

Inverter voltage 630 Vac tri
Loss Fraction 0.06 % at STC

Inverter: SG1100-UD

Wire section (31 Inv.) Copper 31 x 3 x 1000 mm²
Average wires length 10 m

MV line up to Injection

MV Voltage 36 kV
Average each inverter
Wires Alu 3 x 700 mm²
Length 6250 m
Loss Fraction 0.42 % at STC



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

AC losses in transformers

MV transfo

Medium voltage 36 kV

One transfo parameters

Nominal power at STC 19.38 MVA
Iron Loss (night disconnect) 18.41 kVA
Iron loss fraction 0.10 % at STC
Copper loss 202.49 kVA
Copper loss fraction 1.05 % at STC
Coils equivalent resistance 3 x 0.21 mΩ

Operating losses at STC (full system)

Nb. identical MV transfos 2
Nominal power at STC 38.75 MVA
Iron loss (night disconnect) 36.82 kVA
Copper loss 404.98 kVA



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Horizon definition

Horizon from PVGIS website API, Lat=37°13'33", Long=14°13'51", Alt=343m


Average Height	5.9 °	Albedo Factor	0.75
Diffuse Factor	0.96	Albedo Fraction	100 %

Horizon profile

Azimuth [°]	-180	-173	-165	-158	-143	-135	-128	-120	-113	-105	-98	-83
Height [°]	3.8	4.6	5.7	6.1	6.1	5.3	5.0	5.7	7.3	7.3	9.9	9.9
Azimuth [°]	-75	-68	-60	-53	-45	-38	-30	-23	-15	-8	0	8
Height [°]	6.9	7.3	8.0	9.2	9.5	8.8	8.4	5.3	1.9	1.1	1.1	3.1
Azimuth [°]	15	23	30	38	45	53	60	68	75	83	90	98
Height [°]	3.8	4.6	5.0	5.0	5.7	7.3	7.3	8.0	8.0	7.6	6.9	6.9
Azimuth [°]	105	113	120	128	135	143	150	158	165	173	180	
Height [°]	5.3	5.7	5.7	5.3	4.2	2.7	3.1	3.4	3.1	3.4	3.8	

Sun Paths (Height / Azimuth diagram)

Fixed plane, Tilts/azimuths: 25°/ 1°






PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Near shadings parameter


Perspective of the PV-field and surrounding shading scene



Iso-shadings diagram

Orientation #1

Fixed plane, Tilts/azimuths: 25°/ 1°





PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Main results


System Production

Produced Energy (P50) 9059392 kWh/year Specific production (P50) 1760 kWh/kWp/year Perf. Ratio PR 86.82 %
 Produced Energy (P90) 5254657 kWh/year Specific production (P90) 1663 kWh/kWp/year
 Produced Energy (P75) 7059039 kWh/year Specific production (P75) 1709 kWh/kWp/year

Normalized productions (per installed kWp)



Performance Ratio PR



Balances and main results

	GlobHor kWh/m ²	DiffHor kWh/m ²	T_Amb °C	GlobInc kWh/m ²	GlobEff kWh/m ²	EArray kWh	E_Grid kWh	PR ratio
January	73.4	30.70	9.60	110.6	98.3	3712333	3615438	0.833
February	92.6	37.60	9.70	125.8	116.1	4509780	4390182	0.890
March	140.4	54.90	11.50	169.3	157.5	6107128	5943911	0.894
April	170.8	67.30	14.30	185.0	172.2	6662502	6485320	0.893
May	214.8	73.90	18.50	213.3	198.8	7552201	7346011	0.878
June	228.3	71.60	22.70	218.7	204.3	7723578	7516051	0.876
July	244.9	67.20	25.20	239.2	224.0	8334505	8107060	0.864
August	214.6	64.00	25.50	226.8	212.3	7873185	7658055	0.860
September	155.3	58.00	22.30	178.0	165.4	6189253	6024428	0.862
October	116.4	48.10	18.70	149.5	138.6	5267542	5128713	0.874
November	76.4	34.10	14.50	110.3	98.8	3724416	3627657	0.838
December	65.4	28.40	10.89	100.3	88.6	3304134	3216566	0.818
Year	1793.3	635.80	16.99	2026.8	1874.9	70960557	69059392	0.868

Legends


GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_Grid	Energy injected into grid
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane		
GlobEff	Effective Global, corr. for IAM and shadings		



PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Loss diagram






PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Energia incidente di riferimento su piano collettori



Fattori normalizzati di produzione e di perdita






PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Distribuzione irraggiamento incidente



Coda della distribuzione di irradiazione incidente





PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Temperatura del campo vs. irradiazione efficace





Diagramma giornaliero entrata/uscita






PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Energia giornaliera in uscita sistema



Distribuzione potenza dell'impianto






PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Distribuzione potenza in uscita sistema



Coda della distribuzione della potenza in uscita






PVsyst V7.4.6


VC1, Simulation date:
25/03/24 12:19
with V7.4.6

Predef. graphs

Distribuzione tensione impianto



Distribuzione temperatura impianto





PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

P50 - P90 evaluation

Weather data

Source SolarGIS Monthly aver. , period not spec.
Kind Specific year
Year Sintetico
Year-to-year variability(Variance) 3.9 %

Specified Deviation

Year deviation from average 0.0 %

Global variability (weather data + system)

Variability (Quadratic sum) 4.3 %


Simulation and parameters uncertainties

PV module modelling/parameters 1.0 %
Inverter efficiency uncertainty 0.5 %
Soiling and mismatch uncertainties 1.0 %
Degradation uncertainty 1.0 %

Annual production probability

Variability 2.97 GWh
P50 69.06 GWh
P90 65.25 GWh
P75 67.06 GWh

Probability distribution





PVsyst V7.4.6

VC1, Simulation date:
25/03/24 12:19
with V7.4.6

CO₂ Emission Balance

Total: 1093672.4 tCO₂

Generated emissions

Total: 92752.40 tCO₂

Source: Detailed calculation from table below

Replaced Emissions

Total: 1367376.0 tCO₂

System production: 69059.39 MWh/yr

Grid Lifecycle Emissions: 660 gCO₂/kWh


Source: IEA List

Country: Zimbabwe

Lifetime: 30 years

Annual degradation: 1.0 %

Saved CO₂ Emission vs. Time



System Lifecycle Emissions Details

Item	LCE	Quantity	Subtotal
			[kgCO ₂]
Modules	1649 kgCO ₂ /kWp	54088 kWp	89206165
Supports	4.40 kgCO ₂ /kg	801300 kg	3527483
Inverters	436 kgCO ₂ /units	43.0 units	18754