

	PROGETTISTA  Tecnologia Ricerca Rischi	COMMESSA NQ/R21300/L01	UNITA' -
	LOCALITA' PORTO TORRES (SS) (SARDEGNA)	001-CI-E-60001	
	PROGETTO / IMPIANTO FSRU Porto Torres e Opere Connesse	Allegato C.4.2_1	Rev. 00

Rif. TRR: 72556

FSRU di PORTO TORRES e OPERE CONNESSE

Rapporto Preliminare di Sicurezza ai sensi del D.Lgs. 105/15

ALLEGATO C.4.2_1

ELABORATI DI CALCOLO 11R

0	Emissione per permessi	A.VISIGOTI	V.ROMANO	G.ROMANO	AGOSTO 2024
Rev.	Descrizione	Elaborato	Verificato	Approvato	Data

Input Report

Workspace: 2FSRURegas-11R

FSRU in rigassificazione

Study

2FSRURegas-11R

Tab	Group	Field	Value
Context of calculations	Selection of context	Weathers to use for this study	Weather folder
		Parameters to use for this study	Parameter set
		Obstructions to use for this study	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Default terrain
		Type of pool substrate and bunds	No bund
Toxic parameters	Indoor toxic calculations	Specify the downwind building type Building type (downwind building type)	Unselected

11R Linee BOG da serbatoi

Pressure vessel

2FSRURegas-11R\FSRU in rigassificazione

Tab	Group	Field	Value	Units
Material	Material	Material	GAS NATURALE	
		Specify volume inventory?	Yes	
		Mass inventory	1071,64	kg
		Volume inventory	127,4	m3
		Material to track	GAS NATURALE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	-42	degC
		Pressure (gauge)	7,5	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
Scenario	Pipe dimensions	Pipe length		m
	Release location	Elevation	17	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe	Pipe roughness	0,045	mm

	characteristics			
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	127,4	m ³
		Tank vapour volume	127,4	m ³
		Tank liquid volume	0	m ³
		Tank liquid level	0	m
		Maximum vapour release height	0	m

		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Default terrain	
		Type of pool substrate and bunds	No bund	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	None	
		Wind or release angle from North	0	deg
		Handling of	Trapped	

		droplets		
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: Uniform confined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	3	
		Intensity levels	4; 12,5; 37,5	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	

	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	3; 5; 7; 12,5; 37,5	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	3; 5; 7; 12,5; 37,5	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	



		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

90mm-1,1kg/s

User defined source

2FSRURegas-11R\FSRU in rigassificazione\11R Linee BOG da serbatoi

Tab	Group	Field	Value	Units
Scenario	Release scenario	Release scenario	Leak	
		The number of release observers	2	
	Release observers	Release time	3600	s
		Release phase	Vapour; Vapour	
		Mass flow	1,1; 1,1	kg/s
		Final velocity	300; 300	m/s
		Final temperature	-71,7136; -71,7136	degC
		Liquid fraction	0; 0	fraction
		Droplet diameter		um
		Pool radius		m
		Pre-dilution air rate	0; 0	kg/s
		Downstream calculation status	No errors detected	
	Release location	Elevation	17	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
	Fireball emissive power	Use vessel burst pressure	No	
		Vessel burst pressure - gauge		bar
	Jet fire Miller model hole size	Orifice diameter	0	mm
Material	Material	Material characteristics	Flammable only	
		Material to track	GAS NATURALE	

		Type of risk effects to model	Flammable only	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Default terrain	
		Type of pool substrate and bunds	No bund	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: Uniform confined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	3	
		Intensity levels	4; 12,5; 37,5	kW/m2
		Probit levels	2,73; 3,72; 7,5	

		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Automatic selection of method	Jet fire method to be used in calculations	Cone model	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	3; 5; 7; 12,5; 37,5	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	

	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	3; 5; 7; 12,5; 37,5	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s



Dispersion Report

Workspace: 2FSRURegas-11R

Study: FSRU in rigassificazione

Equipment Item: 11R Linee BOG da serbatoi

2FSRURegas-11R\FSRU in rigassificazione\11R Linee BOG da serbatoi

Material	GAS NATURALE	
East	0	m
North	0	m

Scenario (User defined source) : 90mm-1,1kg/s

2FSRURegas-11R\FSRU in rigassificazione\11R Linee BOG da serbatoi\90mm-1,1kg/s

Material to track	GAS NATURALE
-------------------	---------------------

Weather: Category 2/F

Wind speed [m/s]	2
Pasquill stability	F stable - night with moderate clouds and light/moderate wind
Atmospheric temperature [degC]	25
Relative humidity [fraction]	0,75
Solar radiation flux [kW/m2]	0,5
Mixing layer height [m]	100

Observer Release Data and Observer Mass Data

Observer number	Release type	Start time [s]	Start downwind distance [m]	Unit	Masses or mass rates		
					Release	Rainout	Final
1	Continuous	0	0	kg/s	1,1	0	1,1
2	Continuous	3600	0	kg/s	1,1	0	1,1



Weather: Category 5/D

Wind speed [m/s]	5
Pasquill stability	D neutral - little sun and high wind or overcast/windy night
Atmospheric temperature [degC]	25
Relative humidity [fraction]	0,75
Solar radiation flux [kW/m2]	0,5
Mixing layer height [m]	800

Observer Release Data and Observer Mass Data

Observer number	Release type	Start time [s]	Start downwind distance [m]	Unit	Masses or mass rates		
					Release	Rainout	Final
1	Continuous	0	0	kg/s	1,1	0	1,1
2	Continuous	3600	0	kg/s	1,1	0	1,1

