

REGIONE PUGLIA
CITTA' METROPOLITANA DI BARI
COMUNE DI RUVO DI PUGLIA

IMPIANTO EOLICO COMPOSTO DA 8 WTG DA 7.2 MW,
SISTEMA DI ACCUMULO ELETTROCHIMICO DELL'ENERGIA
ELETTRICA E OPERE DI CONNESSIONE ALLA RETE

R39

ANALISI ANEMOLOGICA

Proponente

RDP

RDP srl
CORSO MONFORTE 2
20122 Milano (MI)
P.IVA 13058670962
rdp.srl.pec@legalmail.it
Legale Rappresentante: Ing. Danilo Lerda

Progetto

STM Engineering

STIM ENGINEERING S.r.l.
VIA GARRUBA, 3 - 70121 BARI
Tel. 080.5210232 - Fax 080.5234353
www.stimeng.it - segreteria@stimeng.it

ing. Massimo CANDEO
Ordine Ing. Bari n° 3755
Via Cancellotto, 3
70125 Bari
m.candeo@pec.it
stimdue@stimeng.it
tel. +39 328 9569922

ing. Gabriele CONVERSANO
Ordine ing. Bari n° 8884
via Garruba, 3
70122 Bari
g.conversano@stimeng.it
gabrieleconversano@pec.it
tel. +39 328 6739206



Collaborazione:
ing. Antonio Campanale
ing. Flavia Blasi

**Progetto
elettrico**

ing. Gianluca Pantile
Ordine Ing. Brindisi n° 803
Via del Lavoro, 15/D
72100 Brindisi (BR)
Tel. cell. 3471939994
PEC: pantile.gianluca@ingpec.eu

luglio 24	1	TRADUZIONE IN LINGUA ITALIANA	ing. A.Campanale, F.Blasi, G.Conversano	ing. M. Candeo
gennaio 24	0	PRIMA EMISSIONE	ing. A.Campanale, F.Blasi, G.Conversano	ing. M. Candeo
Data	Rev.	DESCRIZIONE	Elaborato e controllato da:	Approvato da:

REVISIONI




EMD International A/S
www.emd.dk

Ruvo di Puglia Wind Farm

Valutazione preliminare del rendimento energetico

9 OTTOBRE 2023





Ruvo di Puglia

COMMITTENTE

Enlight
13 Ha'amal St.
Parco industriale di
Afek Rosh Ha'ayin
4809249
Israel

Attn. Danilo Lerda

DATA

09 Ottobre 2023

PREPARATO DA

EMD International A/S
Niels Jernes Vej 10
DK- 9220 Aalborg
Tel.: + 45 69 16 48 50
E: emd@emd.dk

CONSULENTI

Maurizio Motta
Stela M. Zanchettin

APPROVATO DA

Madalina Calin

DOCUMENTO

231009_23142_Ruvo_A_SZ_3

CLASSIFICAZIONE

Commerciale riservato



DOCUMENT REVISIONS

Revisione	Dati	Rapporto n.	Capitoli	Descrizione dello scopo/ cambiamenti
0	2023-09-12	230912_23142_Ruvo_A_MM_0	Complessivo	Report iniziale
1	2023-09-18	230922_23142_Ruvo_A_MM_1	Ex. Sommario e 5	Perdite ricalcolate
2	2023-09-22	230922_23142_Ruvo_A_MM_2	Ex. Sommario e 5	Perdite aggiornate
3	2023-10-09	231009_23142_Ruvo_A_SZ_3	Complessivo	Nuovo layout

CHIAVE PER LA CLASSIFICAZIONE DEI DOCUMENTI

Classificazione	
Strettamente confidenziale:	Solo destinatari
Privato e confidenziale:	Per la comunicazione alle persone direttamente interessate all'interno del organizzazione
Commerciale in confidenza:	Da non divulgare al di fuori dell'organizzazione del destinatario
Discrezione del cliente:	Distribuzione a discrezione del cliente previo accordo contrattuale
Edito:	Disponibile al pubblico

LIABILITIES

EMD International A/S (EMD) non garantisce, garantisce o rilascia alcuna dichiarazione in merito al materiale di consulenza fornito causato da errori o omissioni nei dati forniti. EMD non può essere ritenuta responsabile per risultati errati causati da imprecisioni, limitazioni o malfunzionamenti dei modelli o del software utilizzato.

Per qualsiasi reclamo relativo all'oggetto di questo lavoro di consulenza, la responsabilità di EMD per danni effettivi, indipendentemente dalla forma dell'azione, sarà limitata all'importo totale pagato a EMD per i servizi forniti nell'ambito di questo lavoro di consulenza. Su richiesta può essere fornita una copertura assicurativa separata per la responsabilità estesa, ma a spese del cliente.



Sintesi

Questo rapporto presenta la stima preliminare della produzione annuale di energia per il progetto del parco eolico di Ruvo di Puglia in Italia, con una capacità di 57,6 MW.

I calcoli sono stati effettuati utilizzando dati a mesoscala ad alta risoluzione (EMD-WRF Europe+ che coprono un periodo di 20 anni).

Il cliente ha fornito il layout che consiste in 8 turbine eoliche V172-7.2. Sono state prese in considerazione due diverse soluzioni di altezza del mozzo, 114 e 150 m.

Non sono stati presi in considerazione parchi eolici vicini.

La produzione annua di energia è riassunta nella tabella 1. Sono state calcolate le perdite di scia e di rete elettrica ed è stata stimata una somma forfettaria per altre perdite.

Una serie di ragioni rende questi risultati preliminari e da considerare con grande attenzione:

- L'input è costituito da dati di vento simulati da un modello a mesoscala, con una risoluzione orizzontale di 3x3 km: questi dati possono essere notoriamente errati rispetto alla verità sul terreno, in particolare su terreni complessi. Solo le misurazioni in loco possono garantire con precisione un investimento di questo tipo.
- I dati sono stati ridimensionati utilizzando precedenti esperienze nella regione, ma in un terreno diverso e distante. Sebbene questa procedura sia certamente utile (piuttosto che lasciare i dati completamente non calibrati), comporta ancora una significativa incertezza.

Per tutti i motivi sopra esposti, i risultati numerici indicati nella Tabella 1 possono essere considerati solo indicativi e, in termini di produzione e suoi derivati, sono influenzati da incertezze nell'ordine del 20%.



Tabella 1. Riepilogo dei risultati.

Descrizione del progetto		
Impaginazione	1	2
Tipo di turbina	V172-7.2	V172-7.2
Altezza mozzo [m]	114	150
Numero di turbine	8	8
Capacità installata [MW]	57.6	57.6
AEP lordo e netto preliminare		
Velocità media del vento a lungo termine [m/s] @ altezza del mozzo	6.4	6.6
Produzione lorda [GWh/a]	161	170
Produzione netta (P50) [GWh/a]	144	152
P50 - Fattore di capacità [%]	29	30
Incertezza, P90		
Incertezza (20 anni) [%]	20	20
P90 (20 anni) [GWh/a]	107	113
P90, Fattore di capacità [%]	21	22



Consigli

Per garantire una riduzione dell'incertezza e portare le stime a un livello bancabile, devono essere effettuate misurazioni in loco per almeno 12 mesi consecutivi, come raccomandato nelle "Linee guida tecniche per le turbine eoliche, TR6" [1] e MEASNET "Valutazione delle condizioni del vento specifiche del sito" [2].

Una corretta progettazione della campagna di misura è fondamentale per massimizzare le possibilità di ottenere la minima incertezza ottenibile sulla misurazione del vento e sull'estrapolazione del flusso.

A seconda dei vincoli sociali e ambientali – che non sono stati resi noti in questa fase – potrebbe esserci spazio per migliorare l'attuale assetto.



Contenuto

Sintesi	3
1 Scopo.....	8
2 Descrizione del sito	9
2.1 Ubicazione	9
2.2 Descrizione del terreno	9
3 Metodologia	10
4 Dati del vento	11
5 Risultati	13
5.1 Previsioni sulla resa energetica	13
6 Riferimenti.....	15
Appendix A. Calcolo del parco – 114 m HH.....	16
Appendix B. Calcolo del parco – 150 m HH	28



Elenco delle figure

Figura 1. Mappa OpenTopo della regione, con il layout preliminare come simboli rossi	9
Figura 2. Ubicazione del nodo dati a mesoscala (simbolo arancione) e delle turbine pianificate	10
Figura 3. Distribuzione di frequenza ed energia in posizione WTG 8, 150 m AGL basata su 20 anni di dati EMD- WRF Europe+ downscaled.....	12
Figura 4. Perdite incluse nei calcoli, in % e GWh/a: sopra, per il mozzo da 114 m, sotto, per il mozzo da 150 m.	14

Elenco delle tabelle

Tabella 1. Riepilogo dei risultati	4
Tabella 2. Velocità media del vento settoriale e frequenza dei dati del vento a 20 anni nella posizione di WTG 8, 150 m AGL.	11
Tabella 3. Risultati, P50 e P90.	13



1 Scopo

Questo rapporto presenta la stima preliminare della produzione annuale di energia, basata sui dati eolici di un modello a mesoscala per il progetto del parco eolico di Ruvo di Puglia in Italia con una capacità di 57,6 MW.

2 Descrizione del sito

2.1 Ubicazione

Il centro del parco eolico si trova a circa 7,5 km a sud-ovest della città di Ruvo di Puglia, in Italia.




Figura 1. Mappa OpenTopo della regione, con il layout preliminare come simboli rossi.

2.2 Descrizione del terreno

Le turbine previste si trovano su un piccolo altopiano, con il terreno che sale rapidamente verso sud-ovest, verso l'Appennino, e più dolcemente digrada verso il mare in direzione opposta.

Come dati digitali di elevazione, il TIN Italy DEM, 10 m di dati grigliati trasformati in curve di livello equidistanti di 5 m, è stato utilizzato per 20 x 20 km intorno al sito.

La rugosità è stata compilata dalle banche dati di copertura del suolo Corine 2018, griglia di 100 m per un'area di 60 x 60 km intorno al sito.

3 Metodologia

Ai fini della valutazione preliminare del rendimento energetico, si ritiene opportuno l'uso di dati a mesoscala.

I calcoli sono stati effettuati utilizzando 20 anni di dati eolici provenienti da un nodo di rete del modello a mesoscala ad alta risoluzione WRF (EMD-WRF Europe+)¹. La posizione del nodo a mesoscala può essere vista nella Figura 2.

I dati a mesoscala sono stati ridimensionati a livello di microscala del sito utilizzando una procedura [3] in cui i dati a mesoscala vengono elaborati da WAsP [4]. Il processo utilizza prima il terreno a mesoscala (fornito da EMD) sui dati a mesoscala, quindi i dati del terreno a microscala sulle turbine.

A causa della natura dei dati a mesoscala in cui le velocità del vento sono spesso compensate, i risultati iniziali della velocità del vento sono stati ulteriormente scalati di un fattore (1,018), sulla base dell'esperienza precedente nella regione. Questo passaggio in qualche modo aiuta a ridurre l'incertezza, ma allo stesso tempo si basa su condizioni del terreno diverse e distanti, e quindi di per sé comporta un'incertezza significativa.

Il set di dati risultante è stato quindi estrapolato a ciascuna località del WTG per valutare il microclima specifico, quindi utilizzato per stimare la produzione di energia.




Figura 2. Ubicazione del nodo dati a mesoscala (simbolo arancione) e delle turbine pianificate.

¹Sono stati ottenuti dati su mesoscala ad alta risoluzione EMD-WRF Europe+. Il modello a mesoscala ha una risoluzione spaziale di 0,03°x0,03° o circa 3x3 km con risoluzione temporale oraria. I dati ERA5 dell'ECMWF (<http://www.ecmwf.int>) sono stati utilizzati come set di dati sui confini globali. Le altezze modellate sono 200, 150, 100, 75, 50, 25, 10 m AGL. [5]



4 Dati del vento

Seguendo il metodo di downscaling descritto in precedenza, i dati sul vento a lungo termine utilizzati per le stime preliminari sono presentati di seguito, per una posizione rappresentativa (WTG 8).

Tabella 2. Velocità media del vento settoriale e frequenza dei dati del vento a 20 anni nella posizione di WTG 8, 150 m AGL.

Posizione	WTG 8	150 m s.l.m.
Settore	Velocità del vento medie aritmetiche [m/s]	Frequenza [%]
0 N	5.6	11.8
1 NNE	4.2	6.7
2 ENE	3.8	4.2
3 E	3.7	3.2
4 ESE	3.8	2.7
5 SSE	6.0	3.9
6 S	9.2	10.3
7 SSW	7.2	8.7
8 WSW	7.7	8
9 W	7.5	8.8
10 WNW	7.0	19.1
11 NNW	5.3	12.6
Tutto	6.4	100

La frequenza a lungo termine e la distribuzione dell'energia per i dati a mesoscala EMD-WRF Europe+ a 150 m AGL indicano una direzione principale dell'energia eolica da ovest-nord-ovest (Figura 3).




Figura 3. Distribuzione di frequenza ed energia in posizione WTG 8, 150 m AGL basata su 20 anni di dati EMD-WRF Europe+ downscaled.



5 Risultati

5.1 Previsioni sulla resa energetica

Sulla base della risorsa eolica stimata, del layout, delle curve di potenza standard e della densità dell'aria regolata, è stata calcolata la previsione energetica preliminare. I risultati sono presentati nella Tabella 3.

Le perdite sono state calcolate (scie e rete elettrica) o dato un valore standard, per ottenere la produzione netta.

Il livello di incertezza sulle previsioni annuali del rendimento energetico è elevato a causa dell'uso esclusivo di dati a mesoscala e stimato nell'ordine del 20%.

Si noti che per una valutazione preliminare come quella qui condotta, non è ritenuto pertinente e potrebbe persino essere fuorviante presentare una valutazione dettagliata delle perdite e dell'incertezza.

Tabella 3. Risultati, P50 e P90.

Risultati		
Impaginazione	1 (114 m HH)	2 (150 m HH)
Capacità installata [MW]	57.6	57.6
Produzione lorda [GWh/a]	161	170
Perdite di scia [%]	2.9	2.6
Perdite totali incl. perdite di scia [%]	10.6	10.4
Produzione netta (P50) [GWh/a]	144	152
Incertezza (20 anni) [%]	20	20
P90 (20 anni) [GWh/a]	107	113



LOSS			
	Method *)	Loss [%]	Loss [GWh/y]
1. Wake effects			
Wake effects, all WTGs	Calculation	2.9	4.7
2. Availability			
Turbine availability	Estimate	3.0	4.8
Balance of plant (Substation)	Estimate	0.2	0.3
3. Turbine performance			
High wind hysteresis	Calculation	0.1	0.1
Other turbine performance	Estimate	1.0	1.6
4. Electrical			
Electrical losses	Estimate	3.2	5.2
5. Environmental			
Performance degradation not due to icing	Estimate	0.5	0.8
High and low temperature	Calculation	0.1	0.2
6. Curtailment			
7. Other			
LOSS, total		10.6	17.0

LOSS			
	Method *)	Loss [%]	Loss [GWh/y]
1. Wake effects			
Wake effects, all WTGs	Calculation	2.6	4.5
2. Availability			
Turbine availability	Estimate	3.0	5.1
Balance of plant (Substation)	Estimate	0.2	0.3
3. Turbine performance			
High wind hysteresis	Calculation	0.1	0.1
Other turbine performance	Estimate	1.0	1.7
4. Electrical			
Electrical losses	Estimate	3.3	5.5
5. Environmental			
Performance degradation not due to icing	Estimate	0.5	0.8
High and low temperature	Calculation	0.1	0.2
6. Curtailment			
7. Other			
LOSS, total		10.4	17.6

Figura 4. Perdite incluse nei calcoli, in % e GWh/a: sopra, per il mozzo da 114 m, sotto, per il mozzo da 150 m.



6 Riferimenti

- [1] FGW, "Technical Guideline for Wind Turbines Part 6: Determination of Wind Potential and Energy Yield Rev 10," Fördergesellschaft Windenergie, 2017.
- [2] MEASNET, Evaluation of Site Specific Wind Conditions v3, 2022.
- [3] Badger, "Wind-Climate Estimation Based on Mesoscale and Microscale Modeling: Statistical–Dynamical Downscaling for Wind Energy Applications," DTU Wind Energy, 2014.
- [4] I. Troen and E. L. Petersen, "European Wind Atlas," Risø National Laboratory, Denmark, 1989.
- [5] L. Svenningsen, "Technical Note: Validation of EMD-WFR EUROPE+ (ERA5) mesoscale dataset," 2020.



Appendix A. Calcolo del parco – 114 m HH



Project: Ruvo
Description: EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:
EMD International A/S
 Niels Jernes Vej 10
 DK-9220 Aalborg Ø
 +45 6916 4850
 Stela Maris Zanchettin / sza@emd.dk
 Calculated:
 06/10/2023 10.08/4.0.518

PARK - Main Result

Calculation: 231006_8xV172 @114 m

Setup

AEP scaled to a full year based on number of samples
 Scaling factor from 20.0 years to 1 year: 0.050

Calculation performed in UTM (north)-WGS84 Zone: 33
 At the site centre the difference between grid north and true north is: 1.0°

Wake

Wake Model: N.O. Jensen (RISØ/EMD) Park 2 2018
Wake decay constant
 Wake decay constant: 0.090 DTU default onshore Hub height independent
 Reference WTG: 1


Scaler/wind data

Name: Meso Scaler
 Terrain scaling: Meso-scale Data Downscaling
 Micro terrain flow model: WAsP IBZ from Site Data
 Used period: 01/01/2001 01.00.00 - 01/01/2021
 Meteo object(s): EMD-WRF Europe+ (ERAS)_N41.067535_E016.46872 (2)
 Displacement height: Omnidirectional from objects
 WAsP version: WAsP 12 Version 12.08.0032

Power correction

Power curve correction (adjusted IEC method, improved to match turbine control)

	Min	Max	Avg	Corr.	Neg. corr.	Pos. corr.
	[%]	[%]	[%]	[%]	[%]	[%]
Air density						
EMD-WRF Europe+ (ERAS)_N41.067535_E016.46872 (2) - 100.00 m	[-5.5	39.4	15.5			
From air density settings	[956.0	969.7	962.1			
Resulting air density	[1.076	1.251	1.162			
Relative to 15°C at sea level	[87.8	102.1	94.8	-3.4	-3.4	0.0



Calculated Annual Energy for Wind Farm

WTG combination	Result [MWh/y]	GROSS (no loss) Free WTGs [MWh/y]	Wake loss [%]	Specific results ^{a)}		Wind speed		
				Capacity factor [%]	Mean WTG result [MWh/y]	Full load hours [Hours/year]	free [m/s]	wake reduced [m/s]
PARK	156,205.4	160,914.7	2.9	30.9	19,525.7	2,712	6.4	6.3

^{a)} Based on wake reduced results and any curtailments.

Calculated Annual Energy for each of 8 new WTGs with total 57.6 MW rated power

Valid	Manufact.	Type-generator	Power, rated [kW]	Rotor diameter [m]	Hub height [m]	Power curve Creator	Name	Annual Energy		Wind speed		
								Result [MWh/y]	Wake loss [%]	free [m/s]	reduced [m/s]	
1	Yes	VESTAS	V172-7.2-7,200	7,200	172.0	114.0	EMD	Level 0 & OS - Calculated - PO7200 - 07-2022	20,061.0	3.1	6.46	6.36
2	Yes	VESTAS	V172-7.2-7,200	7,200	172.0	114.0	EMD	Level 0 & OS - Calculated - PO7200 - 07-2022	19,947.4	2.1	6.40	6.31
3	Yes	VESTAS	V172-7.2-7,200	7,200	172.0	114.0	EMD	Level 0 & OS - Calculated - PO7200 - 07-2022	19,920.2	3.1	6.42	6.32
4	Yes	VESTAS	V172-7.2-7,200	7,200	172.0	114.0	EMD	Level 0 & OS - Calculated - PO7200 - 07-2022	20,115.7	2.1	6.43	6.35
5	Yes	VESTAS	V172-7.2-7,200	7,200	172.0	114.0	EMD	Level 0 & OS - Calculated - PO7200 - 07-2022	19,225.6	2.7	6.29	6.21
6	Yes	VESTAS	V172-7.2-7,200	7,200	172.0	114.0	EMD	Level 0 & OS - Calculated - PO7200 - 07-2022	19,267.3	2.3	6.27	6.20
7	Yes	VESTAS	V172-7.2-7,200	7,200	172.0	114.0	EMD	Level 0 & OS - Calculated - PO7200 - 07-2022	19,318.5	4.6	6.38	6.24
8	Yes	VESTAS	V172-7.2-7,200	7,200	172.0	114.0	EMD	Level 0 & OS - Calculated - PO7200 - 07-2022	18,349.7	3.5	6.17	6.07

Annual Energy results includes shown losses. For expected NET AEP (expected sold production), see report Loss & Uncertainty.

WTG siting

	UTM (north)-WGS84 Zone: 33			Z	Row data/Description	Calculation period	
	Easting	Northing				Start	End
1	New	620,594	4,548,218	344.3	1	01/01/2001	01/01/2021
2	New	619,923	4,547,025	339.4	2	01/01/2001	01/01/2021
3	New	620,781	4,546,252	338.4	3	01/01/2001	01/01/2021
4	New	619,868	4,547,939	340.3	4	01/01/2001	01/01/2021
5	New	622,790	4,545,940	325.0	5	01/01/2001	01/01/2021
6	New	623,046	4,544,553	311.7	6	01/01/2001	01/01/2021
7	New	624,139	4,545,263	315.0	7	01/01/2001	01/01/2021
8	New	624,715	4,545,798	289.5	8	01/01/2001	01/01/2021





Project: **Ruvo**


Description: Disclaimers: EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user: **EMD International A/S**
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated: 06/10/2023 10.08/4.0.518

PARK - Production Analysis

Calculation: 231006 8xV172 @114 m WTG: All new WTGs, Air density varies with WTG position 1.164 kg/m³ - 1.170 kg/m³
Directional Analysis

Sector	0 N	1 NNE	2 ENE	3 E	4 ESE	5 SSE	6 S	7 SSW	8 WSW	9 W	10 WNW	11 NNW	Total
Model based energy [MWh]	12,504.1	3,219.8	1,796.8	1,223.7	1,287.0	5,298.1	27,952.5	17,844.9	18,115.4	19,825.0	40,225.3	11,622.0	160,914.7
-Decrease due to wake losses [MWh]	567.6	91.0	145.5	41.2	69.4	78.5	502.9	319.1	654.6	345.6	1,589.4	304.4	4,709.3
Resulting energy [MWh]	11,936.5	3,128.7	1,651.4	1,182.6	1,217.7	5,219.7	27,449.6	17,525.8	17,460.8	19,479.3	38,635.9	11,317.5	156,205.4
Specific energy [kWh/m ²]													840
Specific energy [kWh/kW]													2,712
Decrease due to wake losses [%]													2.93
Full Load Equivalent [Hours/year]	207	54	29	21	21	91	477	304	303	338	671	196	2,712





Project: Description:

Ruvo

Disclaimer: EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:

EMD International A/S

Niels Jernes Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculate: 06/10/2023 10.08/4.0.518

PARK - Power Curve Analysis

Calculation: 231006_8xV172 @114 m WTG: 1 - VESTAS V172-7.2 7200 172.0 !O!, Hub height: 114.0 m

Name: Level 0 & OS - Calculated - PO7200 - 07-2022

Source: Manufacturer

Table with columns: Source/Date, Created by, Created, Edited, Stop wind speed [m/s], Power control, CT curve type, Generator type, Specific power kW/m^2. Values include 08/07/2022, EMD, 25/02/2022, 06/10/2022, 25.0, Pitch, User defined, Variable, 0.31.

HP curve comparison - Note: For standard air density

Table with columns: Vmean, HP value Pitch, variable speed (2013), VESTAS V172-7.2 7200 172.0 !O! Level 0 & OS - Calculated - PO7200 - 07-2022, Check value. Values include [m/s] 5-10, [MWh] 11,840-37,822, [%] 2-3.

The table shows comparison between annual energy production calculated on basis of simplified "HP-curves" which assume that all WTGs performs quite similar - only specific power loading (kW/m^2) and single/dual speed or stall/pitch decides the calculated values. Productions are without wake losses. For further details, ask at the Danish Energy Agency for project report 3.n.r. 51171/00-0016 or see the windPRO manual. The method is refined in EMD report "20 Detailed Case Studies comparing Project Design Calculations and actual Energy Productions for Wind Energy Projects worldwide", jan 2003. Use the table to evaluate if the given power curve is reasonable - if the check value are lower than -5%, the power curve probably is too optimistic due to uncertainty in power curve measurement.

Power curve



Original data, Air density: 1.225 kg/m^3

Table with columns: Wind speed [m/s], Power [kW], Cp, Wind speed [m/s], Ct curve. Data points from 2.0 to 25.0 m/s.

Power and efficiency vs. wind speed

Data used in calculation, Mean air density: 1.160 kg/m^3

Table with columns: Wind speed [m/s], Power [kW], Cp. Data points from 1.0 to 25.0 m/s.





Project: **Ruvo**

Description: Disclaimers: EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user: **EMD International A/S**
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated: 06/10/2023 10.08/4.0.518

PARK - Wind Data Analysis

Calculation: 231006_8xV172 @114 m Wind data: 1 - 1; Hub height: 114.0

Site coordinates





UTM (north)-WGS84 Zone: 33
East: 620,594 North: 4,548,218
1 - 1

Masts used

Take nearest

Winddata for site

Sector	Free mean wind speed [m/s]	Wake reduced mean wind speed [m/s]	Frequency [%]
0 N	5.6	5.6	11.2
1 NNE	4.3	4.3	6.6
2 ENE	4.0	4.0	4.1
3 E	3.7	3.7	3.0
4 ESE	3.7	3.6	2.6
5 SSE	5.7	5.7	3.9
6 S	8.6	8.5	10.5
7 SSW	7.3	7.0	9.2
8 WSW	7.9	7.4	8.1
9 W	7.6	7.4	9.2
10 WNW	7.2	7.2	20.0
11 NNW	5.2	5.2	11.3
All	6.5	6.4	100.0





Project: **Ruvo**

Description: Disclaimer: EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user: **EMD International A/S**
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated: 06/10/2023 10.08/4.0.518

PARK - Wind Data Analysis

Calculation: 231006_8xV172 @114 m Wind data: 8 - 8; Hub height: 114.0

Site coordinates





UTM (north)-WGS84 Zone: 33
East: 624,715 North: 4,545,798
8 - 8

Masts used

Take nearest

Winddata for site

Sector	Free mean wind speed [m/s]	Wake reduced mean wind speed [m/s]	Frequency [%]
0 N	5.4	5.4	11.2
1 NNE	4.1	4.1	6.6
2 ENE	3.7	3.7	4.1
3 E	3.6	3.6	3.0
4 ESE	3.6	3.6	2.6
5 SSE	5.6	5.6	3.9
6 S	8.6	8.6	10.5
7 SSW	7.0	6.8	9.2
8 WSW	7.4	6.9	8.1
9 W	7.1	6.9	9.2
10 WNW	6.7	6.6	20.0
11 NNW	5.0	5.0	11.3
All	6.2	6.1	100.0





Project: Ruvo

Description:

Disclaimer:

EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:

EMD International A/S

Niels Jerne Vej 10

DK-9220 Aalborg Ø

+45 6916 4850

Stela Maris Zanchettin / sza@emd.dk

Calculated:


06/10/2023 10.08/4.0.518

PARK - WTG distances

Calculation: 231006_8xv172 @114 m

WTG distances

	Z	Nearest WTG	Z	Horizontal distance	Distance in rotor diameters
	[m]		[m]	[m]	
1	344.3	4	340.3	777	4.5
2	339.4	4	340.3	915	5.3
3	338.4	2	339.4	1,155	6.7
4	340.3	1	344.3	777	4.5
5	325.0	6	311.7	1,410	8.2
6	311.7	7	315.0	1,303	7.6
7	315.0	8	289.5	786	4.6
8	289.5	7	315.0	786	4.6
Min	289.5	289.5	777	4.5	
Max	344.3	344.3	1,410	8.2	



A: New WTG

Scale: 1:75,000



Project: Ruvo

Description: Disclaimers:

EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:

EMD International A/S

Niels Jernes Vej 10
DK-9220 Aalborg Ø
+45 6916 4850

Stela Maris Zanchettin / sza@emd.dk

Calculated:
06/10/2023 10.08/4.0.518

PARK - Time varying AEP

Calculation: 231006_8xV172 @114 m

Windfarm: 57.6 MW based on 8 turbines of type VESTAS V172-7.2 7200 172.0 !O!

Selection: All new WTGs

Calculated mean yield per month and hour [MWh]. The result includes wake losses and any curtailment losses. Values are scaled to a full year, see correction factors at main result page.

Hour/Month [MWh]	1	2	3	4	5	6	7	8	9	10	11	12	Grand Total
0	796	780	831	743	742	540	563	507	511	564	688	798	8,061
1	808	796	833	724	746	577	585	533	541	570	698	793	8,204
2	811	800	832	728	732	601	609	549	551	564	695	784	8,256
3	796	801	841	728	740	630	619	552	565	548	693	794	8,307
4	798	791	849	738	724	639	624	565	566	541	679	800	8,314
5	791	781	866	724	714	628	632	563	570	540	679	789	8,279
6	797	777	852	718	648	535	576	537	551	530	680	795	7,997
7	792	775	832	601	483	363	399	393	469	509	685	787	7,088
8	792	734	695	482	413	314	326	297	331	412	645	785	6,227
9	699	607	576	426	380	266	292	252	283	351	539	707	5,378
10	573	546	552	406	359	243	268	230	260	329	471	600	4,838
11	534	507	531	404	364	266	299	231	249	315	450	571	4,723
12	512	488	517	408	407	328	364	286	254	317	442	542	4,865
13	509	501	524	441	415	346	404	336	278	318	444	537	5,053
14	511	509	543	427	406	339	390	360	298	330	443	517	5,072
15	520	512	560	428	397	322	356	334	296	329	441	508	5,004
16	561	508	558	419	406	289	322	298	285	341	481	548	5,017
17	651	536	550	416	411	274	295	257	263	393	552	625	5,224
18	671	620	596	443	395	237	253	238	284	449	594	683	5,463
19	693	677	672	527	466	248	255	243	320	490	618	706	5,917
20	715	700	748	627	565	309	295	280	378	518	634	728	6,496
21	746	727	797	702	652	376	371	324	419	542	651	751	7,058
22	775	743	811	735	703	446	458	407	453	560	666	768	7,525
23	795	759	827	739	734	501	519	464	482	567	676	777	7,838
Grand Total	16,647	15,973	16,796	13,735	13,002	9,619	10,072	9,036	9,459	10,929	14,243	16,695	156,205

Hour/Month [MW]	1	2	3	4	5	6	7	8	9	10	11	12	Grand Total
0	25.7	27.8	26.8	24.8	23.9	18.0	18.2	16.4	17.0	18.2	22.9	25.7	22.1
1	26.1	28.4	26.9	24.1	24.1	19.2	18.9	17.2	18.0	18.4	23.3	25.6	22.5
2	26.2	28.6	26.8	24.3	23.6	20.0	19.6	17.7	18.4	18.2	23.2	25.3	22.6
3	25.7	28.6	27.1	24.3	23.9	21.0	20.0	17.8	18.8	17.7	23.1	25.6	22.8
4	25.7	28.3	27.4	24.6	23.4	21.3	20.1	18.2	18.9	17.5	22.6	25.8	22.8
5	25.5	27.9	27.9	24.1	23.0	20.9	20.4	18.2	19.0	17.4	22.6	25.5	22.7
6	25.7	27.8	27.5	23.9	20.9	17.8	18.6	17.3	18.4	17.1	22.7	25.6	21.9
7	25.5	27.7	26.8	20.0	15.6	12.1	12.9	12.7	15.6	16.4	22.8	25.4	19.4
8	25.6	26.2	22.4	16.1	13.3	10.5	10.5	9.6	11.0	13.3	21.5	25.3	17.1
9	22.5	21.7	18.6	14.2	12.2	8.9	9.4	8.1	9.4	11.3	18.0	22.8	14.7
10	18.5	19.5	17.8	13.5	11.6	8.1	8.7	7.4	8.7	10.6	15.7	19.3	13.3
11	17.2	18.1	17.1	13.5	11.7	8.9	9.7	7.4	8.3	10.2	15.0	18.4	12.9
12	16.5	17.4	16.7	13.6	13.1	10.9	11.7	9.2	8.5	10.2	14.7	17.5	13.3
13	16.4	17.9	16.9	14.7	13.4	11.5	13.0	10.8	9.3	10.2	14.8	17.3	13.8
14	16.5	18.2	17.5	14.2	13.1	11.3	12.6	11.6	9.9	10.6	14.8	16.7	13.9
15	16.8	18.3	18.1	14.3	12.8	10.7	11.5	10.8	9.9	10.6	14.7	16.4	13.7
16	18.1	18.2	18.0	14.0	13.1	9.6	10.4	9.6	9.5	11.0	16.0	17.7	13.7
17	21.0	19.1	17.7	13.9	13.3	9.1	9.5	8.3	8.8	12.7	18.4	20.2	14.3
18	21.7	22.1	19.2	14.8	12.7	7.9	8.2	7.7	9.5	14.5	19.8	22.0	15.0
19	22.3	24.2	21.7	17.6	15.0	8.3	8.2	7.9	10.7	15.8	20.6	22.8	16.2
20	23.1	25.0	24.1	20.9	18.2	10.3	9.5	9.0	12.6	16.7	21.1	23.5	17.8
21	24.1	25.9	25.7	23.4	21.0	12.5	12.0	10.5	14.0	17.5	21.7	24.2	19.3
22	25.0	26.5	26.2	24.5	22.7	14.9	14.8	13.1	15.1	18.1	22.2	24.8	20.6
23	25.6	27.1	26.7	24.6	23.7	16.7	16.7	15.0	16.1	18.3	22.5	25.1	21.5
Grand Total	22.4	23.8	22.6	19.1	17.5	13.4	13.5	12.1	13.1	14.7	19.8	22.4	17.8





Project:
Ruvo

Description:
Disclaimer:
EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:
EMD International A/S
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated:
06/10/2023 10.08/4.0.518



PARK - Time varying AEP

Calculation: 231006_8xV172 @114 m

Windfarm: 57.6 MW based on 8 turbines of type VESTAS V172-7.2 7200 172.0 !O!

Selection: All new WTGs

Calculated mean yield per month and hour [MWh]. The result includes wake losses and any curtailment losses. Values are scaled to a full year, see correction factors at main result page.





Project: **Ruvo**

Description: **Disclaimer:**
EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:
EMD International A/S
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated:
06/10/2023 10.08/4.0.518

PARK - Time varying AEP

Calculation: 231006_8xV172 @114 m


Windfarm: 57.6 MW based on 8 turbines of type VESTAS V172-7.2 7200 172.0 !0!.

Selection: All new WTGs

Calculated mean yield per month and hour [MWh]. The result includes wake losses and any curtailment losses.

Hours	Hours [%]	Hours accumulated	Power [MW]	Power (MW/WTG)
197	2.2	197	57.6	7.2
576	6.6	772	55.1 - 57.6	6.9 - 7.2
191	2.2	963	52.6 - 55.1	6.6 - 6.9
155	1.8	1118	50.1 - 52.6	6.3 - 6.6
144	1.6	1263	47.6 - 50.1	5.9 - 6.3
147	1.7	1409	45.1 - 47.6	5.6 - 5.9
145	1.7	1555	42.6 - 45.1	5.3 - 5.6
147	1.7	1702	40.1 - 42.6	5.0 - 5.3
146	1.7	1848	37.6 - 40.1	4.7 - 5.0
149	1.7	1997	35.1 - 37.6	4.4 - 4.7
151	1.7	2148	32.6 - 35.1	4.1 - 4.4
155	1.8	2303	30.1 - 32.6	3.8 - 4.1
167	1.9	2470	27.5 - 30.1	3.4 - 3.8
177	2.0	2647	25.0 - 27.5	3.1 - 3.4
198	2.3	2845	22.5 - 25.0	2.8 - 3.1
215	2.5	3060	20.0 - 22.5	2.5 - 2.8
233	2.7	3293	17.5 - 20.0	2.2 - 2.5
257	2.9	3550	15.0 - 17.5	1.9 - 2.2
299	3.4	3849	12.5 - 15.0	1.6 - 1.9
355	4.1	4204	10.0 - 12.5	1.3 - 1.6
437	5.0	4641	7.5 - 10.0	0.9 - 1.3
548	6.2	5188	5.0 - 7.5	0.6 - 0.9
724	8.3	5912	2.5 - 5.0	0.3 - 0.6
1256	14.3	7168	0.0 - 2.5	0.0 - 0.3
1598	18.2	8766	0.0	0.0

Duration curve 57.6 MW WindFarm





Project:

Ruvo

Description:

Disclaimer:

EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:

EMD International A/S

Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850

Stela Maris Zanchettin / sza@emd.dk

Calculated:
06/10/2023 10.08/4.0.518

PARK - Scaling info

Calculation: 231006_8xV172 @114 m

Scaler settings

Name	Meso Scaler
Terrain scaling	Meso-scale Data Downscaling
RIX correction	No RIX correction
Displacement height	from objects
Micro terrain flow model	SDO

Site Data: SDO

Obstacles:

All obstacles used

Roughness:

Terrain data files used in calculation:

C:\Users\sza\Documents\WindPRO Data\Consultancy\Ruvo\ROUGHNESSLINE_Ruvo_0.wpo
Min X: 602,116, Max X: 642,030, Min Y: 4,526,595, Max Y: 4,568,008, Width: 39,913 m, Height: 41,413 m

Orography:

Terrain data files used in calculation:

C:\Users\sza\Documents\WindPRO Data\Consultancy\Ruvo\CONTOURLINE_ONLINEDATA_0.wpo
Min X: 559,556, Max X: 645,341, Min Y: 4,535,728, Max Y: 4,570,857, Width: 85,784 m, Height: 35,129 m

Post calibration

Overall factor	1.0180
Overall offset	0.0000
By sector	No
By month	No
By hour	No
By wind speed	No




Project:
Ruvo

Description:
Disclaimer:
EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.


Licensed user:
EMD International A/S
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated:
06/10/2023 10.08/4.0.518

PARK - Map

Calculation: 231006_8xV172 @114 m



Map data: © OpenStreetMap contributors (under ODbL) and SRTM | Map rendering: © OpenTopoMap (CC-BY-SA), Distribution through EMD and WindPRO.



Map: OpenTopoMap, Print scale 1:40,000, Map center UTM (north)-WGS84 Zone: 33 East: 622,291 North: 4,546,385

▲ New WTG



Appendix B. Calcolo del parco – 150 m HH



Project: Ruvo

Description: EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used.

Licensed user:

EMD International A/S
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
06/10/2023 10.09/4.0.518

PARK - Main Result

Calculation: 231006_8xV172 @150 m

Setup

AEP scaled to a full year based on number of samples
Scaling factor from 20.0 years to 1 year: 0.050

Calculation performed in UTM (north)-WGS84 Zone: 33
At the site centre the difference between grid north and true north is: 1.0°

Wake

Wake Model: N.O. Jensen (RISO/EMD) Park 2 2018
Wake decay constant: 0.090 DTU default onshore Hub height independent
Reference WTG: 1


Scaler/wind data

Name: Meso Scaler
Terrain scaling: Meso-scale Data Downscaling
Micro terrain flow model: WAsP IBZ from Site Data
Used period: 01/01/2001 01.00.00 - 01/01/2021
Meteo object(s): EMD-WRF Europe+ (ERAS)_N41.067535_E016.46872 (2)
Displacement height: Omnidirectional from objects
WAsP version: WAsP 12 Version 12.08.0032

Power correction

Power curve correction (adjusted IEC method, improved to match turbine control)

Table with columns: Min, Max, Avg, Corr., Neg. corr., Pos. corr. [%]. Rows: Air density, EMD-WRF Europe+, From air density settings, Resulting air density, Relative to 15°C at sea level.



Calculated Annual Energy for Wind Farm

Table with columns: WTG combination, Result, GROSS (no loss), Wake loss, Specific results (Capacity factor, Mean WTG result), Wind speed (Full load hours, free, wake reduced).

Calculated Annual Energy for each of 8 new WTGs with total 57.6 MW rated power

Table with columns: WTG type, Valid, Manufact., Type-generator, Power, rated, Rotor diameter, Hub height, Power curve, Creator, Name, Annual Energy, Wake loss, Wind speed, free, reduced.

Annual Energy results includes shown losses. For expected NET AEP (expected sold production), see report Loss & Uncertainty.

WTG siting

Table with columns: UTM (north)-WGS84 Zone: 33, Easting, Northing, Z, Row data/Description, Calculation period, Start, End.





Project: **Ruvo**


Description: Disclaimers: EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user: **EMD International A/S**
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated: 06/10/2023 10.09/4.0.518

PARK - Production Analysis

Calculation: 231006 8xV172 @150 m WTG: All new WTGs, Air density varies with WTG position 1.160 kg/m³ - 1.166 kg/m³
Directional Analysis

Sector	0 N	1 NNE	2 ENE	3 E	4 ESE	5 SSE	6 S	7 SSW	8 WSW	9 W	10 WNW	11 NNW	Total
Model based energy [MWh]	14,089.0	3,539.5	2,068.4	1,447.1	1,495.9	5,870.6	29,384.1	17,979.6	18,755.8	20,234.8	40,219.9	14,840.2	169,925.0
-Decrease due to wake losses [MWh]	610.0	94.3	153.3	45.4	73.4	75.3	449.7	292.8	590.3	295.5	1,469.0	353.8	4,502.8
Resulting energy [MWh]	13,479.0	3,445.2	1,915.1	1,401.7	1,422.5	5,795.3	28,934.4	17,686.8	18,165.4	19,939.3	38,751.0	14,486.4	165,422.3
Specific energy [kWh/m ²]													890
Specific energy [kWh/kW]													2,872
Decrease due to wake losses [%]	4.3	2.7	7.4	3.1	4.9	1.3	1.5	1.6	3.1	1.5	3.7	2.4	2.65
Full Load Equivalent [Hours/year]	234	60	33	24	25	101	502	307	315	346	673	251	2,872





Project: Description:

Ruvo

Disclaimer: EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:

EMD International A/S

Niels Jernes Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculate: 06/10/2023 10.09/4.0.518

PARK - Power Curve Analysis

Calculation: 231006_8xV172 @150 m WTG: 1 - VESTAS V172-7.2 7200 172.0 !O!, Hub height: 150.0 m

Name: Level 0 & OS - Calculated - PO7200 - 07-2022

Source: Manufacturer

Table with columns: Source/Date, Created by, Created, Edited, Stop wind speed [m/s], Power control, CT curve type, Generator type, Specific power [kW/m^2].

HP curve comparison - Note: For standard air density

Table comparing HP values for Vmean, Pitch, VESTAS V172-7.2 7200 172.0 !O!, and Check value across wind speeds 5-10 m/s.

The table shows comparison between annual energy production calculated on basis of simplified "HP-curves" which assume that all WTGs performs quite similar - only specific power loading (kW/m^2) and single/dual speed or stall/pitch decides the calculated values. Productions are without wake losses.

Power curve



Original data, Air density: 1.225 kg/m^3

Table with columns: Wind speed [m/s], Power [kW], Cp, Wind speed [m/s], Ct curve.

Power and efficiency vs. wind speed

Data used in calculation, Mean air density: 1.156 kg/m^3

Table with columns: Wind speed [m/s], Power [kW], Cp.





Project: Ruvo

Description: Disclaimer: EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user: EMD International A/S Niels Jerne Vej 10 DK-9220 Aalborg Ø +45 6916 4850 Stela Maris Zanchettin / sza@emd.dk Calculated: 06/10/2023 10.09/4.0.518

PARK - Wind Data Analysis

Calculation: 231006_8xV172 @150 m Wind data: 1 - 1; Hub height: 150.0

Site coordinates





UTM (north)-WGS84 Zone: 33 East: 620,594 North: 4,548,218 1 - 1

Masts used

Take nearest

Winddata for site

Table with 4 columns: Sector, Free mean wind speed [m/s], Wake reduced mean wind speed [m/s], Frequency [%]. Rows include sectors 0 N to 11 NNW and an All row.





Project: Ruvo

Description: Disclaimer: EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user: EMD International A/S Niels Jerne Vej 10 DK-9220 Aalborg Ø +45 6916 4850 Stela Maris Zanchettin / sza@emd.dk Calculated: 06/10/2023 10.09/4.0.518

PARK - Wind Data Analysis

Calculation: 231006_8xV172 @150 m Wind data: 8 - 8; Hub height: 150.0

Site coordinates





UTM (north)-WGS84 Zone: 33 East: 624,715 North: 4,545,798 8 - 8

Masts used

Take nearest

Winddata for site

Table with 4 columns: Sector, Free mean wind speed [m/s], Wake reduced mean wind speed [m/s], Frequency [%]. Rows include sectors 0 N to 11 NNW and an All row.





Project: **Ruvo**

Description:

Ruvo

Disclaimer:
EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:

EMD International A/S

Niels Jerne Vej 10

DK-9220 Aalborg Ø

+45 6916 4850

Stela Maris Zanchettin / sza@emd.dk

Calculated:


06/10/2023 10.09/4.0.518

PARK - WTG distances

Calculation: 231006_8xv172 @150 m

WTG distances

	Z	Nearest WTG	Z	Horizontal distance	Distance in rotor diameters
	[m]		[m]	[m]	
1	344.3	4	340.3	777	4.5
2	339.4	4	340.3	915	5.3
3	338.4	2	339.4	1,155	6.7
4	340.3	1	344.3	777	4.5
5	325.0	6	311.7	1,410	8.2
6	311.7	7	315.0	1,303	7.6
7	315.0	8	289.5	786	4.6
8	289.5	7	315.0	786	4.6
Min	289.5	289.5	777	777	4.5
Max	344.3	344.3	1,410	1,410	8.2



A New WTG

Scale 1:75,000



Project: Ruvo

Description:

Disclaimer:

EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:

EMD International A/S

Niels Jernes Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated: 06/10/2023 10.09/4.0.518

PARK - Time varying AEP

Calculation: 231006_8xV172 @150 m

Windfarm: 57.6 MW based on 8 turbines of type VESTAS V172-7.2 7200 172.0 !O!

Selection: All new WTGs

Calculated mean yield per month and hour [MWh]. The result includes wake losses and any curtailment losses. Values are scaled to a full year, see correction factors at main result page.

Table with 13 columns: Hour/Month [MWh], 1-12, Grand Total. Rows 0-23 showing monthly yield data.

Table with 13 columns: Hour/Month [MW], 1-12, Grand Total. Rows 0-23 showing monthly power yield data.





Project: **Ruvo**

Description:
Disclaimer:
EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:
EMD International A/S
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated:
06/10/2023 10.09/4.0.518



PARK - Time varying AEP

Calculation: 231006_8xV172 @150 m

Windfarm: 57.6 MW based on 8 turbines of type VESTAS V172-7.2 7200 172.0 !O!

Selection: All new WTGs

Calculated mean yield per month and hour [MWh]. The result includes wake losses and any curtailment losses. Values are scaled to a full year, see correction factors at main result page.





Project: **Ruvo**

Description: **Disclaimer:**
EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:
EMD International A/S
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated:
06/10/2023 10.09/4.0.518

PARK - Time varying AEP

Calculation: 231006_8xV172 @150 m


Windfarm: 57.6 MW based on 8 turbines of type VESTAS V172-7.2 7200 172.0 !O!

Selection: All new WTGs

Calculated mean yield per month and hour [MWh]. The result includes wake losses and any curtailment losses.

Hours	Hours [%]	Hours accumulated	Power [MW]	Power (MW/WTG)
308	3.5	308	57.6	7.2
709	8.1	1017	55.1 - 57.6	6.9 - 7.2
204	2.3	1221	52.6 - 55.1	6.6 - 6.9
156	1.8	1376	50.1 - 52.6	6.3 - 6.6
144	1.6	1521	47.6 - 50.1	5.9 - 6.3
138	1.6	1658	45.1 - 47.6	5.6 - 5.9
140	1.6	1799	42.6 - 45.1	5.3 - 5.6
136	1.5	1934	40.1 - 42.6	5.0 - 5.3
137	1.6	2071	37.6 - 40.1	4.7 - 5.0
140	1.6	2210	35.1 - 37.6	4.4 - 4.7
135	1.5	2345	32.6 - 35.1	4.1 - 4.4
139	1.6	2485	30.1 - 32.6	3.8 - 4.1
150	1.7	2635	27.5 - 30.1	3.4 - 3.8
163	1.9	2798	25.0 - 27.5	3.1 - 3.4
182	2.1	2980	22.5 - 25.0	2.8 - 3.1
198	2.3	3178	20.0 - 22.5	2.5 - 2.8
212	2.4	3390	17.5 - 20.0	2.2 - 2.5
247	2.8	3636	15.0 - 17.5	1.9 - 2.2
285	3.3	3922	12.5 - 15.0	1.6 - 1.9
346	3.9	4267	10.0 - 12.5	1.3 - 1.6
422	4.8	4689	7.5 - 10.0	0.9 - 1.3
541	6.2	5230	5.0 - 7.5	0.6 - 0.9
715	8.2	5946	2.5 - 5.0	0.3 - 0.6
1228	14.0	7174	0.0 - 2.5	0.0 - 0.3
1592	18.2	8766	0.0	0.0

Duration curve 57.6 MW WindFarm





Project:

Ruvo

Description:

Disclaimer:

EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.

Licensed user:

EMD International A/S

Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850

Stela Maris Zanchettin / sza@emd.dk

Calculated:
06/10/2023 10.09/4.0.518

PARK - Scaling info

Calculation: 231006_8xV172 @150 m

Scaler settings

Name	Meso Scaler
Terrain scaling	Meso-scale Data Downscaling
RIX correction	No RIX correction
Displacement height	from objects
Micro terrain flow model	SDO

Site Data: SDO

Obstacles:

All obstacles used

Roughness:

Terrain data files used in calculation:

C:\Users\sza\Documents\WindPRO Data\Consultancy\Ruvo\ROUGHNESSLINE_Ruvo_0.wpo
Min X: 602,116, Max X: 642,030, Min Y: 4,526,595, Max Y: 4,568,008, Width: 39,913 m, Height: 41,413 m

Orography:

Terrain data files used in calculation:

C:\Users\sza\Documents\WindPRO Data\Consultancy\Ruvo\CONTOURLINE_ONLINEDATA_0.wpo
Min X: 559,556, Max X: 645,341, Min Y: 4,535,728, Max Y: 4,570,857, Width: 85,784 m, Height: 35,129 m

Post calibration

Overall factor	1.0180
Overall offset	0.0000
By sector	No
By month	No
By hour	No
By wind speed	No




Project:
Ruvo

Description:
Disclaimer:
EMD International A/S does not warrant, guarantee or make any representations regarding the delivered consultancy material caused by errors or omissions in the delivered data. EMD cannot be held liable for erroneous results caused by inaccuracy, limitations or malfunctioning of models or software used. For any claim whatsoever related to the subject matter of this consultancy service, the liability of EMD International A/S for actual damages, regardless of the form of action, shall be limited to the total amount paid to EMD International for the services provided as part of this consultancy service. Separate insurance cover for extended liability can be provided upon request, but at the expense of the Client.


Licensed user:
EMD International A/S
Niels Jerne Vej 10
DK-9220 Aalborg Ø
+45 6916 4850
Stela Maris Zanchettin / sza@emd.dk
Calculated:
06/10/2023 10.09/4.0.518

PARK - Map

Calculation: 231006_8xV172 @150 m



Map data: © OpenStreetMap contributors (under ODbL) and SRTM | Map rendering: © OpenTopoMap (CC-BY-SA), Distribution through EMD and WindPRO.



Map: OpenTopoMap, Print scale 1:40,000, Map center UTM (north)-WGS84 Zone: 33 East: 622,291 North: 4,546,385

▲ New WTG