

**Progetto per la realizzazione di un impianto agrivoltaico
avanzato denominato “Pontedera” di potenza pari a
43,2 MWp nel comune di Pontedera (PI) e opere di
connessione alla RTN ricadenti nel Comune di
Ponsacco (PI)**

Relazione di calcolo di producibilità impianto



02/10/2024	00	Emissione per autorizzazione	D.Stangalino	G. D'Amico/ L. Marabeti/ O.Retini	F. Boni Castagnetti
Data	Rev.	Descrizione Emissione	Preparato	Verificato	Approvato
Logo Committente e Denominazione Commerciale 			ID Documento Committente H060_FV_BER_00014		
Logo Appaltatore e Denominazione Commerciale 			ID Documento Appaltatore -		



ID Documento Committente
H060_FV_BER_00014

Pagina
2 / 19

Numero
Revisione

00

Sommario

1	Premessa	3
2	Calcolo della producibilità.....	4

1 Premessa

La presente relazione riporta il calcolo di producibilità dell'impianto agrivoltaico avanzato denominato "Pontedera" di potenza 43,2 MWp, che la Società Iren Green Generation Tech s.r.l. (da qui anche indicata come IGGT s.r.l.) prevede di realizzare nel territorio del comune di Pontedera (PI) finalizzato alla produzione di energia elettrica rinnovabile, che sarà connesso alla R.T.N. 132 kV attraverso la realizzazione di una Sotto Stazione Elettrica di Utenza e il nuovo Stallo AT nella esistente CP di Ponsacco e-distribuzione.

	ID Documento Committente H060_FV_BER_00014	Pagina 4 / 19
		Numero Revisione
		00

2 Calcolo della producibilità

Far riferimento al report allegato.



Version 7.4.8

PVsyst - Simulation report

Grid-Connected System

Project: PONTEDERA_PVGis

Variant: VC3

Tracking system with backtracking

System power: 43.20 MWp

PONTEDERA - Italy

MASTER TECH INGEGNERIA



PVsyst V7.4.8
VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Project: PONTEDERA_PVGis

Variant: VC3

Project summary

Geographical Site PONTEDERA Italy	Situation Latitude 43.62 °N Longitude 10.66 °E Altitude 23 m Time zone UTC+1	Project settings Albedo 0.20
Weather data PONTEDERA PVGIS api TMY		

System summary

Grid-Connected System	Tracking system with backtracking	
PV Field Orientation Orientation Tracking plane, horizontal N-S axis Axis azimuth 20 °	Tracking algorithm Astronomic calculation Backtracking activated Wind stow Wind Speed threshold 10 m/s Wind stow position 0 °	Near Shadings According to strings : Slow (simul.) Electrical effect 100 % Diffuse shading Automatic
System information PV Array Nb. of modules 66640 units Pnom total 43.20 MWp	Inverters Nb. of units 145 units Pnom total 43.50 MWac Pnom ratio 0.993	
User's needs Unlimited load (grid)		

Results summary

Produced Energy 75.47 GWh/year	Specific production 1747 kWh/kWp/year	Perf. Ratio PR 88.89 %
--------------------------------	---------------------------------------	------------------------

Table of contents

Cover page	1
Project and results summary	2
Variant notes	3
General parameters, PV Array Characteristics, System losses	5
Horizon definition	11
Near shading definition - Iso-shadings diagram	12
Main results	13
Loss diagram	14
Predef. graphs	15



PVsyst V7.4.8
VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Project: PONTEDERA_PVGis
Variant: VC3

Variant notes

DATABASE METEO

> È stato utilizzato il database meteo PVGIS 5.2

ORIENTAMENTO

> È stato considerato un azimut +20° (verso Ovest) dell'asse del tracker secondo quanto evinto dal layout.
> Sono stati altresì considerati:
>> limite di rotazione dei tracker +-50°.
>> tecnologia backtracking attiva.
>> 10m/s come limite della velocità del vento che provoca la messa in protezione dei tracker (tilt 0°).

SISTEMA

> È stata considerata la seguente composizione del generatore
>> n. 2735 stringhe da 24 moduli
>> n. 145 inverter
> È stata considerata la tecnologia bifacciale dei moduli secondo trackers 2D illimitati e parametri geometrici derivanti dalle caratteristiche del generatore.
> L'albedo è stato posto pari a 0,2 quale valor medio per suolo con erba.

PERDITE

> Parametri Termici
>> Sono stati considerati moduli montati "liberi" con circolazione d'aria.
> Perdite Ohmiche
>> Tenuto conto della conformazione geometrica del campo si è ipotizzata una cdt media sui circuiti DC pari al 1% (come da richiesta del cliente).
>> Si è altresì considerato l'impiego di n.27 trasformatori con perdite a vuoto 0,1% e perdite a carico 1%; ai collegamenti fra inverter e trasformatori è stata attribuita una perdita pari a 1%.
>> Considerata la geometria dell'impianto si è ipotizzato un collegamento MT fra trasformatori e punto di consegna pari a 1500m con una perdita pari allo 0,1%.
> Qualità dei moduli
>> Sono stati considerati i parametri di default anche per il LID dato che nel .pan non è stato compilato il campo specifico.
> Sporco
>> È stato considerato un fattore di perdita annuale pari al 3%.
> Perdite IAM
>> Sono state considerate le perdite dichiarate dal costruttore.
> Ausiliari
>> Sono stata considerate consumi ausiliari pari a 145kW (10kW per cabina di trasformazione e 5kW per la cabina di consegna) comprendenti il consumo dei sistemi di raffreddamento.
>> Sono state considerate perdite notturne addizionali pari a 45kW (3kW per cabina di trasformazione) comprendenti le perdite della cabina di consegna.
> Decadimento
>> La simulazione è stata condotta con riferimento a primo anno e quindi non si è tenuto conto delle perdite per decadimento.
> Indisponibilità
>> È stata impostata una indisponibilità al 2% suddivisa in 5 periodi random.
> Correzione spettrale
>> Sono stati considerati i valori default di correzione spettrale per la tecnologia di moduli considerata.

ORIZZONTE

> Il profilo dell'orizzonte è stato importato da PVGIS 5.2.

CREAZIONE DELLO SCENARIO OMBRE

> Considerando l'assenza di fonti d'ombra significative è stato creato un modello "generico" del generatore (non rispondente alla reale disposizione dei moduli) il quale però rispetta le caratteristiche geometriche rilevanti:
>> superficie radiante pari a quella reale
>> pitch 5,5m
>> azimuth +20° (per tutto il generatore)
>> altezza dell'asse tracker da terra 3m (dato ipotizzato)
>> ombreggiamento secondo le stringhe dei moduli



PVsyst V7.4.8
VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Project: PONTEDERA_PVGis

Variant: VC3

Variant notes



PVsyst V7.4.8
VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Project: PONTEDERA_PVGis
Variant: VC3

PV Array Characteristics

Array #2 - Campo_2			
Number of PV modules	2616 units	Number of inverters	36 * MPPT 17% 6 units
Nominal (STC)	1700 kWp	Total power	1800 kWac
Modules	109 string x 24 In series		
At operating cond. (50°C)			
Pmpp	1591 kWp	Operating voltage	550-1500 V
U mpp	1001 V	Max. power (=>30°C)	330 kWac
I mpp	1589 A	Pnom ratio (DC:AC)	0.94
		No power sharing between MPPTs	
Array #7 - Campo_7			
Number of PV modules	1392 units	Number of inverters	18 * MPPT 17% 3 units
Nominal (STC)	905 kWp	Total power	900 kWac
Modules	58 string x 24 In series		
At operating cond. (50°C)			
Pmpp	846 kWp	Operating voltage	550-1500 V
U mpp	1001 V	Max. power (=>30°C)	330 kWac
I mpp	845 A	Pnom ratio (DC:AC)	1.01
		No power sharing between MPPTs	
Array #9 - Campo_9			
Number of PV modules	1320 units	Number of inverters	18 * MPPT 17% 3 units
Nominal (STC)	858 kWp	Total power	900 kWac
Modules	55 string x 24 In series		
At operating cond. (50°C)			
Pmpp	803 kWp	Operating voltage	550-1500 V
U mpp	1001 V	Max. power (=>30°C)	330 kWac
I mpp	802 A	Pnom ratio (DC:AC)	0.95
		No power sharing between MPPTs	
PV module		Inverter	
Manufacturer	LONGi solar	Manufacturer	Huawei Technologies
Model	LR7-72HYD-660M	Model	SUN2000-330KTL-H1
(Custom parameters definition)		(Original PVsyst database)	
Unit Nom. Power	660 Wp	Unit Nom. Power	300 kWac
Number of PV modules	53352 units	Number of inverters	117 units
Nominal (STC)	35.21 MWp	Total power	35100 kWac
Array #3 - Campo_3			
Number of PV modules	8232 units	Number of inverters	108 * MPPT 17% 18 units
Nominal (STC)	5433 kWp	Total power	5400 kWac
Modules	343 string x 24 In series		
At operating cond. (50°C)			
Pmpp	5083 kWp	Operating voltage	550-1500 V
U mpp	1008 V	Max. power (=>30°C)	330 kWac
I mpp	5054 A	Pnom ratio (DC:AC)	1.01
		No power sharing between MPPTs	
Array #4 - Campo_4			
Number of PV modules	17952 units	Number of inverters	234 * MPPT 17% 39 units
Nominal (STC)	11.85 MWp	Total power	11700 kWac
Modules	748 string x 24 In series		
At operating cond. (50°C)			
Pmpp	11.09 MWp	Operating voltage	550-1500 V
U mpp	1006 V	Max. power (=>30°C)	330 kWac
I mpp	11022 A	Pnom ratio (DC:AC)	1.01
		No power sharing between MPPTs	



PVsyst V7.4.8

VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Project: PONTEDERA_PVGis

Variant: VC3

PV Array Characteristics

Array #5 - Campo_5			
Number of PV modules	11976 units	Number of inverters	156 * MPPT 17% 26 units
Nominal (STC)	7904 kWp	Total power	7800 kWac
Modules	499 string x 24 In series		
At operating cond. (50°C)		Operating voltage	550-1500 V
Pmpp	7395 kWp	Max. power (=>30°C)	330 kWac
U mpp	1006 V	Pnom ratio (DC:AC)	1.01
I mpp	7353 A	No power sharing between MPPTs	
Array #6 - Campo_6			
Number of PV modules	4416 units	Number of inverters	60 * MPPT 17% 10 units
Nominal (STC)	2915 kWp	Total power	3000 kWac
Modules	184 string x 24 In series		
At operating cond. (50°C)		Operating voltage	550-1500 V
Pmpp	2727 kWp	Max. power (=>30°C)	330 kWac
U mpp	1006 V	Pnom ratio (DC:AC)	0.97
I mpp	2711 A	No power sharing between MPPTs	
Array #8 - Campo_8			
Number of PV modules	10776 units	Number of inverters	144 * MPPT 17% 24 units
Nominal (STC)	7112 kWp	Total power	7200 kWac
Modules	449 string x 24 In series		
At operating cond. (50°C)		Operating voltage	550-1500 V
Pmpp	6654 kWp	Max. power (=>30°C)	330 kWac
U mpp	1006 V	Pnom ratio (DC:AC)	0.99
I mpp	6616 A	No power sharing between MPPTs	
Total PV power		Total inverter power	
Nominal (STC)	43200 kWp	Total power	43500 kWac
Total	65640 modules	Number of inverters	145 units
Module area	177306 m ²	Pnom ratio	0.99
Cell area	164940 m ²	No power sharing	

Array losses

Array Soiling Losses		Thermal Loss factor		Serie Diode Loss				
Loss Fraction	3.0 %	Module temperature according to irradiance		Voltage drop	0.7 V			
		Uc (const)	29.0 W/m ² K	Loss Fraction	0.1 % at STC			
		Uv (wind)	0.0 W/m ² K/m/s					
LID - Light Induced Degradation		Module Quality Loss		Module mismatch losses				
Loss Fraction	2.0 %	Loss Fraction	-0.8 %	Loss Fraction	2.0 % at MPP			
Strings Mismatch loss								
Loss Fraction	0.1 %							
IAM loss factor								
Incidence effect (IAM): User defined profile								
0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	1.000	1.000	1.000	0.990	0.970	0.910	0.820	0.000



Project: PONTEDERA_PVGis

Variant: VC3

PVsyst V7.4.8

VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Array losses

Spectral correction

FirstSolar model

Precipitable water estimated from relative humidity

Coefficient Set	C0	C1	C2	C3	C4	C5
Monocrystalline Si	0,85014	-0,02088	-0,0058853	0,12029	0,026814	-0,001781

DC wiring losses

Global wiring resistance 0.27 mΩ
Loss Fraction 1.0 % at STC

Array #1 - Campo_1

Global array res. 2.6 mΩ
Loss Fraction 1.0 % at STC

Array #3 - Campo_3

Global array res. 2.2 mΩ
Loss Fraction 1.0 % at STC

Array #5 - Campo_5

Global array res. 1.5 mΩ
Loss Fraction 1.0 % at STC

Array #7 - Campo_7

Global array res. 13 mΩ
Loss Fraction 1.0 % at STC

Array #9 - Campo_9

Global array res. 14 mΩ
Loss Fraction 1.0 % at STC

Array #2 - Campo_2

Global array res. 6.8 mΩ
Loss Fraction 1.0 % at STC

Array #4 - Campo_4

Global array res. 0.99 mΩ
Loss Fraction 1.0 % at STC

Array #6 - Campo_6

Global array res. 4.0 mΩ
Loss Fraction 1.0 % at STC

Array #8 - Campo_8

Global array res. 1.6 mΩ
Loss Fraction 1.0 % at STC

System losses

Unavailability of the system

Time fraction 2.0 %
7.3 days,
5 periods

Auxiliaries loss

constant (fans) 145.0 kW
10.0 kW from Power thresh.
Night aux. cons. 45.0 kW

AC wiring losses

Inv. output line up to MV transfo

Inverter voltage 800 Vac tri
Loss Fraction 0.94 % at STC

Inverter: SUN2000-330KTL-H1

Wire section (145 Inv.) Alu 145 x 3 x 185 mm²
Average wires length 120 m

MV line up to Injection

MV Voltage 30 kV
Average each inverter
Wires Alu 3 x 240 mm²
Length 1500 m
Loss Fraction 0.10 % at STC



PVsyst V7.4.8

VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Project: PONTEDERA_PVGis

Variant: VC3

AC losses in transformers

MV transfo	
Grid voltage	30 kV
One transfo in each sub-array	
Array #1 - Campo_1	
Transformer parameters	
Nominal power at STC	4.48 MVA
Iron Loss (24/24 Connexion)	4.80 kVA
Iron loss fraction	0.11 % at STC
Copper loss	41.78 kVA
Copper loss fraction	0.93 % at STC
Coils equivalent resistance	3 x 1.33 mΩ
Array #2 - Campo_2	
Transformer parameters	
Nominal power at STC	1.68 MVA
Iron Loss (24/24 Connexion)	1.80 kVA
Iron loss fraction	0.11 % at STC
Copper loss	15.74 kVA
Copper loss fraction	0.94 % at STC
Coils equivalent resistance	3 x 3.56 mΩ
Array #3 - Campo_3	
Transformer parameters	
Nominal power at STC	5.38 MVA
Iron Loss (24/24 Connexion)	5.40 kVA
Iron loss fraction	0.10 % at STC
Copper loss	53.56 kVA
Copper loss fraction	1.00 % at STC
Coils equivalent resistance	3 x 1.19 mΩ
Array #4 - Campo_4	
Transformer parameters	
Nominal power at STC	11.73 MVA
Iron Loss (24/24 Connexion)	11.70 kVA
Iron loss fraction	0.10 % at STC
Copper loss	117.56 kVA
Copper loss fraction	1.00 % at STC
Coils equivalent resistance	3 x 0.55 mΩ
Array #5 - Campo_5	
Transformer parameters	
Nominal power at STC	7.82 MVA
Iron Loss (24/24 Connexion)	7.79 kVA
Iron loss fraction	0.10 % at STC
Copper loss	78.48 kVA
Copper loss fraction	1.00 % at STC
Coils equivalent resistance	3 x 0.82 mΩ
Array #6 - Campo_6	
Transformer parameters	
Nominal power at STC	2.88 MVA
Iron Loss (24/24 Connexion)	3.00 kVA
Iron loss fraction	0.10 % at STC
Copper loss	27.75 kVA
Copper loss fraction	0.96 % at STC
Coils equivalent resistance	3 x 2.13 mΩ



PVsyst V7.4.8

VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Project: PONTEDERA_PVGis

Variant: VC3

AC losses in transformers

MV transfo	
Grid voltage	30 kV
One transfo in each sub-array	
Array #7 - Campo_7	
Transformer parameters	
Nominal power at STC	895 kVA
Iron Loss (24/24 Connexion)	0.90 kVA
Iron loss fraction	0.10 % at STC
Copper loss	8.91 kVA
Copper loss fraction	1.00 % at STC
Coils equivalent resistance	3 x 7.11 mΩ
Array #8 - Campo_8	
Transformer parameters	
Nominal power at STC	7.04 MVA
Iron Loss (24/24 Connexion)	7.19 kVA
Iron loss fraction	0.10 % at STC
Copper loss	68.83 kVA
Copper loss fraction	0.98 % at STC
Coils equivalent resistance	3 x 0.89 mΩ
Array #9 - Campo_9	
Transformer parameters	
Nominal power at STC	849 kVA
Iron Loss (24/24 Connexion)	0.90 kVA
Iron loss fraction	0.11 % at STC
Copper loss	8.01 kVA
Copper loss fraction	0.94 % at STC
Coils equivalent resistance	3 x 7.11 mΩ



Project: PONTEDERA_PVGis
Variant: VC3

PVsyst V7.4.8

VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Horizon definition


Horizon from PVGIS website API, Lat=43°37'8", Long=10°39'49", Alt=23m

Average Height 1.6 ° Albedo Factor 0.96
Diffuse Factor 0.99 Albedo Fraction 100 %

Horizon profile

Azimuth [°]	-180	-173	-165	-158	-150	-143	-135	-120	-113	-105	-98	-90	-83
Height [°]	1.5	2.3	2.3	3.4	3.8	3.4	4.2	4.2	3.1	1.9	1.9	3.1	2.7
Azimuth [°]	-75	-68	-60	-53	-15	-8	8	15	23	30	45	53	68
Height [°]	2.7	1.5	1.1	0.8	0.8	1.1	1.1	1.9	1.5	1.1	1.1	0.8	0.8
Azimuth [°]	75	98	105	120	128	143	150	158	165	173	180		
Height [°]	0.4	0.4	0.0	0.0	0.4	2.7	2.7	1.9	1.1	1.5	1.5		



Sun Paths (Height / Azimuth diagram)





Project: PONTEDERA_PVGis
Variant: VC3

PVsyst V7.4.8
VC3. Simulation date:
17/09/24 09:53
with V7.4.8







Project: PONTEDERA_PVGis
Variant: VC3

PVsyst V7.4.8
VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Main results

System Production
Produced Energy **75.47 GWh/year**
Specific production **1747 kWh/kWp/year**
Perf. Ratio PR **86.89 %**



Balances and main results

	GlobHor kWh/m ²	DiffHor kWh/m ²	T_Amb °C	GlobInc kWh/m ²	GlobEff kWh/m ²	EArray GWh	E_Grid GWh	PR ratio
January	51.2	22.15	4.11	69.0	65.0	2.94	2.75	0.924
February	68.9	29.68	5.90	92.4	87.4	3.89	3.69	0.923
March	100.4	47.69	9.04	126.8	120.0	5.24	4.72	0.882
April	161.4	57.75	14.85	209.3	199.1	8.40	8.06	0.892
May	208.7	71.37	17.57	264.5	252.0	10.50	10.09	0.883
June	207.5	76.06	21.02	260.4	248.0	10.27	9.46	0.841
July	237.7	63.38	23.47	310.5	296.4	12.09	11.65	0.868
August	189.2	69.82	21.98	244.6	232.9	9.70	9.34	0.883
September	148.4	48.15	21.68	196.1	186.8	7.81	6.96	0.822
October	87.0	40.39	13.46	115.2	109.0	4.76	4.17	0.838
November	54.4	28.98	11.14	71.5	67.2	3.00	2.62	0.849
December	38.3	22.16	5.55	50.3	47.0	2.14	1.96	0.902
Year	1553.2	577.58	14.18	2010.6	1910.7	80.75	75.47	0.869

Legends

GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_Grid	Energy injected into grid
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane		
GlobEff	Effective Global, corr. for IAM and shadings		




PVsyst V7.4.8

VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Project: PONTEDERA_PVGis

Variant: VC3






PVsyst V7.4.8
VC3, Simulation date:
17/09/24 09:53
with V7.4.8

Project: PONTEDERA_PVGis

Variant: VC3

Predef. graphs

Diagramma giornaliero entrata/uscita



Distribuzione potenza in uscita sistema

