



PARTICOLARE 1

TIPOLOGICI GIUNZIONI/SALDATURE

Cadweld connection
 Example of Cadweld connection (exothermic welding):
 - Ring grounding electrode on ground rod
 - Ring grounding electrode on reinforcing steel
 - Ring grounding electrode on galvanized steel strip (30 x 3.5 mm)

Connection clamps
 Grounding loop and cross connection cross-pieces for above and below ground connections for connection of conductors in crosswise and T-arrangement with intermediate plate for R4 and F1 material; clamp: NBRD (V4A), clamp range R4Rd: 8-10/8-10 mm, clamp range R4FF: 8-10/30 mm, clamp range F1FF: 30/30 mm

Connecting clamps, foundation loop and cross connections
 Cross-pieces for above and below ground connections for connection of conductors in crosswise and T-arrangement without intermediate plate for F1 and F1 material; clamp: SDCZ, clamp range F1FF: 30/30 mm

Clamps for connecting round conductors, cables and flat cables to ground rods

Terminals for connecting round and flat cables in the concrete foundation or concrete reinforcing mats and reinforcements to round and flat cables

PARTICOLARE 2

TIPOLOGICI DISP. VERTICALE O IN ALTERNATIVA IN ACC. ZINCATO A CROCE L.3m

Hammer inserts for driving in ground rods using vibratory hammers

Ground rods
 1.5 m, 20 mm Ø, SIZn
 Typ 9

Impact tips

PARTICOLARE 3

Inspection shaft for ground connection

The ERICO TIP-03 inspection shaft has a closable cover and is suitable for an equipotential bonding busbar. The following ground connections can be connected:

1. Connection of ground rods
2. Grounding of the external transformer station
3. Grounding of the stairs
4. Radial extension of the grounding system if the grounding resistance is too high
5. Resurveying of the grounding resistance

DIMENSIONI MINIME 25x25x25

REGIONE SICILIA
 Provincia di Catania
 COMUNI DI MILITELLO VAL DI CATANIA - VIZZINI - MINEO

PROGETTO
POTENZIAMENTO PARCO EOLICO MINEO-MILITELLO- VIZZINI

PROGETTO DEFINITIVO

COMMITTEE

PROGETTISTA

 Hydro Engineering s.r.l.
 di Damiano e Mariano Galbo
 via Rossini, 39
 91011 Alcamo (TP) Italy

OGGETTO DELL'ELABORAZIONE
RETE DI TERRA E FONDAZIONE WTG

REV.	DATA	ATTIVITA'	REDAITTO	VERIFICATO	APPROVATO
0	FEB 2018	PRIMA DESCRIZIONE	LV	VF	MG

CODICE PROGETTISTA	DATA	SCALA	FORMATO	FOGLIO	CODICE COMMITTENTE
	Febbraio 2018	Varie	A0	1 di 1	MMV ENG TAV 0075 00

NDME FILE: MMV-ENG-TAV-0075_00.dwg
 ERICO Wind Sic 2 0.1 x ERICO Wind Sic 1 0.1 x ERICO TAV 0075 00 (1) x ERICO TAV 0075 00 (1) x ERICO TAV 0075 00 (1) x ERICO TAV 0075 00 (1)