

## TABELLA 4.4/1

ENEL - Centrale di Porto Corsini - Sezione Termoelettrica n. E

Sistema di Misura delle Emissioni

Andamento Orario delle Grandezze Acquisite dal Sistema

dal 31/12/2005 01:00:00 al 01/01/2006 00:00:00

(ALLEGATO 10)

	1 :00	2 :00	3 :00	4 :00	5 :00	6 :00	7 :00	8 :00	9 :00	10:00	11:00	12:00
NOX TQ (mg/Nm3)	19.1	19.5	18.3	18.3	16.2	16.0	15.8	16.1	15.9	16.9	19.6	20.0
NOX (mg/Nm3)	16.7	17.0	16.2	16.1	14.9	14.7	14.6	14.7	14.6	15.1	17.1	17.4
CO TQ (mg/Nm3)	0.7	0.6	1.0	1.1	2.6	1.2	1.8	1.0	1.2	0.5	0.5	0.5
CO (mg/Nm3)	0.6	0.5	0.9	1.0	2.4	1.1	1.7	0.9	1.1	0.5	0.4	0.5
O2 Riferimento (%)	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0
O2 Misurato (%)	14.1	14.1	14.1	14.1	14.4	14.4	14.4	14.3	14.4	14.2	14.1	14.0
O2 Stimato (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Temperatura Fumi (°C)	111.1	111.1	110.3	109.8	105.1	106.0	105.3	106.4	106.2	108.7	111.7	112.4
Pressione Fumi (mbar)	1003.7	1003.0	1002.1	1002.8	1000.3	999.8	1001.1	1000.7	1000.4	1001.9	1003.2	1002.8
Umidita' (%)	S 8.0	S 8.0	S 7.9	S 7.9	S 7.6	S 7.7	S 7.7	S 7.7	S 7.7	S 7.8	S 8.0	S 8.0
Port. Fumi (1000°Nm3/h)	S 1615.2	S 1608.6	S 1566.1	S 1547.7	S 1241.9	S 1289.3	S 1258.4	S 1317.4	S 1292.8	S 1450.2	S 1639.3	S 1681.8
Portata Gas (Sm3/h)	61352.7	60805.2	58876.7	58057.3	46287.0	48518.0	47118.2	49632.8	48696.8	55277.1	62620.9	64295.8
Potenza Generata (MW)	350.5	348.9	338.1	333.5	258.5	270.3	261.9	277.1	270.9	310.5	355.9	366.2
Stato Sezione Term.	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON