

**ALLEGATO
ACQ-6**

		Parametri (mg/l)																							
		SS	COD	Al	As	Ba	Cd	Cr tot	CrVI	Fe	Mn	Hg	Ni	Pb	Cu	Se	Sn	Zn	CN-	NH4+	NO2-	NO3-	oli	fenoli	S-
IMPIANTO DI DEPURAZIONE	ingr	5731		232	0.018	0.24	0.0012	0.05	0.01	15.5	0.52	0.001	0.05	0.003	0.01	0.01	0.001	0.003					0.5		
	uscita	0.03		0.12	0.015	0.11	0.0002	0.05	0.01	0.62	0.02	0.001	0.01	0.007	0.002	0.002	0.002	0.005					0.5		
IMPIANTO BIOLOGICO SOTTOPRODOTTI	ingr	46	932	0.33	0.001	0.07	0.0002	0.15	0.01	32.5	0.27	0.001	0.1	0.004	0.02	0.029	0.001	0.009	14.9	990	0.27	1.49	2.39	77.6	<0.1
	uscita	90	346	0.22	0.0008	0.07	0.0002	0.05	0.01	26.6	0.19	0.001	0.04	0.009	0.016	0.022	0.002	0.009	0.53	1100	0.1	4.42	0.02	<0.04	<0.1
	ingr	290	1044	0.54	0.012	0.07	0.0002	0.05	0.01	17.5	0.12	0.001	0.01	0.003	0.025	0.02	0.001	0.003	26.26	399	<0.1	2.32	0.5	128	<0.1
	uscita	58	261	0.19	0.009	0.07	0.0002	0.05	0.01	19.1	0.09	0.001	0.01	0.004	0.02	0.02	0.001	0.003	1.16	704	<0.1	1.3	0.5	0.04	<0.1