


- Legenda
- Sorgenti d'impatto elettromagnetico (380 kV)
 - Sorgenti d'impatto elettromagnetico (120 kV)
 - Fascia di rispetto per il campo magnetico (3 uT)



Nella revisione della presente tavola non sono variate le informazioni afferenti ai temi illustrati in legenda, ma solo la base planimetrica e la scala di rappresentazione.



1	09/01/09	Seconda emissione	SG	RC	MZ
0	23/01/06	Prima emissione	DS	MZ	MZ
LETTER	DATE	DESCRIPTION	BY	CHK	APP.

api raffineria di Ancona S.p.A. CENTRALE A CICLO COMBINATO DA 580 Mwe		APPROVED FOR CONSTRUCTION DWG. REV. DATE SIGNATURE	
Allegato B26 - Planimetria 1/2 Planimetria dello stabilimento con individuazione delle sorgenti d'impatto elettromagnetico		ORDER N° SUPPLIER CONTRACT N° 1-BH-0233A	FRAME N° THIS DWG. SUPERSEDED BY SCALE
FOSTER WHEELER ITALIANA S.P.A. ENVIRONMENTAL DIVISION <small>THIS DRAWING IS THE PROPERTY OF FOSTER WHEELER ITALIANA AND IS LENT WITHOUT CONSIDERATION OTHER THAN THE BORROWER'S AGREEMENT THAT IT SHALL NOT BE REPRODUCED, COPIED, LENT OR DISPOSED OF DIRECTLY OR INDIRECTLY, NOR USED FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY FURNISHED. THE APPARATUS SHOWN IN THE DRAWING IS COVERED BY PATENTS.</small>		THIS DWG. SUPERSEDES DWG. N° BH0233A-01-15-Rev01	REV. 1

File name: