


LIMITE DI FORNITURA

CLIENTE IFS s.r.l.



- NOTE:**
- 1- LOCATE GLOBE VALVES AT GRADE AND AWAY FROM SULFUR PIT
 - 2- ALL STEAM AND CONDENSATE PIPING WITHIN THE PIT ARE TO BE STAINLESS STEEL. PIPE SPEC BREAKS OCCUR AT THE PIT COVERS.
 - 3-LOCATE PUMP START-STOP BUTTONS AT GRADE
 - 4- TIE-IN POINT TO BE LOCATED AT EXISTING SULFUR STORAGE TANK AREA
 - 5- HV 01/02 WILL BE FAILURE CLOSE WITH MANUAL OVERRIDE SULFUR STORAGE TANK AREA
 - 6- HV 01/02 MUST BE LOCATED AT SAFE DISTANCE FROM THE SULFUR PIT

* ALL CONDENSATE FROM THE SULFUR STORAGE UNIT WILL BE SENT TO WATER RECOVERY OR LOST

Portovesme S.r.l. STABILIMENTO DI PORTOVESME
 Ufficio Tecnico
 ITEM: 42-W-801 DISEGNO N. 428-WF-01-05
 FILE: 428-WF-01-05 REV-01 (P&ID-SULFUR STORAGE AND USE).dwg

| REV. | DESCRIPTION | DESIGNED | CHECKED | APPROVED | DATE |
|------|-------------------------------------|----------|------------|----------|----------|
| 1 | INSERITO NUMERAZIONE STRUMENTAZIONE | Muscheri | Deru | Longu | 13.08.12 |
| 0 | PRELIMINARY ISSUE | Tocco | Bartolucci | Lovregio | 1.08.12 |

| | | |
|-----------------------------|------------------------|------|
| CUSTOMER | DWG. | REV. |
| LOCALITY | 1112.10.001A | 0 |
| JOB | 1112 | |
| PLANT | SULFUR STORAGE UNIT | |
| SHEET | 1 | 2 |
| FILE DWG | SULFUR STORAGE AND USE | |
| PIPING & INSTRUMENT DIAGRAM | | |

WE RESERVE THE OWNERSHIP UNDER THE LAW OF THIS DRAWING WITH PROHIBITION OF ANY PARTIAL REPRODUCTION AND TO MAKE IT KNOWN PERSONS WITH OUR WRITTEN AUTHORIZATION