

Dal 01/03/2009 Al 31/03/2009 744 ore
 Dati: Riconciliati

RILEVAZIONE CONSUMI COMBUSTIBILE - RAFFINERIA

Impianto	Carica	Consumi totali	Fuel Gas				Fuel Oil			
	tonnellate		tag cpp	tonnellate	% su totale	densità	tag cpp	tonnellate	% su totale	D15
T1	513.804	7.027	T1FC124	1.682	5,1	0,660	T1FC125	5.006	30,0	0,955
T2	509.301	5.909	T2FRC59	2.183	6,6	0,660	T2FRC58	3.299	19,8	0,955
RT2	257.819	3.201	R2FR27A	2.666	8,1	0,660	R2FRC80	32	0,2	0,955
V1	170.822	2.484	V1FRC34	1.710	5,2	0,660				
			V1NFR33	404	1,2	0,660				
V2	233.060	1.577	V1FRC35	948	2,9	0,660				
			V1NFR34	404	1,2	0,660				
VSB	158.580	2.320	R1FC137B	654	2,0	0,660	FOVSBF102C			
			R1FC188	655	2,0	0,660	FOVSBF102B	-	-	0,955
			R1FC189	642	1,9	0,660				
ALKY	25.642	1.117	A1FRC16	940	2,9	0,660				
FCC-K1F3	388.648	1.902	K1FR26	1.600	4,9	0,660				
CO-BO	87.831	3.492	K1FRC704	2.937	8,9	0,660				
CCR	120.715	8.953	CCRFR40	5.206	15,8	0,660				
			CCRFR70	1.303	4,0	0,660				
			CCRFR71	1.058	3,2	0,660				
MHC1 -F101	251.193	622	HFI021	523	1,6	0,660				
MHC1/2 - F251	231.929	1.300	HFI441	1.095	3,3	0,660				
MHC2-F201	243.992	402	H2FT008	338	1,0	0,660				
U300	50.373	528	U3FRC307	444	1,3	0,660				
U400	98.147	535	U4FRC407	450	1,4	0,660				
U500	51.502	405	U5FRC513	340	1,0	0,660				
U700	92.582	570	U7FRC709	479	1,5	0,660				
Z3F2		82	Z3FT114A	69	0,2	0,660				
Z4F2		33	Z4FT214A	27	0,1	0,660				
B1A	41.716	2.938	FIC4	326	1,0	0,660	FIC5	2.539	15,2	0,955
B1B	79.417	3.725	FIC104	1.369	4,2	0,660	FIC105	2.088	12,5	0,955
B1C	79.417	5.850	FIC204	1.783	5,4	0,660	FIC205	3.718	22,3	0,955
U800	75.442	869	U8FIC402	418	1,3	0,660				
			U8FIC502	314	1,0	0,660				

TOTALI				32967	98			16682	100	
--------	--	--	--	-------	----	--	--	-------	-----	--

FCC - Rigenerazione catalizzatore		
Carica	d15°c	0,8759
	S %p.	0,090
Coke	tonnellate	15.402,90