

Dal 01/09/2009 Al 30/09/2009 720 ore
 Dati: Riconciliati

RILEVAZIONE CONSUMI COMBUSTIBILE - RAFFINERIA

Impianto	Carica	Consumi totali	Fuel Gas				Fuel Oil			
	tonnellate	foeton	tag cpp	tonnellate	% su totale	densità	tag cpp	tonnellate	% su totale	D15
T1	462.513	5.630	T1FC124	1.969	7,6	0,657	T1FC125	3.200	16,9	1,080
T2	454.284	5.133	T2FRC59	1.570	6,0	0,657	T2FRC58	3.181	16,8	1,080
RT2	250.551	3.488	R2FR27A	2.779	10,7	0,657	R2FRC80	162	0,9	1,080
V1	151.242	1.832	V1FRC34	1.188	4,6	0,657				
			V1NFR33	228	0,9	0,657				
			V1NFR35	130	0,5	0,657				
V2	196.392	1.238	V1FRC35	736	2,8	0,657				
			V1NFR34	197	0,8	0,657				
			V1NFR35	115	0,4	0,657				
VSB	10.239	126	R1FC137B	43	0,2	0,657	FOVSBF102C	-	-	1,080
			R1FC188	26	0,1	0,657	FOVSBF102B			
			R1FC189	36	0,1	0,657				
ALKY	21.092	960	A1FRC16	803	3,1	0,657				
FCC-K1F3	301.394	2.538	K1FR26	2.123	8,2	0,657				
CO-BO	64.633	3.049	K1FRC704	2.548	9,8	0,657				
CCR	93.783	7.436	CCRFR40	4.389	16,9	0,657				
			CCRFR70	1.814	7,0	0,657				
			CCRFR71	421	1,6	0,657				
MHC1 -F101	190.247	432	HFIC021	361	1,4	0,657				
MHC1/2 - F251	126.188	956	HFI441	801	3,1	0,657				
MHC2-F201	115.740	387	H2FT008	324	1,2	0,657				
U300	51.535	747	U3FRC307	625	2,4	0,657				
U400	85.031	615	U4FRC407	515	2,0	0,657				
U500	47.050	472	U5FRC513	394	1,5	0,657				
U700	85.125	664	U7FRC709	555	2,1	0,657				
Z3F2		42	Z3FT114A	35	0,1	0,657				
Z4F2		32	Z4FT214A	27	0,1	0,657				
B1A	46.044	4.070	FIC4	-	-	0,657	FIC5	3.979	21,1	1,080
B1B	72.835	4.005	FIC104	69	0,3	0,657	FIC105	3.834	20,3	1,080
B1C	72.835	5.620	FIC204	811	3,1	0,657	FIC205	4.544	24,0	1,080
U800	51.850	423	U8FIC402	230	0,9	0,657				
			U8FIC502	124	0,5	0,657				
TOTALI										
				25984	99			18900	100	

FCC - Rigenerazione catalizzatore		
Carica	d15°C	0,8720
	S %p.	0,115
Coke	tonnellate	11.532,84