

Edison spa - CTE Marghera Azotati
TG1

Medie orarie del 15 aprile 2013

	NOx (mg/Nm3)	ID%	CO (mg/Nm3)	ID%	O2 (%)	ID%	Polenza Elettrica (MW)	ID%	Temperatura lumi (°C)	ID%	Pressione lumi (mbar)	ID%	Portata Gas (Sm3/h)	ID%	NOx Totale Quale (mg/Nm3)	CO Totale Quale (mg/Nm3)
01.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
02.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
03.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
04.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
05.00	*	10%	*	10%	*	10%	*	100%	*	10%	*	10%	*	100%	*	*
06.00	44	98.3%	2	98.3%	13.9	98.3%	69.2	98.3%	377.2	98.3%	1021.6	98.3%	17436.1	98.3%	52	3
07.00	48	100%	1	100%	13.7	100%	79.9	100%	387.2	100%	1021.3	100%	19476.4	100%	58	1
08.00	47	100%	2	100%	14.1	100%	56.8	100%	266.3	100%	1024.5	100%	15022.5	100%	54	2
09.00	47	95%	2	95%	14.8	95%	31.7	100%	138.5	100%	1027.4	100%	10098.9	100%	48	2
10.00	N.D.	0%	N.D.	0%	N.D.	0%	*	100%	*	8.3%	*	8.3%	*	100%	N.D.	N.D.
11.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
12.00	F	1.7%	F	1.7%	F	1.7%	F	100%	F	1.7%	F	1.7%	F	100%	*	*
13.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
14.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
15.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
16.00	F	0%	F	0%	F	0%	F	98.3%	F	0%	F	0%	F	98.3%	N.D.	N.D.
17.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
18.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
19.00	*	10%	*	10%	*	10%	*	100%	*	10%	*	10%	*	100%	*	*
20.00	48	100%	10	100%	13.1	100%	102.7	100%	383.5	100%	1017.6	100%	24022.6	100%	63	14
21.00	*	10%	*	10%	*	10%	*	100%	*	10%	*	10%	*	100%	*	*
22.00	F	1.7%	F	1.7%	F	1.7%	F	100%	F	0%	F	0%	F	100%	*	*
23.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
24.00	F	0%	F	0%	F	0%	F	100%	F	0%	F	0%	F	100%	N.D.	N.D.
Min	44		1		13.1		31.7		138.5		1017.6		10098.9		48	1
Max	48		10		14.8		102.7		383.5		1027.4		24022.6		63	14
Limite	50		30													
Nr Sup.	0		0													
24H	n.c.	100%	n.c.	100%	n.c.	100%	n.c.	100%	n.c.	100%	n.c.	100%	n.c.	100%	n.c.	n.c.
Ore valide	5		5		5		5		5		5		5		5	5

Media oraria: % Validazione = 70%
Media giornaliera: % Validazione = 70%

Edison spa - CTE Marghera Azotati
TG2

Medie orarie del 15 aprile 2013

	NOx (mg/Nm3)	ID%	CO (mg/Nm3)	ID%	O2 (%)	ID%	Potenza Elettrica (MW)	ID%	Temperatura (um)	ID%	Pressione (um)	ID%	Portata Gas (Sm3/h)	ID%	NOx Totale Quale (mg/Nm3)	CO Totale Quale (mg/Nm3)
01.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
02.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
03.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
04.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
05.00	*	8,3%	*	8,3%	*	8,3%	*	8,3%	*	8,3%	*	8,3%	*	8,3%	*	*
06.00	45	98,3%	11	98,3%	13,6	98,3%	69,6	98,3%	402,9	98,3%	1020,8	98,3%	18074,9	98,3%	56	14
07.00	47	100%	6	100%	13,4	100%	80,3	100%	403,8	100%	1020,9	100%	20170,7	100%	59	7
08.00	47	100%	2	100%	13,8	100%	57,1	100%	402,2	100%	1021,3	100%	15526,6	100%	56	2
09.00	48	100%	2	100%	14,7	100%	31,9	100%	215,3	100%	1019,2	100%	10414,6	100%	50	2
10.00	*	8,3%	*	8,3%	*	8,3%	*	8,3%	*	8,3%	*	8,3%	*	8,3%	*	*
11.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
12.00	F	0%	F	1,7%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	*
13.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
14.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
15.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
16.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
17.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
18.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
19.00	*	10%	*	10%	*	10%	*	10%	*	10%	*	10%	*	10%	*	*
20.00	48	100%	15	100%	12,9	100%	103,1	100%	405,2	100%	1017,6	100%	24686,7	100%	64	20
21.00	*	10%	*	10%	*	10%	*	10%	*	10%	*	10%	*	10%	*	*
22.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
23.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
24.00	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	F	0%	N.D.	N.D.
Min	45		2		12,9		31,9		215,3		1017,6		10414,6		50	2
Max	48		15		14,7		103,1		405,2		1021,3		24686,7		64	20
Limite	50		30													
Nr Sup.	0		0													
24H	n.c.	100%	n.c.	100%	n.c.	100%	n.c.	100%	n.c.	100%	n.c.	100%	n.c.	100%	n.c.	n.c.
Ore valide	5		5		5		5		5		5		5		5	5

Media oraria: % Validazione = 70%
Media giornaliera: % Validazione = 70%