

ALLEGATO 2 - ELENCO APPARECCHIATURE REFRIGERANTI

Luogo	KKS	Marca	Tipo	Matricola	Tipo refrigerante	Quantita refrigerante (kg)	MP48-6M	MP48-1A
Cabinato CEMS	11SAZ01AH001	Carrier	Xpower	82301019	R410A	0.8	5192	5145
Cabinato CEMS	11SAZ01AH002	Carrier	Xpower	82301289	R410A	0.8	5193	5146
Cabinato GVA	11SAZ01AH003	Mitsubishi	MUZ-GC35VA	8019361T	R410A	0.85	5194	5147
Cabinato GVA	11SAZ01AH004	Mitsubishi	MUZ-GC35VA	8006500T	R410A	0.85	5195	5148
Cabinato riduzione gas	11SAZ01AH005	Toyotomi	TAG-A32GW		R410A	1.1	5196	5149
Cabinato riduzione gas	11SAZ01AH006	Toyotomi	TAG-A32GW	G32A083F14	R410A	1.1	5197	5150
Cabinato banco campionamento HRSG	11SAZ01AH007	Maxa	Monoblocco			<3	5198	5151
Cabinato banco campionamento HRSG	11SAZ01AH008	Maxa	Monoblocco			<3	5199	5152
Cabina gas PMC	11SAZ01AH009	ARGO	AE64AH3	3600269857	R410A	2.04	5200	5153
Cabina gas PMC	11SAZ01AH010	ARGO	AE64AH4	3600269858	R410A	2.04	5201	5154
Uffici	11SAV01AH003	Pielle	URC 10-06Pa	06i292131	R407c	2.4	5202	5155
Uffici	11SAV01AH000	LG	Multi V Plus II ARUN100LT2	908KANY00023	R410A	8	5203	5156
Uffici switchgear room	11SAT01AH004	LG	UU36W	911KAYR00058	R410A	2.5	5204	5157
Uffici switchgear room	11SAT01AH005	LG	UU36W	911KAPB00056	R410A	2.5	5205	5158
Infermeria	11SAX01AH001	LG	UU24W	...Y00319	R410A	2	5206	5159
Infermeria	11SAX01AH002	LG	UU24W	...AED00316	R410A	2	5207	5160
Infermeria	11SAX01AH201	Pielle	URC 06-06Pa		Assente			
Sala elettrica condensatore	11SAS01AH001	LG	UU24W	912KAAE00320	R410A	2	5208	5161
Sala elettrica condensatore	11SAS01AH002	LG	UU24W	912KADT00410	R410A	2	5209	5162
Sala elettrica HRSG	11SAH01AH001	LG	UU24W	911KABF00005	R410A	2	5210	5163
Sala elettrica HRSG	11SAH01AH002	LG	UU24W	912KAKN00317	R410A	2	5211	5164
ZLD AUX electronic room 2	11SAG01AH001	LG	UU24W	912KADT00314	R410A	2	5212	5165
ZLD AUX electronic room 2	11SAG01AH002	LG	UU24W	912KANY00415	R410A	2	5213	5166
ZLD AUX switchgear room 2	11SAG01AH003	LG	UU24W	912KAXV00418	R410A	2	5214	5167
ZLD AUX switchgear room 2	11SAG01AH004	LG	UU24W	911KAXV00002	R410A	2	5215	5168
ZLD electronic room 1	11SAG01AH005	LG	UU18W	911KASL00182	R410A	1.3	5216	5169
ZLD electronic room 1	11SAG01AH006	LG	UU18W	911KACA00227	R410A	1.3	5217	5170
ZLD switchgear room 1	11SAG01AH007	LG	UU18W	911KACA00179	R410A	1.3	5218	5171
ZLD switchgear room 1	11SAG01AH008	LG	UU18W	911KAQJ00180	R410A	1.3	5219	5172
Chiller VFD	11SAC01CK001	Daikin	EUWAB16KAZW1	2900647	R407c	4,6 + 4,6	5220	5173
Chiller VFD	11SAC01CK002	Daikin	EUWAB16KAZW1	3900723	R407c	4,6 + 4,6	5221	5174
Cabinato polishing system	11SAZ01AH011	Syntec	SKWT0902FHP7 (Monoblocco)	N3813426	R407c	0,6	5222	5175
Chiller cristallizzatore con compressore Danfoss	11GN*04GH002	Emicon	RAE151.PS.K	09H022	R407c	3.5	5223	5176
Sala Server mono split	11SAV01AH004	Daikin	RR71B2W1B	J003697	R410A	2,7	5224	5177
Sala Server dual split	11SAV01AH005	Daikin	RR125B8W1B	3213982	R410A	3,7	5225	5178
Sala Server dual split	11SAV01AH006	Daikin	RR125B8W1B	3213980	R410A	3,7	5226	5179
Control Room	11SAV01AH001	Trane	WKH265	R976855	R407c	8,6 + 8,6	5227	5180
Control Room	11SAV01AH002	Trane	WKH265	R976857	R407c	8,6 + 8,6	5228	5181
Sala elettrica principale electronic room	11SAC01AH001	Trane	WKH200	R976824	R407c	9+9	5229	5182
Sala elettrica principale electronic room	11SAC01AH002	Trane	WKH200	R976828	R407c	9+9	5230	5183
Sala elettrica principale switchgear room	11SAC01AH003	Trane	WKH265	R976879	R407c	8,6 + 8,6	5231	5184
Sala elettrica principale switchgear room	11SAC01AH004	Trane	WKH265	R976881	R407c	8,6 + 8,6	5232	5185
Sala elettrica condensatore	11SAS01AH003	Trane	WSH90	R936847	R407c	5.7	5233	5186
Sala elettrica condensatore	11SAS01AH004	Trane	WSH90	R936815	R407c	5.7	5234	5187
Sala elettrica HRSG	11SAH01AH003	Trane	WSH90	R936816	R407c	5.7	5235	5188
Sala elettrica HRSG	11SAH01AH004	Trane	WSH90	R936814	R407c	5.7	5236	5189
Cabinato spogliatoio ditte esterne	11SAZ01AH012		Monoblocco		R407c	0,94	5237	5190
Cabinato spogliatoio ditte esterne	11SAZ01AH013		Monoblocco		R407c	0,94	5238	5191