

EMISSIONI IN CONTINUO Settembre 2014

Camino	48		
	H2SO4		
Analizzatore	Ossidi di Azoto C48		
	OSSIDI AZOTO		
	mg/Nm3		
Giorno	Valore Medio	IV %	IF %
1	93,44	100	100
2	62,13	100	100
3	43,83	100	79
4	42,96	100	50
5	32,13	100	50
6	70,41	100	45
7	76,85 (AS)	16	95
8	117,51 (AS)	58	100
9	98,66	95	100
10	83,73	100	87
11	96,99	100	95
12	109,35 (FL)	100	100
13	78,9	100	100
14	105,93 (FL)	100	100
15	95,9	100	100
16	107,85 (FL)	95	100
17	65,04	100	54
18	48,07 (TF)	100	0
19	51,95 (TF)	91	0
20	39,67 (TF)	100	0
21	36,84 (TF)	100	0
22	44,13 (TF)	100	0
23	77,48	95	41
24	72,87	100	100
25	63,68	100	100
26	58,27	100	87
27	61,52	100	100
28	61,52	100	100
29	27,32	100	37
30	30,23 (TF)	100	0
Max	117,51	100	100
Min	27,32	16	0
Media	68,22	93	80
Limite giornaliera	100		