

EMISSIONI IN CONTINUO Agosto 2014

Camino	53P		
	PRINCIPALE KIVCET		
Analizzatore	Anidride Solforosa C53P		
	SO2		
	mg/Nm3		
Giorno	Valore Medio	IV %	IF %
1	42,90 (FL)	100	100
2	41,09 (FL)	100	100
3	37,98 (FL)	100	95
4	29,2	100	91
5	34,53	100	91
6	45,33 (FL)	100	95
7	43,46 (FL)	100	70
8	74,27 (FL)	100	29
9	62,85 (FL)	100	66
10	79,75 (TF)	100	16
11	70,61 (FL)	100	95
12	78,52 (FL)	95	91
13	79,76 (FL)	95	70
14	79,76 (FL)	100	95
15	79,64 (FL)	100	95
16	79,76 (FL)	100	75
17	79,05 (FL)	100	75
18	78,51 (FL)	100	91
19	79,76 (FL)	87	83
20	79,76 (FL)	100	25
21	79,76 (FL)	100	100
22	74,37 (FL)	87	83
23	63,79 (FL)	100	100
24	50,85 (FL)	95	91
25	53,51 (AS)	33	33
26	61,76 (FL)	100	91
27	75,58 (FL)	100	33
28	79,76 (FL)	100	58
29	146,53 (FL)	100	70
30	186,57 (FL)	100	95
31	75,02 (FL)	100	95
Max	186,57	100	100
Min	29,2	33	16
Media	72,44 (FL)	97	94
Limite giornaliera	35		