

EMISSIONI IN CONTINUO Gennaio 2017

| Camino | 48 | | | 53P | | |
|--------------------|---------------------|------|------|-------------------------|------|------|
| | H2SO4 | | | PRINCIPALE KIVCET | | |
| Analizzatore | Ossidi di Azoto C48 | | | Anidride Solforosa C53P | | |
| | NOx | | | SO2 | | |
| | mg/Nm3 | | | mg/Nm3 | | |
| Giorno | Valore Medio | IV % | IF % | Valore Medio | IV % | IF % |
| 6 | 28,13 | 100 | 100 | 622,10 (FL) | 100 | 92 |
| 7 | 23,01 | 100 | 100 | 18,29 | 100 | 96 |
| 8 | 34,59 | 100 | 75 | 79,25 | 100 | 92 |
| 9 | 46,11 | 95 | 96 | 146,26 | 100 | 100 |
| 10 | 46,13 | 100 | 100 | 56,67 | 100 | 100 |
| 11 | 50,4 | 100 | 100 | 25,29 | 100 | 100 |
| 12 | 54,88 | 100 | 100 | 23,09 | 100 | 100 |
| 13 | 58,39 | 100 | 100 | 18 | 100 | 100 |
| 14 | 41,72 | 100 | 75 | 49,22 | 100 | 88 |
| 15 | 42,17 | 100 | 63 | 257,69 (FL) | 100 | 83 |
| 16 | 51,74 (TF) | 100 | 17 | 730,29 (AS) | 45 | 38 |
| 17 | 63,4 | 100 | 100 | 152,13 | 91 | 92 |
| 18 | 51,35 | 100 | 96 | 34,73 | 100 | 92 |
| 19 | 42,52 | 100 | 92 | 126,71 | 100 | 75 |
| 20 | 59,1 | 100 | 100 | 248,65 (FL) | 91 | 100 |
| 21 | 61,96 | 100 | 96 | 228,27 (FL) | 100 | 96 |
| 22 | 46,93 | 100 | 100 | 388,26 (FL) | 100 | 100 |
| 23 | 44,22 | 100 | 67 | 643,77 (FL) | 100 | 71 |
| 24 | 45,53 | 100 | 67 | 821,96 (FL) | 91 | 46 |
| 25 | 53,94 | 100 | 88 | 760,14 (FL) | 83 | 58 |
| 26 | 58,5 | 95 | 100 | 705,50 (FL) | 100 | 96 |
| 27 | 31,25 | 100 | 92 | 991,08 (AS) | 29 | 13 |
| 28 | 48,55 | 100 | 100 | 396,70 (FL) | 100 | 100 |
| 29 | 37,1 | 100 | 100 | 385,55 (FL) | 100 | 100 |
| 30 | 34,8 | 100 | 100 | 396,73 (FL) | 100 | 96 |
| 31 | 33,22 | 100 | 100 | 316,02 (FL) | 95 | 96 |
| Max | 63,4 | 100 | 100 | 991,08 | 100 | 100 |
| Min | 23,01 | 95 | 16 | 18 | 29 | 12 |
| Media | 45,76 | 100 | 96 | 331,63 (FL) | 92 | 96 |
| Limite giornaliera | 100 | | | 200 | | |