



Sostituisce dis. FU-A-E2
FU-A-V4
CTN 524291
A: FASE CENTRALE 7000/5A-100VA-510
NOTE:
1) ...
2) ...
3) ...

CENTRALE DI FUSINA Gr 1-2																																		
12	29/05/12	B.S.	B.S.	B.S.	ELE	Modifica trasf. TAA																												
12	30/07/09	Eno	Eno	2NO	REG	SEATTO SEQUENZIALE																												
11	23/12/08	Eno			REG	Inserito OSCILLO																												
10	27/02/07	Eno			REG	Sost.TA TV e BIL																												
9	31/08/05	sf			Vn	PrgrM Agg. Dati Transform.																												
8	16/04/04	sf			Vn	PrgrM mod. Lines Ingr 20KV																												
EDIC.	DATA	DIS.	CONTR.	STATO	UFF.	NOTE	SOST. N°	EDIZ. 6	TIFF	FOGLIO N° 1																								
<table border="1"> <tr> <td>FORMATO</td> <td>AO</td> <td>SCALA</td> <td>1</td> <td>FILE N°</td> <td>PTT419B</td> <td>DIS. N°</td> <td>PT/1419B</td> </tr> <tr> <td>FS</td> <td>1</td> <td>26</td> <td>BE</td> <td></td> <td></td> <td>DEI</td> <td>ENEVE</td> </tr> <tr> <td>ENTRALE</td> <td>SEZ.</td> <td>SI.</td> <td>U.F.</td> <td>SP</td> <td>U.E.</td> <td>CODICE "SAP"</td> <td>TPD DOC</td> <td>ESECUTORE</td> </tr> </table>										FORMATO	AO	SCALA	1	FILE N°	PTT419B	DIS. N°	PT/1419B	FS	1	26	BE			DEI	ENEVE	ENTRALE	SEZ.	SI.	U.F.	SP	U.E.	CODICE "SAP"	TPD DOC	ESECUTORE
FORMATO	AO	SCALA	1	FILE N°	PTT419B	DIS. N°	PT/1419B																											
FS	1	26	BE			DEI	ENEVE																											
ENTRALE	SEZ.	SI.	U.F.	SP	U.E.	CODICE "SAP"	TPD DOC	ESECUTORE																										

SCHEMA UNIFILARE GENERALE
MISURE E PROTEZIONI

RIF. all' ALLEGATO AE 2/2