

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00						34		
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						34		
#####	07:00						31		
#####	08:00	13.8	96.1	1000.7	1478547		30 21.7	6.8	21.6
#####	09:00	13.8	94.1	1001.0	1381620		30 20.9	0.3	21.2
#####	10:00	14.1	90.3	1001.5	1539904		30 20.5	1.9	21.0
#####	11:00	14.3	86.1	1002.2	1015350		30 20.6	2.6	21.0
#####	12:00	14.2	89.6	1002.4	888149		30 20.8	1.9	21.2
#####	13:00	14.1	91.2	1002.1	1209954		30 21.3	1.6	21.7
#####	14:00	14.1	90.2	1002.1	1378174		30 21.2	1.6	21.6
#####	15:00	14.2	92.1	1001.9	1466750		30 21.3	1.5	21.7
#####	16:00	14.1	89.0	1002.0	1315696		30 20.6	1.8	21.0
#####	17:00	14.2	91.8	1002.1	1737796		30 21.3	1.8	21.7
#####	18:00	13.7	94.0	1002.7	1861022		30 19.6	0.6	20.0
#####	19:00	13.7	94.5	1003.0	1819222		30 19.2	0.3	19.6
#####	20:00	13.7	94.3	1003.4	1886013		30 19.3	0.4	19.7
#####	21:00	13.7	93.0	1004.1	1918750		30 18.5	0.8	18.9
#####	22:00	13.9	91.8	1004.7	1507692		30 20.3	1.9	20.7
#####	23:00	13.8	93.0	1004.5	1806169		30 19.6	1.9	20.0
#####	24:00:00	13.9	90.4	1004.4	1924121		30 19.8	2.5	20.3

CO
mg/Nm³

0.8
0.7
3.9
5.2
3.8
3.2
3.2
3.1
3.8
3.8
1.3
0.8
0.8
1.7
3.8
4.0
5.1