

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00					34			
#####	02:00					34			
#####	03:00					34			
#####	04:00					34			
#####	05:00					34			
#####	06:00					31			
#####	07:00					31			
#####	08:00	14.6	95.3	1028.2	605775	30	22.7	2.0	23.1
#####	09:00	14.6	90.2	1028.2	898607	30	22.3	3.1	22.7
#####	10:00	14.6	89.4	1028.6	993936	30	21.8	3.1	22.3
#####	11:00	14.6	89.5	1028.6	646840	30	21.9	2.7	22.4
#####	12:00	14.7	89.4	1027.9	468346	30	21.8	2.4	22.3
#####	13:00	14.7	89.3	1027.0	497247	30	22.1	2.3	22.6
#####	14:00	14.7	88.9	1026.2	631944	30	21.7	2.2	22.2
#####	15:00	14.7	88.9	1025.8	608897	30	21.9	2.2	22.4
#####	16:00	14.3	92.5	1025.4	1072371	30	20.3	1.4	20.8
#####	17:00	14.3	94.5	1025.5	1706606	30	20.8	0.7	21.3
#####	18:00	13.9	96.9	1025.5	2038988	30	18.1	0.2	18.6
#####	19:00	13.9	96.6	1025.8	1928507	30	18.5	0.2	19.0
#####	20:00	13.8	96.4	1025.7	1884808	30	18.7	0.2	19.2
#####	21:00	13.8	96.2	1025.7	1866094	30	18.7	0.3	19.2
#####	22:00	13.9	94.9	1026.0	1534447	30	19.4	0.3	19.9
#####	23:00	14.0	95.0	1026.0	1549043	30	20.1	0.3	20.5
#####	24:00:00	13.8	97.0	1025.9	1670631	30	19.0	0.3	19.4

CO
mg/Nm³

4.2
6.3
6.3
5.5
4.9
4.6
4.5
4.4
2.8
1.5
0.6
0.6
0.6
0.8
0.8
0.8
0.8