

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00						34		
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	14.2	99.2	1011.0	1209170		30 22.1	0.6	22.4
#####	08:00	14.1	101.6	1010.9	1740823		30 20.2	0.3	20.7
#####	09:00	14.3	99.7	1011.1	1180401		30 22.6	0.5	23.0
#####	10:00	14.0	103.4	1010.9	1561737		30 20.5	0.3	20.9
#####	11:00	14.1	105.7	1010.9	1580405		30 19.9	0.3	20.3
#####	12:00	14.0	105.6	1011.0	1797566		30 19.6	0.3	20.1
#####	13:00	14.0	107.3	1010.8	1517890		30 19.6	0.3	20.1
#####	14:00	14.0	107.7	1010.5	1805068		30 19.6	0.3	20.1
#####	15:00	14.0	108.1	1009.8	1664882		30 19.5	0.3	20.0
#####	16:00		108.2	1009.4			30		
#####	17:00		108.0	1009.4			30		
#####	18:00	14.1	108.7	1009.5	1843205		30 19.8	0.2	20.3
#####	19:00	14.1	107.8	1009.4	1702963		30 19.8	0.2	20.2
#####	20:00	14.0	107.5	1010.1	1863649		30 19.9	0.2	20.4
#####	21:00	14.0	105.9	1010.7	1864748		30 19.9	0.2	20.4
#####	22:00	14.1	104.9	1011.4	1967756		30 20.1	0.2	20.5
#####	23:00	14.2	103.3	1011.6	1364275		30 22.1	0.2	22.5
#####	24:00:00	14.1	104.1	1011.1	1657793		30 20.9	0.2	21.3

CO  
mg/Nm3

1.2  
0.7  
1.0  
0.7  
0.6  
0.7  
0.6  
0.6  
0.6

0.5  
0.5  
0.4  
0.4  
0.4  
0.5  
0.4