

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00						34		
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	13.8	94.8	1014.1	1671523		30 21.1	15.8	20.8
#####	08:00	13.8	94.9	1014.0	1724647		30 19.9	0.3	20.3
#####	09:00	13.8	96.5	1013.8	1322930		30 19.1	0.3	19.6
#####	10:00	13.7	98.8	1013.4	1581651		30 18.2	0.4	18.7
#####	11:00	13.9	95.4	1013.6	1781079		30 19.1	1.1	19.5
#####	12:00	13.6	99.9	1013.2	1656400		30 17.7	0.3	18.2
#####	13:00	13.6	102.3	1012.4	1627740		30 17.5	0.3	18.0
#####	14:00	14.2	97.1	1011.8	1121136		30 19.1	1.4	19.7
#####	15:00	14.4	91.8	1011.3	793554		30 20.4	2.1	20.9
#####	16:00	14.4	91.2	1010.7	755295		30 20.5	2.1	21.1
#####	17:00	14.3	92.5	1009.9	705639		30 20.7	1.7	21.2
#####	18:00	13.8	102.7	1009.2	1463433		30 18.1	0.2	18.6
#####	19:00	13.5	102.1	1008.8	1916748		30 17.5	0.2	18.0
#####	20:00	13.6	100.5	1008.9	1919001		30 17.3	0.2	17.8
#####	21:00	13.6	100.0	1009.2	1920120		30 17.4	0.3	17.9
#####	22:00	13.6	99.1	1009.3	1921219		30 17.4	0.3	17.9
#####	23:00	13.8	98.2	1009.0	1926346		30 17.7	0.3	18.3
#####	24:00:00	13.7	98.1	1008.6	1926502		30 18.2	0.3	18.7

CO
mg/Nm³

0.8
0.8
0.7
0.8
2.3
0.6
0.6
3.0
4.4
4.3
3.4
0.6
0.6
0.6
0.6
0.6
0.7
0.7