

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00						34		
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	14.1	95.0	1014.0	1886798		30 22.5	5.2	22.4
#####	08:00	14.2	91.8	1014.4	1299309		30 21.2	1.6	21.6
#####	09:00	14.2	90.0	1014.5	909151		30 20.9	1.7	21.3
#####	10:00	14.4	88.4	1014.6	1085061		30 21.6	2.4	22.0
#####	11:00	14.3	90.2	1014.7	1614126		30 20.9	2.1	21.4
#####	12:00	14.3	88.9	1014.9	1715096		30 20.8	2.3	21.3
#####	13:00	14.5	87.7	1014.6	1282557		30 21.5	2.7	22.0
#####	14:00	14.5	87.9	1014.1	847083		30 21.5	2.2	22.0
#####	15:00	14.5	87.8	1013.8	502447		30 21.5	2.1	22.0
#####	16:00	14.3	87.7	1013.5	523741		30 20.2	3.1	20.7
#####	17:00	14.4	87.3	1013.5	887283		30 21.7	2.2	22.2
#####	18:00	14.4	87.2	1013.9	1557928		30 21.2	2.5	21.7
#####	19:00	14.2	92.1	1013.7	1007594		30 21.0	1.6	21.5
#####	20:00	13.8	96.1	1013.6	1883082		30 18.9	0.3	19.4
#####	21:00	13.7	97.4	1014.0	1939631		30 17.3	0.3	17.9
#####	22:00	13.7	97.2	1014.9	1892329		30 17.5	0.2	18.1
#####	23:00	13.8	95.7	1015.3	1660586		30 18.6	0.3	19.1
#####	24:00:00	13.8	95.8	1015.3	1919225		30 18.3	0.3	18.8

CO
mg/Nm3

1.6
3.3
3.5
4.9
4.3
4.6
5.5
4.5
4.3
6.3
4.6
5.1
3.3
0.6
0.6
0.6
0.6
0.6