

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.0	102.9	1010.9	1762117		30 20.1	0.3	20.5
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						34		
#####	07:00						31		
#####	08:00	14.2	101.1	1010.5	1544936		30 21.3	0.5	21.7
#####	09:00	14.3	101.8	1010.5	1184366		30 20.8	0.3	21.3
#####	10:00	14.1	104.2	1010.3	1566553		30 18.9	0.3	19.4
#####	11:00		105.6	1010.5			30		
#####	12:00	14.1	106.2	1010.4	1597462		30 18.4	0.3	19.0
#####	13:00	14.2	107.1	1010.1	1497768		30 18.4	0.3	19.0
#####	14:00	14.2	108.6	1009.4	1646750		30 19.1	0.3	19.6
#####	15:00	14.2	109.7	1009.1	1721825		30 19.4	0.3	19.9
#####	16:00	14.3	109.6	1009.0	1690040		30 19.3	0.3	19.9
#####	17:00	14.2	109.2	1008.9	1651076		30 19.2	0.3	19.8
#####	18:00	14.2	109.9	1008.9	1721525		30 19.2	0.3	19.8
#####	19:00	14.1	109.5	1008.9	1707480		30 19.2	0.3	19.7
#####	20:00	14.2	107.8	1009.1	1744436		30 20.0	0.3	20.5
#####	21:00	14.0	106.6	1009.4	1835956		30 19.7	0.2	20.1
#####	22:00	14.0	105.6	1009.9	1642903		30 19.7	0.2	20.2
#####	23:00	14.2	103.1	1010.2	1430356		30 21.6	0.2	22.0
#####	24:00:00	14.2	103.1	1010.1	1494732		30 21.1	0.2	21.5

CO
mg/Nm3
0.6

1.1
0.7
0.7

0.7
0.7
0.7
0.7
0.6
0.6
0.6
0.6
0.6
0.6
0.6
0.5
0.6
0.6