

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00					34			
#####	02:00					34			
#####	03:00					34			
#####	04:00					34			
#####	05:00					34			
#####	06:00					31			
#####	07:00					31			
#####	08:00	13.7	98.0	1021.6	1565156	30	16.7	0.4	17.3
#####	09:00	13.7	96.7	1022.0	1799564	30	15.8	0.4	16.4
#####	10:00	13.7	96.0	1022.6	1855535	30	15.4	0.4	16.1
#####	11:00	13.7	96.4	1023.0	1698611	30	15.2	0.3	15.9
#####	12:00	14.1	91.7	1023.2	1142165	30	16.0	1.1	16.7
#####	13:00	14.5	84.4	1023.0	603000	30	16.5	3.7	17.3
#####	14:00	14.5	86.1	1022.8	691255	30	16.6	3.7	17.4
#####	15:00	14.4	87.4	1022.7	795511	30	16.7	3.2	17.5
#####	16:00	13.8	97.3	1022.6	1731846	30	15.0	0.3	15.8
#####	17:00	13.8	96.2	1023.6	1861688	30	14.9	0.3	15.6
#####	18:00	13.8	95.4	1024.6	2006014	30	14.8	0.3	15.6
#####	19:00	13.8	95.3	1025.6	2013271	30	14.8	0.3	15.5
#####	20:00	13.8	95.3	1026.2	1975634	30	14.8	0.3	15.5
#####	21:00	13.8	95.1	1026.6	2015879	30	14.8	0.3	15.6
#####	22:00	13.8	95.0	1026.9	1948478	30	14.8	0.3	15.6
#####	23:00	13.8	95.3	1027.4	1745063	30	14.8	0.3	15.5
#####	24:00:00	13.8	95.0	1027.7	1834447	30	14.9	0.3	15.6

CO
mg/Nm3

1.0
0.9
0.9
0.7
2.4
7.4
7.5
6.5
0.6
0.6
0.7
0.7
0.7
0.7
0.7
0.7
0.7