

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	13.8	93.4	1027.1	1922277	30	20.2	0.5	20.6
#####	02:00					34			
#####	03:00					34			
#####	04:00					34			
#####	05:00					34			
#####	06:00					31			
#####	07:00	13.9	96.4	1025.8	1911437	30	21.1	0.5	21.4
#####	08:00	13.7	94.4	1025.9	1914085	30	19.5	0.4	19.9
#####	09:00	13.8	94.7	1026.1	1912607	30	19.4	0.4	19.9
#####	10:00	13.8	95.3	1026.4	1911016	30	19.7	0.4	20.1
#####	11:00	13.8	95.5	1026.6	1913230	30	19.7	0.4	20.1
#####	12:00	14.4	91.2	1026.2	1239789	30	22.7	1.3	23.1
#####	13:00	14.6	86.9	1025.6	505234	30	23.2	2.3	23.6
#####	14:00	14.6	87.8	1024.9	444683	30	23.4	2.1	23.8
#####	15:00	14.1	94.8	1024.3	1411196	30	21.9	0.4	22.2
#####	16:00	13.8	97.6	1024.2	1902885	30	19.4	0.3	19.8
#####	17:00	13.9	95.7	1024.3	1861672	30	19.8	0.4	20.2
#####	18:00	13.8	96.2	1024.3	1910716	30	19.4	0.2	19.8
#####	19:00	13.8	95.9	1024.4	1887106	30	19.4	0.3	19.9
#####	20:00	13.8	95.2	1024.1	1905636	30	19.9	0.3	20.3
#####	21:00	13.8	94.3	1024.0	1910938	30	19.8	0.4	20.2
#####	22:00	13.8	94.7	1023.8	1910621	30	20.0	0.4	20.4
#####	23:00	13.8	94.9	1023.7	1908568	30	20.1	0.4	20.5
#####	24:00:00	13.9	93.3	1024.0	1918983	30	20.8	0.5	21.1

CO
mg/Nm³
1.0

1.1
0.9
0.9
0.8
0.8
2.7
4.6
4.2
1.0
0.7
0.9
0.6
0.6
0.8
0.9
0.9
0.9
1.0