

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00						34		
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	13.9	95.2	1023.4	1844910		30 20.9	0.3	21.2
#####	08:00	13.8	97.5	1023.7	1908275		30 19.3	0.2	19.8
#####	09:00	13.8	97.2	1024.0	1906331		30 19.0	0.2	19.5
#####	10:00	14.0	95.2	1024.3	1582456		30 19.7	0.2	20.1
#####	11:00	14.4	89.9	1024.6	1186657		30 23.0	1.3	23.3
#####	12:00	13.8	96.8	1023.8	1878671		30 19.3	0.2	19.8
#####	13:00	13.7	96.7	1023.0	1641018		30 20.3	0.2	20.6
#####	14:00	14.5	88.5	1023.0	722209		30 21.7	1.7	22.1
#####	15:00	14.6	84.7	1023.0	1034797		30 22.4	1.9	22.9
#####	16:00	13.7	96.9	1022.8	1784002		30 20.5	0.2	20.8
#####	17:00	13.8	97.1	1023.1	1687325		30 18.7	0.2	19.2
#####	18:00	13.8	96.5	1023.3	1794018		30 18.7	0.2	19.2
#####	19:00	14.0	95.0	1023.5	1899910		30 19.2	0.2	19.7
#####	20:00	13.8	96.2	1023.8	1912349		30 18.8	0.3	19.3
#####	21:00	13.9	94.8	1024.2	1904075		30 19.2	0.2	19.6
#####	22:00	13.8	95.6	1024.2	1913095		30 18.9	0.3	19.3
#####	23:00	13.9	94.9	1024.3	1920103		30 19.4	0.3	19.9
#####	24:00:00	13.8	95.0	1024.1	1918310		30 19.5	0.3	19.9

CO
mg/Nm3

0.7
0.5
0.5
0.5
2.7
0.5
0.4
3.5
4.0
0.5
0.5
0.5
0.5
0.6
0.5
0.6
0.6
0.6