

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.1	102.5	1011.6	1879587		30 20.9	0.2	21.3
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	14.1	99.8	1011.6	1719449		30 21.6	0.4	22.0
#####	08:00	14.1	101.9	1011.5	1726468		30 20.0	0.2	20.4
#####	09:00	14.4	99.3	1011.7	1001023		30 22.2	0.4	22.6
#####	10:00	14.0	104.7	1011.5	1577634		30 20.0	0.2	20.4
#####	11:00	14.1	105.4	1011.7	1702729		30 19.6	0.2	20.1
#####	12:00	14.5	100.2	1011.8	1172973		30 20.8	1.3	21.3
#####	13:00	14.8	95.0	1011.6	607906		30 22.2	1.9	22.7
#####	14:00	14.0	103.9	1010.5	1522961		30 20.2	0.3	20.7
#####	15:00	14.0	107.0	1010.2	1652732		30 19.5	0.2	20.0
#####	16:00	14.1	107.9	1010.2	1741280		30 19.3	0.2	19.8
#####	17:00	14.1	107.6	1010.3	1761491		30 19.1	0.2	19.6
#####	18:00	14.1	108.3	1010.4	1857272		30 19.1	0.2	19.6
#####	19:00	14.0	108.2	1009.7	1655642		30 19.0	0.2	19.5
#####	20:00	14.0	107.2	1010.3	1898180		30 19.2	0.2	19.7
#####	21:00	14.0	105.8	1010.8	1887413		30 19.4	0.2	19.8
#####	22:00	14.0	104.8	1010.8	1799010		30 19.6	0.2	20.0
#####	23:00	14.2	103.4	1011.3	1857395		30 21.1	0.2	21.5
#####	24:00:00	14.1	103.3	1011.6	1891587		30 20.7	0.2	21.2

CO
mg/Nm³
0.4

0.9
0.5
1.0
0.5
0.5
2.8
3.9
0.7
0.5
0.5
0.6
0.6
0.6
0.6
0.5
0.5
0.5
0.5