

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00						34		
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						31		
#####	06:00						31		
#####	07:00	14.2	100.9	1013.5	1528541		30 20.9	0.3	21.3
#####	08:00	14.2	101.8	1013.4	1602785		30 19.2	0.2	19.7
#####	09:00	14.3	100.9	1013.9	1933082		30 20.9	0.3	21.3
#####	10:00	14.2	104.0	1013.8	1675213		30 18.9	0.3	19.4
#####	11:00	14.2	105.3	1013.8	1885614		30 18.5	0.2	19.1
#####	12:00		105.8	1013.7			30		
#####	13:00		107.7	1013.5			30		
#####	14:00	14.2	107.6	1013.1	1696578		30 19.0	0.2	19.6
#####	15:00	14.2	109.2	1012.6	1585110		30 19.1	0.2	19.7
#####	16:00	14.2	109.7	1012.3	1745334		30 18.9	0.2	19.5
#####	17:00	14.2	109.2	1012.3	1822527		30 18.8	0.2	19.4
#####	18:00	14.2	110.2	1012.0	1794144		30 18.8	0.2	19.4
#####	19:00	14.2	109.4	1011.9	1921645		30 18.8	0.2	19.4
#####	20:00	14.2	108.3	1012.3	1987214		30 18.8	0.2	19.4
#####	21:00	14.1	106.1	1012.8	1920968		30 18.9	0.2	19.4
#####	22:00	14.1	105.4	1013.2	1743461		30 19.0	0.2	19.5
#####	23:00	14.1	104.8	1013.4	1852006		30 19.2	0.2	19.8
#####	24:00:00	14.2	102.3	1013.6	2000417		30 20.0	0.2	20.5

CO  
mg/Nm<sup>3</sup>

0.7  
0.5  
0.6  
0.6  
0.6

0.5  
0.4  
0.4  
0.4  
0.4  
0.4  
0.4  
0.4  
0.4  
0.4  
0.5