

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.0	90.4	999.4	688078		30 18.0	2.0	18.6
#####	02:00	14.0	86.1	998.8	438622		30 17.9	2.3	18.5
#####	03:00	13.9	86.6	998.1	494661		30 17.3	2.2	17.9
#####	04:00	14.0	86.2	997.9	1579212		30 17.8	2.4	18.4
#####	05:00	14.0	85.7	998.2	1535641		30 18.2	2.1	18.7
#####	06:00	14.0	85.7	997.5	1137170		30 17.9	2.2	18.5
#####	07:00	13.8	92.2	997.8	1637036		30 17.5	1.3	18.0
#####	08:00	13.8	92.3	997.8	1438593		30 17.6	1.1	18.2
#####	09:00	13.5	94.6	998.0	1301883		30 16.7	0.4	17.2
#####	10:00	13.8	91.1	997.9	1101352		30 16.8	1.2	17.4
#####	11:00						31		
#####	12:00						34		
#####	13:00						34		
#####	14:00						34		
#####	15:00						34		
#####	16:00						34		
#####	17:00						34		
#####	18:00						31		
#####	19:00	13.9	93.7	1001.1	1139784		30 18.4	1.3	19.1
#####	20:00	13.5	96.6	1000.8	1709455		30 16.7	0.5	17.2
#####	21:00	13.4	96.5	1000.8	1875214		30 15.4	0.4	16.0
#####	22:00	14.0	89.5	1000.9	1121947		30 17.4	2.0	18.0
#####	23:00	13.6	95.3	1000.7	1718369		30 16.7	0.4	17.2
#####	24:00:00	14.0	88.9	1000.7	1102492		30 18.1	1.9	18.6

CO
mg/Nm³
4.1
4.7
4.6
4.8
4.3
4.5
2.8
2.3
0.9
2.6

1.3
1.1
0.8
4.1
1.0
3.9