

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	13.8	99.5	1007.3	1531537	30	18.4	0.1	18.9
#####	02:00					34			
#####	03:00					34			
#####	04:00					34			
#####	05:00					34			
#####	06:00					31			
#####	07:00	14.3	90.4	1007.2	822712	30	21.3	2.2	21.7
#####	08:00	14.4	88.8	1007.3	539616	30	20.9	2.4	21.3
#####	09:00	14.1	93.1	1007.4	899418	30	20.1	1.3	20.6
#####	10:00	13.8	99.9	1007.5	1487458	30	18.4	0.2	18.9
#####	11:00	13.8	100.4	1007.8	1642713	30	18.1	0.1	18.6
#####	12:00	13.8	100.5	1007.9	1667080	30	18.0	0.1	18.5
#####	13:00	13.8	100.4	1008.0	1717100	30	17.9	0.1	18.5
#####	14:00	13.9	101.6	1007.8	1546208	30	18.3	0.1	18.8
#####	15:00	13.9	101.9	1007.7	1643754	30	18.1	0.1	18.7
#####	16:00	13.9	101.4	1007.6	1720930	30	18.2	0.2	18.8
#####	17:00	13.9	101.1	1007.3	1720189	30	18.3	0.2	18.9
#####	18:00	13.8	100.7	1007.4	1770755	30	18.4	0.1	18.9
#####	19:00	13.8	100.6	1007.9	1859836	30	18.5	0.2	19.0
#####	20:00	13.8	101.3	1008.0	1594367	30	18.5	0.1	19.0
#####	21:00	13.8	100.9	1008.6	1761518	30	18.5	0.2	19.0
#####	22:00	13.8	99.7	1009.0	1676442	30	18.8	0.1	19.3
#####	23:00	13.8	100.3	1009.0	1652780	30	18.8	0.1	19.3
#####	24:00:00	13.9	99.4	1009.1	1619410	30	19.1	0.2	19.5

CO
mg/Nm3
0.4

4.5
4.9
2.6
0.5
0.4
0.4
0.4
0.3
0.4
0.4
0.4
0.3
0.4
0.4
0.4
0.4
0.4
0.4