

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.1	101.7	1013.1	1857623		30 20.7	0.3	21.2
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	14.3	96.1	1012.5	1309180		30 22.9	0.7	23.3
#####	08:00	14.4	95.8	1012.4	1044273		30 22.0	0.7	22.4
#####	09:00	14.2	100.6	1012.7	1460517		30 20.3	0.3	20.8
#####	10:00	14.2	102.2	1012.9	1860237		30 19.6	0.3	20.1
#####	11:00	14.3	104.4	1012.7	1619799		30 18.9	0.3	19.5
#####	12:00	14.3	106.6	1012.3	1659416		30 18.8	0.3	19.4
#####	13:00	14.2	108.8	1012.1	1771757		30 18.7	0.3	19.3
#####	14:00	14.3	108.9	1012.0	1782179		30 18.8	0.3	19.4
#####	15:00	14.3	108.7	1011.8	1582537		30 18.5	0.3	19.1
#####	16:00	14.2	108.8	1011.5	1667300		30 18.3	0.3	18.9
#####	17:00	14.2	108.8	1011.4	1802591		30 18.2	0.3	18.8
#####	18:00	14.2	109.4	1011.3	1818385		30 18.3	0.2	18.9
#####	19:00	14.2	108.9	1011.4	1808799		30 18.6	0.2	19.1
#####	20:00	14.1	107.3	1011.5	1805040		30 18.7	0.2	19.2
#####	21:00	14.3	103.8	1012.2	1913147		30 21.7	0.3	22.1
#####	22:00	14.2	103.8	1012.7	1959308		30 20.2	0.3	20.7
#####	23:00	14.2	101.8	1012.7	1962742		30 21.6	0.3	22.0
#####	24:00:00	14.2	101.7	1012.6	1968500		30 21.4	0.3	21.8

CO  
mg/Nm3  
0.6

1.4  
1.5  
0.8  
0.7  
0.6  
0.7  
0.7  
0.6  
0.6  
0.6  
0.6  
0.6  
0.6  
0.6  
0.6  
0.6  
0.6