

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	13.8	96.3	1008.0	1539223		30 20.2	0.6	20.6
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	14.0	97.9	1007.9	1320089		30 20.7	0.4	21.1
#####	08:00	13.8	99.7	1007.9	1557733		30 18.6	0.2	19.1
#####	09:00	13.9	100.3	1007.8	1406749		30 17.9	0.2	18.4
#####	10:00	14.0	99.6	1008.2	1234790		30 19.0	0.5	19.5
#####	11:00	14.5	91.4	1008.6	512402		30 21.4	1.7	21.8
#####	12:00	14.4	91.7	1008.7	559510		30 20.8	1.4	21.3
#####	13:00	14.5	90.4	1008.4	462945		30 21.8	1.6	22.2
#####	14:00	14.4	91.5	1007.8	576673		30 20.7	1.5	21.2
#####	15:00	14.5	90.8	1007.8	629554		30 21.7	1.6	22.2
#####	16:00	14.5	90.1	1008.0	566903		30 21.8	1.6	22.2
#####	17:00	14.5	89.8	1008.0	462907		30 21.7	1.6	22.1
#####	18:00	14.5	90.1	1008.2	464794		30 21.7	1.7	22.1
#####	19:00	14.5	89.6	1008.3	698132		30 21.6	1.7	22.1
#####	20:00	14.2	93.5	1008.6	1236990		30 20.2	1.1	20.7
#####	21:00	13.8	99.8	1008.9	1873080		30 17.8	0.2	18.4
#####	22:00	14.3	92.4	1009.5	1042068		30 19.8	1.7	20.3
#####	23:00	14.5	88.0	1009.5	755562		30 21.0	2.1	21.5
#####	24:00:00	14.4	88.2	1009.6	865449		30 21.0	2.1	21.5

CO
mg/Nm3
1.3

0.9
0.6
0.5
1.1
3.5
2.8
3.4
3.0
3.3
3.4
3.3
3.5
3.6
2.3
0.5
3.4
4.4
4.3