

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.0	100.3	1015.3	1362583		30 20.7	0.2	21.1
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						34		
#####	07:00						31		
#####	08:00	14.0	98.5	1014.0	1248701		30 21.2	0.4	21.5
#####	09:00	14.1	98.5	1013.9	1144201		30 21.3	0.2	21.7
#####	10:00	14.0	101.7	1013.9	1503552		30 19.4	0.2	19.9
#####	11:00	14.0	103.9	1013.7	1524015		30 19.1	0.2	19.6
#####	12:00	14.0	104.7	1013.4	1584879		30 18.7	0.2	19.2
#####	13:00	14.0	105.5	1013.2	1519883		30 18.5	0.2	19.1
#####	14:00	14.0	105.7	1013.0	1538856		30 18.7	0.2	19.2
#####	15:00	14.0	106.0	1012.7	1516158		30 18.5	0.1	19.0
#####	16:00	14.0	105.8	1012.3	1490502		30 18.6	0.1	19.2
#####	17:00	14.1	104.7	1012.0	1369844		30 20.0	0.2	20.5
#####	18:00	14.0	106.3	1011.7	1517379		30 19.0	0.2	19.5
#####	19:00	13.9	105.3	1011.8	1544961		30 19.2	0.2	19.7
#####	20:00	13.9	104.1	1011.9	1625153		30 19.2	0.2	19.6
#####	21:00	13.9	103.1	1012.5	1603744		30 19.2	0.2	19.7
#####	22:00	13.9	102.6	1013.1	1518864		30 19.4	0.1	19.9
#####	23:00	13.9	102.3	1013.6	1633977		30 19.7	0.2	20.1
#####	24:00:00	14.0	101.5	1013.7	1327357		30 20.2	0.2	20.6

CO
mg/Nm³
0.4

[illegible]