

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	13.9	99.6	1015.2	1580451		30 19.9	0.2	20.3
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	13.9	99.3	1014.3	1541033		30 21.2	0.4	21.5
#####	08:00	13.9	99.7	1014.2	1606190		30 19.4	0.2	19.9
#####	09:00	14.0	98.9	1014.1	1290928		30 20.1	0.2	20.6
#####	10:00	13.9	100.9	1014.2	1665505		30 19.1	0.2	19.6
#####	11:00	14.0	102.6	1014.4	1458176		30 18.5	0.2	19.1
#####	12:00	14.0	104.6	1014.0	1441416		30 18.3	0.2	18.8
#####	13:00	14.0	105.0	1013.6	1664000		30 18.2	0.2	18.7
#####	14:00	14.0	105.4	1013.0	1507763		30 18.0	0.1	18.5
#####	15:00	13.9	107.5	1012.2	1405891		30 18.1	0.2	18.6
#####	16:00	13.9	107.9	1011.8	1497955		30 18.1	0.2	18.7
#####	17:00	14.5	99.4	1012.1	740442		30 20.9	1.4	21.4
#####	18:00	13.9	104.6	1011.8	1547895		30 19.0	0.2	19.5
#####	19:00	13.8	105.6	1011.9	1559556		30 18.7	0.2	19.1
#####	20:00	13.8	104.7	1012.2	1661136		30 18.9	0.2	19.4
#####	21:00	13.8	103.9	1013.1	1710582		30 19.1	0.2	19.6
#####	22:00	13.9	103.3	1013.7	1741807		30 19.3	0.2	19.8
#####	23:00	13.8	102.6	1013.9	1526943		30 19.4	0.2	19.8
#####	24:00:00	13.9	101.5	1014.2	1501743		30 19.9	0.2	20.4

CO
mg/Nm3
0.4

0.8
0.4
0.5
0.5
0.5
0.4
0.4
0.4
0.4
0.4
3.0
0.5
0.4
0.4
0.4
0.5
0.5
0.5