

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.0	102.7	1009.1	1974953		30 19.6	0.7	20.0
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						34		
#####	07:00						34		
#####	08:00						31		
#####	09:00	14.2	102.2	1007.4	1580950		30 21.7	0.6	22.1
#####	10:00	14.1	104.3	1007.4	1984160		30 18.9	0.6	19.5
#####	11:00	14.2	106.8	1007.3	1801887		30 18.5	0.5	19.1
#####	12:00	14.2	108.1	1007.1	1862120		30 18.4	0.5	19.0
#####	13:00	14.2	110.1	1006.8	1703164		30 18.7	0.3	19.3
#####	14:00	14.5	108.3	1006.4	1877519		30 21.8	0.5	22.2
#####	15:00	14.4	108.5	1006.0	1617048		30 21.2	0.3	21.6
#####	16:00	14.3	109.8	1005.9	1439848		30 19.4	0.2	20.0
#####	17:00	14.2	110.0	1005.5	1826406		30 19.4	0.2	20.0
#####	18:00	14.2	109.5	1005.8	1877169		30 19.2	0.2	19.7
#####	19:00	14.2	109.0	1006.7	1971716		30 19.0	0.2	19.5
#####	20:00	14.2	107.6	1007.4	1943898		30 19.1	0.3	19.6
#####	21:00	14.1	105.1	1007.3	1986996		30 19.0	0.3	19.6
#####	22:00	14.1	104.7	1007.7	1804935		30 19.1	0.2	19.7
#####	23:00	14.1	104.5	1008.3	1980107		30 19.2	0.5	19.7
#####	24:00:00	14.2	102.4	1008.5	1959540		30 20.4	0.6	20.9

CO
mg/Nm3
1.5

1.2
1.3
1.0
1.2
0.7
1.1
0.6
0.4
0.4
0.4
0.5
0.7
0.7
0.4
1.0
1.4