

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.3	86.2	1017.0	985231		30 21.2	2.6	21.6
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	14.5	89.0	1018.4	1407281		30 22.7	2.6	23.1
#####	08:00	14.2	91.1	1018.5	1557743		30 21.6	2.1	21.9
#####	09:00	13.7	96.7	1018.6	1898542		30 19.4	0.3	19.8
#####	10:00	13.9	95.2	1019.5	1735781		30 20.5	0.3	20.9
#####	11:00	14.0	94.6	1020.2	1672798		30 21.4	0.3	21.8
#####	12:00	14.1	93.5	1020.3	1499838		30 22.6	0.4	22.9
#####	13:00	14.4	89.1	1020.5	1046485		30 21.9	1.8	22.3
#####	14:00	14.4	85.4	1020.5	750500		30 21.6	2.8	22.1
#####	15:00	14.4	87.0	1020.6	825086		30 21.9	2.3	22.3
#####	16:00	13.9	96.8	1020.9	1488195		30 19.3	0.7	19.8
#####	17:00	14.3	88.3	1021.7	1009385		30 21.6	1.7	22.0
#####	18:00	13.8	95.4	1021.9	1910026		30 19.0	0.3	19.4
#####	19:00	13.8	95.8	1022.4	1908578		30 18.9	0.3	19.4
#####	20:00	13.8	95.7	1022.8	1910338		30 19.0	0.3	19.4
#####	21:00	13.8	95.5	1023.4	1911768		30 19.0	0.3	19.5
#####	22:00	13.8	95.9	1023.5	1900992		30 19.0	0.3	19.4
#####	23:00	13.8	95.1	1024.1	1912866		30 19.1	0.3	19.6
#####	24:00:00	14.3	88.3	1024.6	1659046		30 21.9	1.7	22.3

CO  
mg/Nm3  
5.2

5.3  
4.2  
0.7  
0.7  
0.7  
0.8  
3.8  
5.6  
4.7  
1.4  
3.4  
0.8  
0.7  
0.7  
0.7  
0.7  
0.8  
3.5