

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00						34		
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						34		
#####	07:00						31		
#####	08:00	13.6	100.3	1002.0	1780898		30 20.4	15.3	20.2
#####	09:00	13.6	98.4	1001.9	1707669		30 18.8	0.2	19.2
#####	10:00	13.7	98.0	1001.3	1182781		30 19.9	0.2	20.3
#####	11:00	13.8	97.6	1001.0	1739656		30 20.1	0.2	20.5
#####	12:00	13.8	97.7	1000.9	1590916		30 20.3	0.2	20.6
#####	13:00	13.8	98.2	1000.5	1027527		30 20.2	0.3	20.6
#####	14:00	14.0	95.1	1000.0	1156433		30 20.3	1.2	20.7
#####	15:00	13.7	99.1	999.5	1738962		30 18.9	0.7	19.3
#####	16:00	13.9	98.2	999.7	1908790		30 20.6	0.4	21.0
#####	17:00	13.8	98.6	999.9	1871752		30 20.3	0.3	20.7
#####	18:00	13.7	99.2	999.6	1643560		30 19.6	0.3	19.9
#####	19:00	13.7	98.7	999.5	1626163		30 19.7	0.3	20.1
#####	20:00	13.6	100.5	999.4	1692066		30 18.2	0.2	18.7
#####	21:00	13.6	98.4	1000.2	2066382		30 19.5	0.2	19.8
#####	22:00	13.6	99.1	1000.7	2062246		30 18.7	0.2	19.1
#####	23:00	13.7	97.6	1001.2	2068382		30 20.2	0.3	20.5
#####	24:00:00	13.6	98.3	1001.2	2064567		30 19.0	0.4	19.4

CO
mg/Nm3

0.6
0.4
0.4
0.6
0.5
0.7
2.5
1.4
1.0
0.8
0.6
0.6
0.5
0.5
0.6
0.7
0.9