

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	13.9	100.0	1016.3	1749179		30 20.8	0.0	21.2
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	13.9	103.2	1015.3	1584062		30 22.7	0.1	22.9
#####	08:00	13.8	102.3	1015.1	1656303		30 20.7	0.0	21.0
#####	09:00	14.0	101.0	1015.3	1445378		30 20.8	0.0	21.1
#####	10:00	13.8	102.0	1015.2	1679242		30 20.6	0.0	20.9
#####	11:00	13.8	102.7	1015.1	1563404		30 20.1	0.0	20.4
#####	12:00	13.8	101.6	1014.6	1780926		30 20.1	0.0	20.4
#####	13:00	13.8	101.1	1014.3	1860944		30 20.1	0.1	20.5
#####	14:00	13.9	101.6	1013.9	1730030		30 20.1	0.1	20.5
#####	15:00	13.8	102.5	1013.3	1498383		30 20.0	0.1	20.4
#####	16:00	13.8	104.1	1012.3	1571936		30 20.0	0.1	20.4
#####	17:00	13.9	104.2	1012.3	1782688		30 20.3	0.1	20.7
#####	18:00	14.1	98.6	1013.3	1885982		30 22.6	0.1	22.8
#####	19:00	14.0	97.6	1014.0	1890054		30 22.4	0.1	22.7
#####	20:00	14.0	98.6	1014.2	1852455		30 21.1	0.0	21.4
#####	21:00	14.3	93.5	1014.4	970958		30 22.2	1.5	22.6
#####	22:00	14.3	93.4	1014.6	749849		30 23.1	1.5	23.4
#####	23:00	14.3	96.4	1014.5	1090732		30 23.5	0.6	23.8
#####	24:00:00	14.0	98.7	1014.5	1520064		30 21.3	0.1	21.7

CO
mg/Nm3
0.1

0.3
0.1
0.1
0.1
0.1
0.1
0.3
0.3
0.2
0.2
0.2
0.3
0.2
0.2
3.1
3.1
1.3
0.2