

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00					34			
#####	02:00					34			
#####	03:00					34			
#####	04:00					31			
#####	05:00					31			
#####	06:00	14.5	97.7	1011.7	1253938	30	23.9	12.2	23.8
#####	07:00	14.3	97.8	1011.8	1408309	30	22.4	0.4	22.8
#####	08:00	14.3	98.6	1011.6	1116413	30	21.9	0.3	22.3
#####	09:00	14.2	100.6	1011.2	1247991	30	20.6	0.3	21.0
#####	10:00	14.4	100.8	1011.1	1096351	30	21.9	0.4	22.3
#####	11:00	14.1	105.1	1010.9	1644773	30	19.1	0.3	19.6
#####	12:00	14.1	106.0	1010.6	1543213	30	18.5	0.3	19.1
#####	13:00	14.1	106.7	1010.2	1544415	30	18.6	0.3	19.1
#####	14:00	14.3	107.3	1009.6	1517349	30	19.9	0.3	20.4
#####	15:00	14.2	107.7	1009.1	1590254	30	19.3	0.3	19.8
#####	16:00	14.6	102.1	1009.2	1043651	30	21.8	1.1	22.3
#####	17:00	14.4	104.9	1008.9	1338052	30	21.7	0.4	22.1
#####	18:00	14.3	105.9	1008.6	1410987	30	21.2	0.3	21.6
#####	19:00	14.5	103.1	1008.8	1165224	30	21.6	1.0	22.1
#####	20:00	14.0	105.9	1008.8	1743245	30	19.3	0.3	19.8
#####	21:00	14.0	105.1	1009.2	1783162	30	19.3	0.3	19.8
#####	22:00	14.0	104.3	1009.9	1816597	30	19.3	0.3	19.8
#####	23:00	14.2	103.9	1010.1	1477156	30	20.5	0.3	21.0
#####	24:00:00	14.2	104.5	1010.2	1674694	30	20.3	0.3	20.7

CO
mg/Nm³

1.5
0.9
0.8
0.7
0.8
0.7
0.7
0.7
0.8
0.7
2.4
0.9
0.8
2.0
0.7
0.6
0.6
0.6
0.6