

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00					31			
#####	02:00					31			
#####	03:00					31			
#####	04:00	14.7	89.9	1011.4	1619797	30	22.9	2.7	23.4
#####	05:00	14.7	89.6	1011.5	1685110	30	22.8	2.7	23.2
#####	06:00	14.6	90.3	1011.7	1594636	30	22.6	2.3	23.0
#####	07:00	14.3	97.2	1011.4	1015370	30	23.5	0.5	23.7
#####	08:00	14.3	99.2	1011.0	1133957	30	22.9	0.3	23.2
#####	09:00	14.2	101.5	1010.9	1166313	30	22.0	0.3	22.4
#####	10:00	14.1	105.7	1010.7	1458734	30	19.9	0.2	20.3
#####	11:00	14.2	108.3	1010.7	1725121	30	19.4	0.2	19.9
#####	12:00	14.2	109.0	1010.7	1790336	30	19.5	0.2	20.0
#####	13:00	14.3	110.0	1010.6	1700293	30	19.6	0.2	20.1
#####	14:00	14.3	111.8	1010.1	1628411	30	19.5	0.2	20.0
#####	15:00	14.3	111.1	1010.0	1718210	30	19.6	0.2	20.1
#####	16:00	14.3	111.3	1009.7	1606974	30	19.3	0.2	19.9
#####	17:00	14.4	111.9	1009.4	1736846	30	19.0	0.2	19.6
#####	18:00	14.4	110.5	1009.0	1828717	30	21.0	0.2	21.5
#####	19:00	14.2	110.3	1009.0	1773815	30	20.0	0.2	20.5
#####	20:00	14.1	110.3	1009.1	1922115	30	19.1	0.2	19.7
#####	21:00	14.1	108.1	1009.3	1894508	30	19.5	0.2	20.0
#####	22:00	14.1	106.1	1010.2	1918968	30	20.1	0.2	20.6
#####	23:00	14.1	105.0	1010.6	1747005	30	20.2	0.2	20.6
#####	24:00:00	14.3	103.3	1010.9	1714964	30	21.3	0.4	21.7

