

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.2	99.3	1006.4	2000265		30 20.5	0.7	21.0
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						34		
#####	07:00						31		
#####	08:00	14.1	99.6	1009.8	1376527		30 21.4	0.4	21.7
#####	09:00	14.5	98.2	1010.3	1244663		30 22.3	0.5	22.7
#####	10:00	14.5	95.3	1010.9	1311346		30 21.1	1.9	21.6
#####	11:00		100.6	1010.8			30		
#####	12:00	14.5	101.4	1011.5	1924915		30 19.5	0.8	20.1
#####	13:00	14.9	94.6	1012.5	1783618		30 22.2	2.0	22.7
#####	14:00	14.6	95.7	1012.7	1559120		30 21.3	1.5	21.8
#####	15:00	14.5	99.6	1012.6	1430986		30 21.2	0.4	21.7
#####	16:00	14.4	103.0	1012.5	1707452		30 20.9	0.1	21.4
#####	17:00	14.4	102.6	1012.5	1341782		30 21.1	0.1	21.6
#####	18:00	14.4	103.9	1012.4	1699329		30 20.4	0.1	20.9
#####	19:00	14.3	104.6	1012.1	1899975		30 19.2	0.1	19.7
#####	20:00	14.2	104.1	1012.0	2005609		30 18.5	0.1	19.1
#####	21:00	14.2	102.6	1012.7	2001330		30 18.6	0.1	19.2
#####	22:00	14.4	98.3	1013.4	2009758		30 21.9	0.2	22.4
#####	23:00	14.3	98.5	1013.8	2014167		30 21.4	0.1	21.8
#####	24:00:00	14.3	97.8	1013.6	1780675		30 21.2	0.1	21.6

CO  
mg/Nm3  
1.4

0.9  
1.1  
4.0

1.7  
4.1  
3.1  
1.0  
0.4  
0.4  
0.3  
0.3  
0.3  
0.3  
0.5  
0.3  
0.4