

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.5	99.6	1009.2	1229068		30 22.3	1.1	22.7
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	14.2	98.3	1008.5	1877076		30 21.6	0.5	22.0
#####	08:00	14.1	101.7	1008.6	1691884		30 19.3	0.2	19.8
#####	09:00	14.1	103.3	1008.3	1392882		30 19.2	0.2	19.8
#####	10:00	14.0	105.1	1008.3	1627627		30 19.5	0.2	19.9
#####	11:00	14.0	106.7	1008.3	1807608		30 19.3	0.3	19.8
#####	12:00	14.0	107.6	1008.2	1700772		30 19.1	0.2	19.6
#####	13:00	14.0	109.2	1008.0	1922344		30 18.5	0.2	19.0
#####	14:00	14.0	109.4	1007.7	1764960		30 18.9	0.2	19.4
#####	15:00	14.0	108.8	1007.5	1734321		30 19.0	0.2	19.5
#####	16:00	14.2	108.7	1007.2	1770920		30 19.2	0.2	19.8
#####	17:00	14.7	105.0	1007.0	920436		30 21.9	1.3	22.4
#####	18:00	14.6	101.4	1006.6	1284623		30 21.5	1.5	22.0
#####	19:00	14.7	97.1	1006.5	1379521		30 22.1	2.0	22.6
#####	20:00	14.6	94.8	1006.9	1328704		30 22.3	1.8	22.8
#####	21:00						34		
#####	22:00						34		
#####	23:00						34		
#####	24:00:00						34		

CO  
mg/Nm3  
2.3

1.0  
0.6  
0.5  
0.6  
0.6  
0.5  
0.6  
0.5  
0.5  
0.5  
2.7  
3.1  
4.0  
3.7