

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.2	103.1	1010.9	1927218		30 21.5	0.3	21.9
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						31		
#####	07:00	14.2	98.2	1010.0	1584069		30 21.9	0.5	22.3
#####	08:00	14.1	102.2	1009.7	1442910		30 19.9	0.3	20.4
#####	09:00	14.2	102.6	1009.6	1211515		30 20.9	0.3	21.4
#####	10:00	14.2	105.8	1009.5	1599508		30 19.5	0.3	20.0
#####	11:00	14.2	107.0	1009.6	1951357		30 19.0	0.3	19.5
#####	12:00	14.2	108.7	1009.2	1630634		30 18.7	0.2	19.3
#####	13:00	14.3	111.6	1008.9	1507727		30 18.6	0.2	19.2
#####	14:00	14.3	112.0	1008.5	1696820		30 18.1	0.2	18.8
#####	15:00	14.3	111.8	1008.1	1678738		30 18.1	0.2	18.7
#####	16:00	14.3	111.9	1007.7	1844181		30 18.0	0.2	18.7
#####	17:00	14.3	111.6	1007.2	1740041		30 18.0	0.2	18.6
#####	18:00	14.2	112.2	1007.3	1804750		30 18.4	0.2	19.0
#####	19:00	14.1	111.5	1007.3	1937699		30 18.4	0.2	18.9
#####	20:00	14.1	110.4	1007.4	1970739		30 18.4	0.2	19.0
#####	21:00	14.1	107.9	1007.8	1928731		30 19.0	0.2	19.5
#####	22:00	14.0	106.4	1008.3	1803275		30 19.4	0.2	19.9
#####	23:00	14.1	105.3	1009.1	1935558		30 19.6	0.2	20.1
#####	24:00:00	14.0	105.0	1009.2	1968204		30 19.5	0.2	20.0

