

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	13.9	97.3	1018.7	1898284		30 19.4	0.0	19.8
#####	02:00	14.6	86.0	1019.0	1644177		30 22.0	2.3	22.4
#####	03:00	14.6	85.7	1018.8	1271802		30 22.2	2.4	22.7
#####	04:00	14.6	86.0	1018.8	1356444		30 22.2	2.2	22.7
#####	05:00	14.6	86.4	1018.9	1612840		30 22.3	2.2	22.8
#####	06:00	14.6	87.0	1019.0	1712684		30 22.5	2.0	22.9
#####	07:00	14.0	96.2	1019.2	1815665		30 20.4	0.1	20.8
#####	08:00	13.9	98.2	1019.3	1848679		30 18.8	0.0	19.3
#####	09:00	14.1	95.8	1019.9	1446074		30 20.9	0.1	21.3
#####	10:00	14.6	88.3	1020.6	1093008		30 22.4	1.6	22.8
#####	11:00	14.7	86.1	1020.9	949883		30 22.3	1.8	22.8
#####	12:00	15.0	86.7	1020.6	831348		30 24.2	45.9	24.0
#####	13:00						34		
#####	14:00						34		
#####	15:00						34		
#####	16:00						34		
#####	17:00						31		
#####	18:00	13.9	100.0	1020.6	1636783		30 20.2	0.2	20.6
#####	19:00	14.1	97.3	1021.3	1615937		30 20.2	0.2	20.7
#####	20:00	13.9	98.8	1021.4	1885862		30 19.4	0.2	19.9
#####	21:00	14.0	98.1	1022.0	1804664		30 19.5	0.2	20.0
#####	22:00	13.9	97.7	1022.3	1890323		30 19.5	0.1	19.9
#####	23:00	13.9	97.1	1022.3	1903232		30 19.0	0.1	19.5
#####	24:00:00	14.1	94.4	1022.6	1791764		30 21.3	0.2	21.7

CO
mg/Nm3
0.2
4.7
4.9
4.6
4.4
4.0
0.3
0.1
0.2
3.3
3.7
3.8

0.4
0.4
0.4
0.4
0.4
0.4
0.4