

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00	14.5	85.1	1018.8	2006524		30 20.2	3.7	20.8
#####	02:00	14.5	86.4	1018.6	1805532		30 20.6	3.2	21.1
#####	03:00	14.4	86.5	1016.9	1968522		30 20.7	2.7	21.2
#####	04:00	14.4	86.6	1015.2	1457904		30 20.2	3.2	20.7
#####	05:00	14.4	86.0	1013.9	989225		30 20.5	2.6	21.0
#####	06:00	14.3	87.1	1013.3	938258		30 20.1	2.5	20.6
#####	07:00	14.0	93.3	1012.8	1248090		30 19.6	0.5	20.0
#####	08:00	13.7	96.2	1012.7	1875973		30 17.7	0.1	18.2
#####	09:00	13.7	95.9	1013.2	1916248		30 17.4	0.1	17.9
#####	10:00	13.7	96.4	1012.7	1794991		30 17.6	0.1	18.1
#####	11:00	13.7	96.4	1011.6	1751325		30 17.2	0.1	17.7
#####	12:00	13.8	96.0	1012.7	1859380		30 17.2	0.0	17.8
#####	13:00						34		
#####	14:00						34		
#####	15:00						34		
#####	16:00						31		
#####	17:00	13.7	98.6	1009.6	1578144		30 18.7	0.1	19.1
#####	18:00	13.7	96.9	1009.6	1845262		30 17.7	0.0	18.2
#####	19:00	13.7	96.9	1009.4	1949188		30 17.5	0.0	18.1
#####	20:00	13.6	96.6	1009.2	1939922		30 17.5	0.0	18.0
#####	21:00	13.6	96.1	1009.2	1945844		30 17.5	0.0	18.0
#####	22:00	13.7	95.9	1009.2	1866034		30 17.3	0.0	17.9
#####	23:00	13.7	95.7	1009.3	1937268		30 17.2	0.0	17.8
#####	24:00:00	13.8	94.0	1009.4	1789472		30 17.8	0.0	18.3

CO
mg/Nm3
7.4
6.6
5.5
6.4
5.4
5.0
1.2
0.2
0.2
0.3
0.2
0.1

0.2
0.1
0.1
0.2
0.1
0.1
0.1
0.1
0.1