

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00					34			
#####	02:00					34			
#####	03:00					34			
#####	04:00					34			
#####	05:00					34			
#####	06:00					31			
#####	07:00					31			
#####	08:00	13.5	98.3	1003.3	1866290	30	16.6	0.4	17.2
#####	09:00	13.4	95.0	1003.6	1953202	30	15.4	0.3	16.0
#####	10:00	13.4	94.9	1004.1	1856371	30	15.3	0.3	15.9
#####	11:00	13.5	94.3	1004.9	1788027	30	15.5	0.3	16.2
#####	12:00	13.9	90.3	1005.7	882126	30	17.0	1.1	17.6
#####	13:00	14.1	86.0	1006.2	554973	30	17.5	2.5	18.2
#####	14:00	14.1	85.9	1006.2	412248	30	17.6	2.9	18.2
#####	15:00	14.1	86.2	1006.3	496726	30	17.8	2.7	18.4
#####	16:00	14.2	87.0	1006.6	540641	30	18.3	2.2	18.9
#####	17:00	14.1	87.2	1007.2	460384	30	17.4	2.8	18.1
#####	18:00	14.0	88.9	1007.3	1143628	30	17.6	2.1	18.2
#####	19:00	13.5	96.3	1007.8	1757334	30	15.4	0.4	16.1
#####	20:00	13.5	96.1	1008.5	1862941	30	15.3	0.4	15.9
#####	21:00	13.5	96.0	1008.7	1886646	30	15.3	0.5	15.9
#####	22:00	13.5	95.5	1008.9	1935904	30	15.5	0.5	16.1
#####	23:00	13.6	94.0	1009.4	1982430	30	16.0	0.6	16.6
#####	24:00:00	14.1	89.7	1009.7	1687055	30	18.2	2.2	18.7

CO  
mg/Nm<sup>3</sup>

0.8  
0.7  
0.7  
0.7  
2.4  
5.2  
6.0  
5.4  
4.5  
5.8  
4.2  
0.8  
0.9  
1.0  
1.1  
1.2  
4.5