

postazione : PK-207A - Misure normalizzate e corrette in Ossigeno

data	ora	O2 %dry	TempF °C	PressF mbar	Portata m3/h	St.IMP	NOxQAL2 mg/Nm3	CO QAL2 mg/Nm3	NOx mg/Nm3
#####	01:00						34		
#####	02:00						34		
#####	03:00						34		
#####	04:00						34		
#####	05:00						34		
#####	06:00						34		
#####	07:00						31		
#####	08:00	14.1	99.8	1010.4	1350953		30 22.0	0.5	22.3
#####	09:00	14.2	98.8	1010.5	1462518		30 21.9	0.4	22.2
#####	10:00	14.3	99.5	1010.5	1683828		30 22.1	0.4	22.5
#####	11:00	14.3	101.1	1010.5	1355938		30 22.1	0.3	22.5
#####	12:00	14.3	103.4	1010.1	1349226		30 21.7	0.3	22.1
#####	13:00	14.3	104.3	1010.1	1795149		30 21.7	0.3	22.1
#####	14:00	14.3	105.4	1009.5	1248574		30 21.6	0.3	22.0
#####	15:00	14.3	106.6	1009.2	1400405		30 21.7	0.3	22.1
#####	16:00	14.3	106.8	1009.5	1602937		30 21.6	0.3	22.0
#####	17:00	14.3	103.8	1009.5	1501073		30 21.8	0.3	22.2
#####	18:00	14.3	104.6	1009.7	1379626		30 21.8	0.3	22.2
#####	19:00	14.0	108.2	1009.2	1810918		30 19.6	0.3	20.0
#####	20:00	14.0	107.0	1009.7	1970951		30 19.4	0.3	19.9
#####	21:00	14.0	106.3	1009.9	1697161		30 19.6	0.3	20.1
#####	22:00	14.0	105.6	1010.4	1876506		30 19.8	0.3	20.3
#####	23:00	14.0	104.9	1010.8	1725224		30 19.9	0.3	20.3
#####	24:00:00	14.1	103.8	1011.3	1826908		30 20.5	0.3	20.9

CO  
mg/Nm3

1.2  
0.8  
0.8  
0.8  
0.6  
0.7  
0.6  
0.7  
0.6  
0.7  
0.7  
0.6  
0.6  
0.7  
0.6  
0.6  
0.7